

## The Regional Municipality of Durham

### Bowmanville Drinking Water System 2018 Annual Report

**Drinking Water System Number:** 220000852

**Municipal Drinking Water Licence Number:** 003-103

**Drinking Water System Owner:** The Regional Municipality of Durham

**Drinking Water System Category:** Large Municipal Residential

This Annual Report for the calendar year 2018 is designed to inform you about your drinking water system. This report has been prepared to satisfy Section 11 of Ontario Regulation (O. Reg.) 170/03. O. Reg. 170/03 sets requirements for drinking water systems with regard to sampling and testing, levels of treatment, certification of staff, and notification of authorities and the public about water quality. Hard copies of this report and the Schedule 22 Summary Report are available at the Regional Municipality of Durham Headquarters office that is located at 605 Rossland Road East, Whitby. The annual report is also available on the [Region of Durham's website](http://www.durham.ca) at www.durham.ca. Further information regarding the Drinking Water Regulations can be found on the [Ministry of the Environment, Conservation and Parks website](http://www.ontario.ca/ministry-environment-conservation-parks) at www.ontario.ca/ministry-environment-conservation-parks.

### Drinking Water System Process Description

#### General

The Bowmanville Drinking Water System provides potable water to consumers in the Town of Bowmanville in the Township of Clarington. The water supply plant is a Class Two Water Treatment Plant with an approved capacity of 36,368 cubic metres per day (m<sup>3</sup>/d). The Bowmanville Water Supply Plant feeds a Class Two Distribution System and Class Two Trunk Distribution System. The treatment and distribution systems are owned and operated by the Regional Municipality of Durham.

The source water for the treatment process is drawn from Lake Ontario. The water supply system includes the following processes:

- Zebra mussel control (chlorine),
- Screening,
- Low lift pumping,
- Coagulation (polyaluminum chloride),
- Flocculation,
- Filtration,
- Disinfection (chlorine),
- High lift pumping,
- Water storage and distribution.

## **Raw Water Supply**

Raw water is drawn from Lake Ontario through a 1,050 millimetre diameter intake pipe extending 1,260 metres (m) into the lake. The intake structure is located at a depth of approximately 12 m. Chlorine is added at the raw water intake for zebra mussel control. The chlorine residuals and raw turbidity are continuously monitored by analyzers as the raw water enters the treatment plant.

## **Coagulation/Flocculation**

The water flows through traveling screens to remove large solids and continues towards the low lift pumps. Polyaluminum chloride (PACl) is added into a mechanical mixer upstream of the flocculation tanks. After rapid mixing, the water enters the flocculation tanks where flocculated particles are developed by slow mixing action.

## **Filtration**

Particulate matter that was present in the raw water is captured by the coagulation and flocculation process and deposited on top of the filters. The water supply plant has two dual-compartment multi-media gravity filters which discharge by gravity into a dedicated 690 cubic metre capacity clearwell, as well as a single compartment dual media gravity rapid filter which discharges into a dedicated 506 cubic metre capacity clearwell. Filter effluent turbidity and head loss are continuously monitored to indicate filter effectiveness. Treated water from the clearwells flows into the plant underground reservoir.

Filter backwash treatment includes, filter surface washing equipment, air scouring, two wastewater hopper settling tanks and a supernatant pumping well. The sludge and supernatant are discharged to the sanitary sewer system.

## **Disinfection**

Disinfection is achieved by the addition of chlorine at multiple application points throughout the plant. The free chlorine residual and turbidity are monitored continuously by online analyzers.

## **Distribution System**

The water then flows to a high lift pumping station equipped with six vertical turbine pumps. The distribution system delivers the treated water through approximately 191 kilometres of watermains in two pressure zones and includes a 2,894 cubic metre (m<sup>3</sup>) reservoir, a 1,287 m<sup>3</sup> elevated storage tank and a pumping station. Additional chlorination can be applied at the reservoir facility.

**Major Monetary expenses(above \$10,000)**

Under Section 11 of O. Reg. 170/03, a description of any major expenses incurred during this reporting period to install, repair or replace required equipment must be included in the annual report. The details of major expenses for this drinking water system are as follows:

Replacement of polybutylene service connections - \$532,451

Rebuilt # 4 and # 5 pumps at Concession St. Pumping Station (PS) - \$29,225

Repaired pump at Concession St. PS - \$13,984

Replaced chlorine analyzers at the water supply plant- \$25,249

## Tables

For a description of terms and abbreviations in all tables, refer to the glossary at the end of the report.

### Bowmanville Drinking Water System (DWS) Table 1

Summary of all Adverse Water Quality Incidents (AWQI) in 2018 Reported to Spills Action Centre in Accordance with Schedule 16-3 and 16-4 of O. Reg. 170/03.

Incident Date	Parameter	Result	Corrective Action	Corrective Action Date
April 18	Total Coliforms (distribution)	Presence	Flushed, resampled. Results met Ontario Drinking Water Quality Standards (ODWQS)	April 18

### Bowmanville DWS Table 2

Microbiological Membrane Filtration (MF) Testing Under Schedule 10 of O. Reg. 170/03.

Type of Sample	Number of Samples	Range of Escherichia Coli MF Colony Forming Units per 100 Millilitres	Range of Total Coliforms MF Colony Forming Units per 100 Millilitres
Raw	197	Non-Detect (ND) - 18	ND - 1600
Treated	2	ND	ND
Distribution	37	ND	ND

### Bowmanville DWS Table 3

Microbiological Presence Absence (P/A) Testing Under Schedule 10 of O. Reg. 170/03.

Type of Sample	Number of Samples	Escherichia Coli P/A per 100 Millilitres	Total Coliforms P/A per 100 Millilitres
Treated	197	Absence (A)	A
Distribution	726	A	A - Presence (1)*

\*Number in parenthesis represents number of exceedance(s).

**Bowmanville DWS Table 4**

**Microbiological Heterotrophic Plate Count (HPC) Testing Under Schedule 10 of O. Reg. 170/03.**

Type of Sample	Number of Samples	Range of HPC Samples Colony Forming Units per Millilitre
Treated	199	Non-Detect (ND) - 14
Distribution	412	ND - 79

**Bowmanville DWS Table 5**

**Operational Testing Done Under Schedule 7 of O. Reg. 170/03.**

Test	Number of Samples	Range of Results	Unit of Measure	Parameter Description
<b>Turbidity - Filter Effluent</b>	Continuous	0.01 - 0.15	Nephelometric Turbidity Units (NTU)	Turbidity is a measure of particles in water.
<b>Free Chlorine - Plant</b>	Continuous	1.62 - 4.04*	Milligram per Litre (mg/L)	Must be sufficient to ensure disinfection has been achieved.
<b>Free Chlorine - Distribution</b>	Continuous	0.58 - 3.7*	mg/L	Recommended level of at least 0.20 mg/L in the distribution system to maintain secondary disinfection, 0.05 mg/L is the minimum required.

\*Results include all analyzers and grab samples.

**Bowmanville DWS Table 6**

**Summary of Additional Testing and Sampling Carried Out in Accordance With the Requirement of an Approval, Order or Other Legal Instrument.**

Type of Sample	Parameter	Date Sampled	Result	MAC	Unit of Measure
Raw Water	Gross Beta	January - December	0.09 - 0.15	Not Available (N/A)	Becquerels per Litre (Bq/L)
Raw Water	Tritium	January - December	0.56 - 11.7	N/A	Bq/L
Treated Water	Tritium	January - September	Non-Detect - 11.0	7,000	Bq/L
Raw Water	Microcystin (Total)	June - October	ND	1.5	Microgram per Litre (ug/L)
Treated Water**	Microcystin (Total)	August - October	ND	1.5	ug/L
Distribution**	Microcystin (Total)	June - August	ND	1.5	ug/L

\*\*On August 10, the Region changed the total microcystin sampling location from the distribution to the point of entry to comply with the MECP Director's letter dated May 4, 2018. Prior to this date the Region collected samples from the THM sample locations in the distribution system as per previous direction from the MECP (2017) Director's letters.

## Bowmanville DWS Table 7

### Summary of Treated Water Chemical Parameters Tested Under Schedule 13 and 23 of O. Reg. 170/03.

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources <sup>1</sup>
Antimony	14	Non-Detect (ND) - 0.0009	0.006	Milligram per Litre (mg/L)	No	Fire retardants, ceramics, electronics, solder.
Arsenic	14	ND - 0.0007	0.01	mg/L	No	Mining.
Barium	2	0.0201 - 0.0205	1.0	mg/L	No	Metal refineries, oil drilling.
Boron	2	0.0245 - 0.0273	5.0	mg/L	No	Industrial.
Cadmium	14	ND	0.005	mg/L	No	Industrial.
Chromium	14	ND	0.05	mg/L	No	Industrial.
Haloacetic acids - Distribution (annual average)	12	51.3	80	Microgram per Litre (ug/L)	No	By-product of chlorination of drinking water.
Mercury	2	ND	0.001	mg/L	No	Industrial.
Selenium	14	ND	0.05	mg/L	No	Refineries, mines, chemical manufacturing.
Sodium	12	13.8 - 17.2	Not Applicable <sup>2</sup>	mg/L	No	Storm water runoff including road salt.
Trihalomethane - Distribution (annual average)	12	73.7	100	ug/L	No	By-product of chlorination of drinking water.
Uranium	2	ND	0.02	mg/L	No	Power generation.
Fluoride	12	0.08 - 0.10	1.5	mg/L	No	Mining
Nitrite	12	ND	1.0	mg/L	No	Agriculture runoff, landfill leachate and animal waste.
Nitrate	12	ND	10.0	mg/L	No	Fertilizer.

1 Parameters may occur naturally in the environment.

2 Sodium does not have a Maximum Acceptable Concentration (MAC); only an aesthetic objective of 200 mg/L. Sodium results exceeding 20 mg/L are to be reported to the Medical Officer of Health as per Schedule 16-3 (8) of O. Reg. 170/03.

### Bowmanville DWS Table 8

#### Summary of Lead Testing Under Schedule 15.1 of O. Reg. 170/03.

No lead samples from plumbing were required in 2018.

Location Type	Number of Samples	Range of Lead Results Milligram per Litre	MAC	Number of Exceedances	pH	Alkalinity Milligram per Litre
Plumbing	0	Not Applicable (N/A)	0.01	0	N/A	N/A
Distribution	8	ND - 0.0045	0.01	0	7.64 - 7.88	84.0 - 91.6

### Bowmanville DWS Table 9

#### Summary of Treated Water Organic Parameters Tested Under Schedule 24 of O. Reg. 170/03.

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources
Alachlor	2	Non-Detect (ND)	5	Microgram per Litre (ug/L)	No	Agricultural herbicide.
Atrazine + N-dealkylated metabolites	2	ND	5	ug/L	No	Agricultural herbicide.
Azinphos-methyl	2	ND	20	ug/L	No	Insecticide.
Benzene	2	ND	1	ug/L	No	Plastics manufacturing, leaking fuel tanks.
Benzo(a)pyrene	2	ND	0.01	ug/L	No	Formed from the incomplete burning of organic matter.
Bromoxynil	2	ND	5	ug/L	No	Agricultural herbicide.
Carbaryl	2	ND	90	ug/L	No	Agricultural, forestry, household insecticide.



Bowmanville DWS Table 9 continued

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources
<b>Carbofuran</b>	2	Non-Detect (ND)	90	Microgram per Litre (ug/L)	No	Agricultural insecticide.
<b>Carbon Tetrachloride</b>	2	ND	2	ug/L	No	Chemical and industrial activities.
<b>Chlorpyrifos</b>	2	ND	90	ug/L	No	Agricultural, household insecticide.
<b>Diazinon</b>	2	ND	20	ug/L	No	Agricultural, livestock, operation, residential insecticide.
<b>Dicamba</b>	2	ND	120	ug/L	No	Agricultural herbicide
<b>1,2-Dichlorobenzene</b>	2	ND	200	ug/L	No	Chemical and industrial factories.
<b>1,4-Dichlorobenzene</b>	2	ND	5	ug/L	No	Chemical and industrial factories.
<b>1,2-Dichloroethane</b>	2	ND	5	ug/L	No	Industrial chemical factories.
<b>1,1-Dichloroethylene (vinylidene chloride)</b>	2	ND	14	ug/L	No	Industrial chemical factories.
<b>Dichloromethane</b>	2	ND	50	ug/L	No	Pharmaceutical and chemical factories.
<b>2,4-dichlorophenol</b>	2	ND	900	ug/L	No	Industrial contamination, reaction with chlorine.
<b>2,4-Dichlorophenoxy acetic acid (2,4-D)</b>	2	ND	100	ug/L	No	Agricultural, residential herbicide.

**Bowmanville DWS Table 9 continued**

<b>Parameter</b>	<b>Number of Samples</b>	<b>Results Range</b>	<b>MAC</b>	<b>Unit of Measure</b>	<b>MAC Exceedance</b>	<b>Potential Sources</b>
<b>Diclofop-methyl</b>	2	Non-Detect (ND)	9	Microgram per Litre (ug/L)	No	Agricultural herbicide.
<b>Dimethoate</b>	2	ND	20	ug/L	No	Agricultural, livestock, operation, residential insecticide.
<b>Diquat</b>	2	ND	70	ug/L	No	Agricultural, aquatic herbicide.
<b>Diuron</b>	2	ND	150	ug/L	No	Agricultural, industrial herbicide.
<b>Glyphosate</b>	2	ND	280	ug/L	No	Agricultural, forestry, household herbicide.
<b>Malathion</b>	2	ND	190	ug/L	No	Pest control insecticide.
<b>2-Methyl-4-chlorophenoxyacetic acid (MCPA)</b>	2	ND	100	ug/L	No	Agricultural herbicide.
<b>Metolachlor</b>	2	ND	50	ug/L	No	Agricultural herbicide.
<b>Metribuzin</b>	2	ND	80	ug/L	No	Agricultural herbicide.
<b>Monochlorobenzene</b>	2	ND	80	ug/L	No	Industrial and agricultural chemical factories and dry cleaning facilities.
<b>Paraquat</b>	2	ND	10	ug/L	No	Agricultural, aquatic herbicide.

**Bowmanville DWS Table 9 continued**

<b>Parameter</b>	<b>Number of Samples</b>	<b>Results Range</b>	<b>MAC</b>	<b>Unit of Measure</b>	<b>MAC Exceedance</b>	<b>Potential Sources</b>
<b>Pentachlorophenol</b>	2	Non-Detect (ND)	60	Microgram per Litre (ug/L)	No	Pesticide, wood preservative residue.
<b>Phorate</b>	2	ND	2	ug/L	No	Agricultural insecticide.
<b>Picloram</b>	2	ND	190	ug/L	No	Industrial herbicide.
<b>Polychlorinated Biphenyls(PCB)</b>	2	ND	3	ug/L	No	Residue from various industrial uses.
<b>Prometryne</b>	2	ND	1	ug/L	No	Agricultural herbicide.
<b>Simazine</b>	2	ND	10	ug/L	No	Agricultural herbicide.
<b>Terbufos</b>	2	ND	1	ug/L	No	Agricultural insecticide.
<b>Tetrachloroethylene (perchloroethylene)</b>	2	ND	10	ug/L	No	Leaching from PVC pipes; discharge from factories; dry cleaners and auto shops (metal degreaser).
<b>2,3,4,6 - Tetrachlorophenol</b>	2	ND	100	ug/L	No	Wood preservative.
<b>Triallate</b>	2	ND	230	ug/L	No	Agricultural herbicide.
<b>Trichloroethylene</b>	2	ND	5	ug/L	No	Metal degreasing sites and other factories.

**Bowmanville DWS Table 9 continued**

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources
<b>2,4,6-Trichlorophenol</b>	2	Non-Detect (ND)	5	Microgram per Litre (ug/L)	No	Pesticide manufacturing.
<b>Trifluralin</b>	2	ND	45	ug/L	No	Agricultural herbicide.
<b>Vinyl Chloride</b>	2	ND	1	ug/L	No	Leaching from PVC pipes; discharge from plastics factories.

**Bowmanville DWS Table 10**

**Inorganic or Organic Parameter(s) that Exceed Half the Standard Prescribed in Schedule 2 of the Ontario Drinking Water Quality Standards.**

No inorganic or organic parameters exceeded half the maximum allowable concentration in 2018.

Parameter	Result	Unit of Measure	Date of Sample
<b>Not Applicable (N/A)</b>	N/A	N/A	N/A