




Lake Simcoe Water Pollution Control Plant

2019 Annual Performance Report





The Regional Municipality of Durham

Lake Simcoe Water Pollution Control Plant 2019 Annual Performance Report

Environmental Compliance Approval (ECA): 5292-8CYHTQ Dated June 28, 2012

Environmental Compliance Approval (Air): 8-3041-95-006 Dated February 5, 1996

The Lake Simcoe Water Pollution Control Plant (WPCP) 2019 Annual Performance Report provides staff, stakeholders and customers an overview of the performance of the Lake Simcoe WPCP.

Further, this report fulfills the annual reporting requirements of the Ontario Ministry of Environment, Conservation and Parks (MECP). This report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

Water Pollution Control Plant Process Description

General

The Lake Simcoe WPCP located in the Community of Beaverton in the Township of Brock is owned and operated by the Regional Municipality of Durham (Region). The plant is operated according to the terms and conditions of the ECA. This MECP Class 3 wastewater treatment plant utilizes an extended aeration process with tertiary treatment and is designed to treat wastewater at a rated capacity of 4,550 cubic metres per day (m³/d). The Lake Simcoe WPCP has a service population of approximately 4,121 residents.

Lake Simcoe WPCP treats wastewater from the Community of Beaverton service area utilizing the following processes;

- raw influent pumping,
- preliminary treatment,
- phosphorus removal,
- secondary treatment,
- tertiary treatment,
- disinfection and
- solids management.

Raw Influent Pumping

Wastewater is collected through approximately 24.8 kilometres of sanitary sewers in Beaverton and is conveyed to the WPCP by gravity and two sanitary sewage pumping stations (SSPS); Harbour Street and Cedar Beach located in the collection system. Flow from the two SSPS are combined in the raw sewage inlet channel.

Preliminary Treatment

Screening: There are two screen channels in the screen room for the removal of paper products and large material that could harm pumps and process equipment. One channel contains an automatic,



mechanically cleaned bar screen and the other is equipped with a bar rack to provide screening on an emergency basis. Screenings are removed in this process and transported to landfill for disposal.

Grit Removal: Vortex grit removal is provided to remove sand and small stones (grit) for protection of mechanical equipment from unnecessary wear and reduce formation of heavy deposits in pipelines, channels and process tanks. The vortex grit tank uses centrifugal force to separate the grit from the wastewater. Grit is collected in the lower portion of the grit tank and is pumped to a grit classifier for dewatering. The dewatered grit is conveyed to the grit/screenings bin for landfill disposal.

Phosphorus Removal

The phosphorous removal system lowers the total phosphorous level in the final effluent by adding a chemical coagulant (aluminum sulphate) as part of the treatment process. Aluminum sulphate can be added at multiple locations within the plant.

Secondary Treatment

Aeration Tanks: Preliminary effluent flow is directed to two aeration tanks. Surface mechanical aerators mix air into the wastewater to assist bacteria in removing dissolved and suspended organics and nutrients from the wastewater.

Secondary Clarifier: The effluent from the aeration tanks is directed to two secondary clarifiers where solids settle quickly as activated sludge leaving a clear effluent. A portion of the activated sludge collected on the bottom of the clarifier is pumped back to the head of the aeration tanks and the excess activated sludge is wasted to the aerobic digester.

Tertiary Treatment

Tertiary Clarifier: The secondary effluent is directed to the tertiary clarifier. The helical flow pattern in the clarifier separates the solids from the liquid, the effluent flows over to the tertiary sand filter and the thickened sludge is pumped to the aerobic digester.

Tertiary Sand Filter: Effluent flow from the tertiary clarifier flows into an automatic cleaning sand filter. The automatic backwash is initiated by an increase in head pressure or a programmed timer. The backwash water is returned to the beginning of the plant for further treatment.

Disinfection

Ultra Violet (UV) Irradiation: The effluent flow from the sand filter is then directed to the UV channel for disinfection. The flow passes two banks of UV lamps connected in series before being discharged to Lake Simcoe through the 400mm diameter outfall extending 314 metres into Lake Simcoe.

Solids Treatment

Aerobic Digester: Activated sludge from the secondary clarifiers is pumped to an aerobic digester for stabilization. A mechanical mixer and a fixed header diffused aeration system provide oxygen for the



microorganisms. The mixer and diffusers are turned off to allow solids to settle for removal and the supernatant to be decanted and flow by gravity to the raw sewage pumping station.

Sludge Management: Stabilized biosolids from the digester are transported to Duffin Creek WPCP for further treatment and incineration.

Environmental Compliance Approval

Under Condition 9.(5) of ECA # 5292-8CYHTQ the Region must produce an annual performance report that must contain the following information:

a) Summary and interpretation of all monitoring data and a comparison to the effluent limits;

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA. Table 2 summarizes the raw wastewater characteristics during the reporting period.

The Lake Simcoe WPCP effluent was compliant with the approval limits during the reporting period. The plant operated at 40.2% of its rated capacity and received a maximum daily flow of 5,120 m³/d on April 27. Tables 3-5 provide a tabulation of effluent results.

b) Description of any operating problems encountered and corrective actions taken;

One of the two aeration tanks was out of service between January and June 2019. Maintenance work on the draft tube and impeller was postponed until spring as tank was frozen and could not be cleaned out in winter.

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the Works;

Major maintenance items in 2019 included:

- replaced the air handling unit in the secondary building basement, and
- rebuilt the aeration tank draft tube and impeller with a new splash plate.

d) Summary of any effluent quality assurance or control measures undertaken in the reporting period;

- In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. Results were found to be in a comparable range. On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment;

- Calibration of the effluent flow meter occurred on May 29 and October 22.
- Calibration of the in-house laboratory equipment was conducted on August 27.
- Verification of the pH meter is conducted regularly.



Lake Simcoe Water Pollution Control Plant 2019 Annual Performance Report

Final effluent flow between July 30 and 31 was estimated as the flow meter was out of service to replace a circuit board.

f) Description of efforts made and results achieved in meeting the effluent objectives;

The Region strives to achieve the best effluent quality at all times, remaining below the ECA compliance limits.

- The effluent objective for carbonaceous oxygen demand was exceeded in 1 of 53 samples (1.9%)
- The effluent objective for total suspended solids was exceeded in 8 of 309 samples (2.6%)
- The effluent objective for total phosphorus was exceeded in 4 of 308 samples (1.3%)
- Results for total suspended solids and total phosphorus were monitored and adjustments were made to the treatment process.
- Objective exceedances occurred between February and May when the plant had only one aeration tank in service. The second tank was brought back into service in June as repairs could not be performed in the winter season.

Best efforts will continue to be applied to maintain results below objectives.

g) Biosolids Production;

Tabulation of Volume of Sludge Generated:

The volume of sludge removed from Lake Simcoe WPCP in 2019 was 3,168 m³.

Outline of Anticipated Volumes to be Generated in the Next Reporting Period;

There is no increase of sludge volume expected in the next reporting period.

Summary of Locations to Where Sludge was Disposed;

All sludge produced was transported to Duffin Creek WPCP for incineration.

h) Summary of any complaints received during the reporting period and any steps taken to address the complaints;

A summary of complaints received from the public is administered through a central database. No complaints were received in 2019.

i) Summary of all By-pass, Spill or Abnormal Discharge;

No by-passes, spills or abnormal discharges occurred during the reporting period.

j) Status Update of Initial Effluent Characterization;

The initial effluent characterization report was submitted to MECP in 2015.

k) Information required by Ministry of the Environment, Conservation and Parks District Manager;

No additional information was requested.



Ministry of the Environment, Conservation and Parks (MECP) Inspection

This plant was last inspected by the MECP on March 6, 2019. No compliance items were identified in the report. The MECP did however, recommend that the Region continue to use best efforts to ensure the effluent of the WPCP meets the objectives outlined in the ECA.



**Lake Simcoe Water Pollution Control Plant
2019 Annual Performance Report**

Table 1 Effluent Flows

| Month | Total Plant Flow metered at the final effluent in cubic metre (m ³) | Average Day Flow cubic metre per day (m ³ /d) | Maximum Day Flow m ³ /d |
|----------------|---|--|------------------------------------|
| January | 45,104 | 1,455 | 2,700 |
| February | 36,395 | 1,300 | 2,593 |
| March | 56,643 | 1,827 | 3,339 |
| April | 106,890 | 3,563 | 5,120 |
| May | 115,450 | 3,724 | 5,093 |
| June | 67,233 | 2,241 | 3,512 |
| July | 48,763 | 1,573 | 3,561 |
| August | 27,248 | 879 | 1,140 |
| September | 27,790 | 926 | 1,321 |
| October | 34,039 | 1,098 | 2,997 |
| November | 47,497 | 1,583 | 3,089 |
| December | 55,046 | 1,776 | 3,292 |
| Total | 668,100 | | |
| Average | 55,675 | 1,830 | |
| Minimum | 27,248 | | |
| Maximum | 115,450 | | 5,120 |
| ECA Limit | | 4,550* | |
| Met Compliance | | Yes | Yes |

*Annual Average



**Lake Simcoe Water Pollution Control Plant
2019 Annual Performance Report**

Table 2 Raw Influent Analyses

| Month | Biochemical Oxygen Demand (BOD ₅) average (avg.) concentration (conc.) milligram per litre (mg/L) | BOD ₅ loading kilogram per day (kg/d) | Total Suspended Solids (TSS) avg. conc. mg/L | TSS loading (kg/d) | Total Phosphorous (TP) avg. conc. mg/L | TP avg. loading (kg/d) | Alkalinity CaCO ₃ mg/L |
|------------------------------------|---|--|--|--------------------|--|------------------------|-----------------------------------|
| January | 70 | 102 | 67 | 98 | 2.0 | 3 | 280 |
| February | 72 | 94 | 71 | 93 | 2.3 | 3 | 267 |
| March | 62 | 114 | 61 | 112 | 2.0 | 4 | 258 |
| April | 35 | 123 | 54 | 193 | 0.9 | 3 | 261 |
| May | 37 | 138 | 64 | 237 | 1.0 | 4 | 277 |
| June | 41 | 93 | 68 | 152 | 1.3 | 3 | 290 |
| July | 83 | 131 | 124 | 194 | 2.8 | 4 | 251 |
| August | 121 | 106 | 110 | 97 | 3.6 | 3 | 263 |
| September | 171 | 158 | 111 | 103 | 3.6 | 3 | 265 |
| October | 123 | 136 | 96 | 105 | 3.3 | 4 | 283 |
| November | 75 | 119 | 71 | 113 | 2.0 | 3 | 276 |
| December | 60 | 106 | 62 | 111 | 1.7 | 3 | 291 |
| Average | 79 | 145 | 80 | 146 | 2.2 | 4 | 272 |
| Minimum | 35 | 93 | 54 | 93 | 0.9 | 3 | 251 |
| Maximum | 171 | 158 | 124 | 237 | 3.6 | 4 | 291 |
| Sampling Frequency Requirement Met | Yes | | Yes | | Yes | | Yes |



**Lake Simcoe Water Pollution Control Plant
2019 Annual Performance Report**

Table 2 Raw Influent Analyses continued

| Month | Total Kjeldahl Nitrogen average concentration (conc.) milligram per litre (mg/L) | Total Ammonia Nitrogen (TAN) average conc. mg/L | TAN loading kilogram per day | pH minimum | pH maximum | Temperature Degree Celsius avg. |
|---|---|---|------------------------------------|---------------|---------------|---------------------------------------|
| January | 21.60 | 14.6 | 21 | 6.7 | 7.1 | 9.0 |
| February | 22.05 | 16.6 | 22 | 6.6 | 7.0 | 8.4 |
| March | 19.90 | 13.8 | 25 | 6.7 | 7.5 | 8.6 |
| April | 8.49 | 4.8 | 17 | 6.9 | 7.6 | 8.5 |
| May | 11.27 | 7.1 | 26 | 7.0 | 7.4 | 11.3 |
| June | 12.80 | 8.6 | 19 | 7.0 | 7.5 | 14.4 |
| July | 26.10 | 17.1 | 27 | 7.0 | 7.5 | 17.9 |
| August | 34.73 | 24.7 | 22 | 6.9 | 7.2 | 17.9 |
| September | 36.48 | 25.0 | 23 | 6.9 | 7.1 | 17.2 |
| October | 31.32 | 23.3 | 26 | 6.7 | 7.4 | 14.9 |
| November | 23.35 | 15.1 | 24 | 6.9 | 7.6 | 12.2 |
| December | 16.92 | 12.7 | 23 | 7.3 | 7.5 | 10.0 |
| Average | 22.08 | 15.3 | 28 | | | |
| Minimum | 8.49 | 4.8 | 17 | 6.6 | | 8.4 |
| Maximum | 36.48 | 25.0 | 27 | | 7.6 | 17.9 |
| Sampling Frequency Requirement Met | Yes | | | Yes | Yes | |



Table 3 Final Effluent Analyses

| Month | Carbonaceous Biochemical Oxygen Demand (CBOD ₅) average concentration (conc.) milligram per litre (mg/L) | CBOD ₅ loading kilogram per day (kg/d) | Total Suspended Solids (TSS) average conc. mg/L | TSS loading kg/d |
|--|--|---|---|------------------|
| January | 1.0 | 1 | 0.6 | 1 |
| February | 1.0 | 1 | 1.1 | 1 |
| March | 1.0 | 2 | 1.6 | 3 |
| April | 2.5 | 9 | 2.9 | 10 |
| May | 1.0 | 4 | 3.2 | 12 |
| June | 1.0 | 2 | 1.1 | 2 |
| July | 1.0 | 2 | 0.7 | 1 |
| August | 1.0 | 1 | 0.8 | 1 |
| September | 1.0 | 1 | 0.9 | 1 |
| October | 1.0 | 1 | 0.6 | 1 |
| November | 1.0 | 2 | 0.7 | 1 |
| December | 1.0 | 2 | 0.6 | 1 |
| Total | | | | |
| Average | 1.1 | 2 | 1.2 | 2 |
| Minimum | 1.0 | 1 | 0.6 | 1 |
| Maximum | 2.5 | 9 | 3.2 | 12 |
| ECA Limit | 10* | | 10* | |
| ECA Objective | 5 | | 5 | |
| Lake Simcoe Phosphorous Reduction Strategy | | | | |
| Within Compliance | Yes | | Yes | |
| Sampling Frequency Requirement Met | Yes | | Yes | |

*Monthly Average Concentration



Table 3 Final Effluent Analyses continued

| Month | Total Phosphorous (TP) average (avg.) concentration (conc.) milligram per litre (mg/L) | TP avg. loading kilogram per day | TP avg. loading kilogram per month |
|--|--|----------------------------------|------------------------------------|
| January | 0.06 | 0 | 3 |
| February | 0.08 | 0 | 3 |
| March | 0.08 | 0 | 4 |
| April | 0.06 | 0 | 6 |
| May | 0.06 | 0 | 7 |
| June | 0.03 | 0 | 2 |
| July | 0.05 | 0 | 2 |
| August | 0.05 | 0 | 1 |
| September | 0.07 | 0 | 2 |
| October | 0.05 | 0 | 2 |
| November | 0.03 | 0 | 1 |
| December | 0.03 | 0 | 2 |
| Total | | | 36* |
| Average | 0.05 | 0 | 3 |
| Minimum | 0.03 | 0 | 1 |
| Maximum | 0.08 | 0 | 7 |
| ECA Limit | 0.3** | | 190* |
| ECA Objective | 0.12 | | 190 |
| Lake Simcoe Phosphorous Reduction Strategy | 0.15*** | | 190* |
| Within Compliance | Yes | | Yes |
| Sampling Frequency Requirement Met | Yes | | Yes |

*Total Annual Loading, kg/year

**Monthly Average Concentration

***Annual Average Concentration



**Lake Simcoe Water Pollution Control Plant
2019 Annual Performance Report**

Table 3 Final Effluent Analyses continued

| Month | Total Ammonia Nitrogen (TAN) average (avg.) concentration (conc.) milligram per litre (mg/L) summer | TAN avg. conc. mg/L winter | TAN loading kilogram per day | Total Kjeldahl Nitrogen avg. conc. mg/L | Unionized Ammonia Nitrogen avg. conc. mg/L |
|------------------------------------|---|----------------------------|------------------------------|---|--|
| January | | 1.94 | 3 | 2.80 | 0.0 |
| February | | 4.86 | 6 | 5.62 | 0.0 |
| March | | 4.19 | 8 | 5.23 | 0.0 |
| April | | 0.72 | 3 | 1.61 | 0.0 |
| May | | 1.08 | 4 | 1.91 | 0.0 |
| June | 0.08 | | 0 | 0.73 | 0.0 |
| July | 0.03 | | 0 | 0.63 | 0.0 |
| August | 0.04 | | 0 | 0.72 | 0.0 |
| September | | 0.04 | 0 | 0.81 | 0.0 |
| October | | 0.02 | 0 | 0.68 | 0.0 |
| November | | 0.03 | 0 | 0.59 | 0.0 |
| December | | 0.06 | 0 | 0.57 | 0.0 |
| Average | 0.05 | 1.44 | 2 | 1.82 | 0.0 |
| Minimum | 0.03 | 0.02 | 0 | 0.57 | 0.0 |
| Maximum | 0.08 | 4.86 | 8 | 5.62 | 0.0 |
| ECA Limit | 5** | 15** | | | |
| ECA Objective | 3 | 10 | | | |
| Within Compliance | Yes | Yes | | | |
| Sampling Frequency Requirement Met | Yes | Yes | | | |

**Monthly Average Concentration



Table 3 Final Effluent Analyses continued

| Month | pH minimum | pH maximum | Temperature Degree Celsius avg. |
|------------------------------------|------------|------------|---------------------------------|
| January | 6.5 | 6.7 | 8.5 |
| February | 6.5 | 6.7 | 7.8 |
| March | 6.5 | 7.1 | 8.3 |
| April | 6.7 | 7.1 | 8.8 |
| May | 6.7 | 7.1 | 12.2 |
| June | 6.7 | 7.3 | 14.3 |
| July | 6.7 | 7.4 | 20.3 |
| August | 6.6 | 6.9 | 19.9 |
| September | 6.6 | 6.9 | 17.8 |
| October | 6.6 | 7.3 | 14.7 |
| November | 6.8 | 7.4 | 11.8 |
| December | 6.8 | 7.6 | 9.8 |
| Minimum | 6.5 | | 7.8 |
| Maximum | | 7.6 | 20.3 |
| ECA Objective | 6.5 | 9.0 | |
| Sampling Frequency Requirement Met | Yes | Yes | Yes |



Table 4 *Escherichia coli* Sampling

| Month | Number of Samples | Monthly Geometric Mean Density |
|------------------------------------|-------------------|--------------------------------|
| January | 5 | 3 |
| February | 4 | 19 |
| March | 4 | 7 |
| April | 4 | 1 |
| May | 5 | 3 |
| June | 4 | 2 |
| July | 5 | 0 |
| August | 4 | 2 |
| September | 4 | 1 |
| October | 5 | 5 |
| November | 4 | 4 |
| December | 5 | 3 |
| ECA Objective | | 40 organisms/100ml |
| Sampling Frequency Requirement Met | Yes | |



Table 5 Total Coliform Sampling

| Month | Number of Samples | Monthly Geometric Mean Density |
|------------------------------------|-------------------|--------------------------------|
| January | 5 | 35 |
| February | 4 | 114 |
| March | 4 | 82 |
| April | 4 | 6 |
| May | 5 | 43 |
| June | 4 | 9 |
| July | 5 | 1 |
| August | 4 | 16 |
| September | 4 | 3 |
| October | 5 | 17 |
| November | 4 | 29 |
| December | 5 | 15 |
| Sampling Frequency Requirement Met | Yes | |



Table 6 Energy and Chemical Usage

| Month | Aluminum Sulphate litre | Hydro kilowatt hour | Natural Gas cubic metre |
|-----------|-------------------------|---------------------|-------------------------|
| January | 3,259 | 66,600 | 16,484 |
| February | 2,691 | 61,560 | 22,889 |
| March | 5,113 | 68,040 | 10,894 |
| April | 9,931 | 61,200 | 15,832 |
| May | 8,664 | 72,720 | 3,356 |
| June | 7,642 | 42,840 | 1,141 |
| July | 4,781 | 69,480 | 8,988 |
| August | 3,015 | 54,000 | 372 |
| September | 3,217 | 63,720 | 854 |
| October | 4,401 | 56,520 | 1,105 |
| November | 5,201 | 58,680 | 11,894 |
| December | 6,236 | 80,280 | 17,313 |
| Total | 64,149 | 755,639 | 111,122 |