



Nonquon Water Pollution Control Plant 2025 Annual Performance Report





The Regional Municipality of Durham

Nonquon Water Pollution Control Plant 2025 Annual Performance Report

Environmental Compliance Approval (ECA): 2207-9LKHLM

Dated July 17, 2014

The Nonquon Water Pollution Control Plant (WPCP) 2025 Annual Performance Report provides staff, stakeholders and customers an overview of the performance of the Nonquon WPCP in 2025. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of Environment, Conservation and Parks (MECP). This report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

Water Pollution Control Plant Process Description

General

The Nonquon WPCP located in the Community of Port Perry in the Township of Scugog is owned and operated by the Regional Municipality of Durham (Region). The plant is operated according to the terms and conditions of the ECA. This MECP Class 3 wastewater treatment plant utilizes an extended aeration process with tertiary treatment and is designed to treat wastewater at a rated capacity of 5,900 cubic metres per day (m³/d). The Nonquon WPCP has a service population of 9,875 residents.

Nonquon WPCP treats wastewater from the Port Perry service area utilizing the following processes:

- Raw influent pumping
- Preliminary treatment
- Phosphorus removal
- Secondary treatment
- Tertiary treatment
- Disinfection
- Solids management

Raw Influent Pumping

Wastewater is collected through approximately 53.4 kilometres of sanitary sewers in the Port Perry service area and is conveyed to the Nonquon WPCP by three sanitary sewage pumping stations (SSPS): Water Street, Reach Street and Canterbury Common SSPS.

The influent pumping station at the Nonquon WPCP allows raw wastewater flow more than the design flow of 5,900 m³/d to passively overflow to the inlet chamber and be directed to one of the five equalization lagoons for storage. A gravity sanitary sewer pipe allows for lagoon effluent to be returned to the influent pumping station during periods of low flows, for full treatment.



Preliminary Treatment

Screening: There are two bar screens in the screening room for the removal of paper products and large material that could harm pumps and process equipment. One channel contains an automatic, mechanically cleaned bar screen and the other is equipped with a manually raked bar screen to provide screening on an emergency basis. A screenings washer/compacter utilizes plant effluent water to wash and compact the screenings. Screenings are removed in this process and transported to landfill for disposal.

Grit Removal: The vortex grit removal removes sand and small stones (grit) for the protection of mechanical equipment from unnecessary wear and reduce formation of heavy deposits in pipelines, channels and process tanks. The vortex grit removal chamber uses centrifugal force to separate the grit from the wastewater. Grit is collected in the lower portion of the grit tank and is pumped to a grit classifier for dewatering. The dewatered grit is conveyed to the grit/screenings bin for landfill disposal.

Phosphorus Removal

The phosphorus removal system lowers the total phosphorus level in the final effluent by adding a chemical coagulant, aluminum sulphate, as part of the treatment process. Aluminum sulphate can be added at multiple locations throughout the plant.

Secondary Treatment

Aeration Tanks: Preliminary effluent flow is directed to two aeration tanks comprised of two distinct zones. The first is a swing zone equipped with fine bubble diffusers. This zone is capable of being operated as an anoxic zone where no oxygen is introduced and allows for potential denitrification or an aerated zone where fine bubbled air is diffused into the wastewater. It is typically operated as an anoxic zone. The flow leaves the swing zone and enters the aerated zone where fine bubbled air is diffused into the wastewater to assist bacteria in removing dissolved and suspended organics and nutrients. Prior to entering the secondary clarifiers, the two aeration tanks are equipped with a rotating slotted pipe for removal of any excess activated sludge, the waste activated sludge (WAS) is decanted manually to the WAS chamber and pumped to a storage lagoon.

Secondary Clarifiers: The effluent from the aeration tank is directed to the two secondary clarifiers where solids settle quickly as activated sludge leaving a clear effluent. The activated sludge collected on the bottom of the clarifiers is pumped back to the front of the aeration tanks. The clear effluent continues to tertiary treatment.

Tertiary Treatment

Tertiary Sand Filter: Effluent from the secondary clarifiers is filtered through four upflow filter cells operated in parallel. The tertiary influent flow is directed to the bottom of the cells and upward through the sand media. The automatic backwash is initiated by an increase in head pressure or on a



programmed timer. The backwash water is returned to the influent pumping station for further treatment.

Disinfection

Ultra Violet (UV) Irradiation: The effluent flow from the sand filter is then directed to the UV channel for disinfection. The effluent passes through two banks of UV lamps connected in series. The treated final effluent is discharged to the Nonquon River.

Solids Management

Equalization Storage Lagoons: During high flow conditions excess flow from the influent pumping station is diverted to the aerated cell inlet chamber, from here it is directed to one of the five storage lagoons. During low flow conditions the lagoon effluent can be returned to the influent pumping station for treatment.

Solids Treatment: Waste activated sludge (WAS) is pumped from the WAS chamber to lagoon number six for storage and settling, the solid levels are monitored and removed for disposal as needed.

Environmental Compliance Approval (ECA)

Under Condition 10(6) of ECA #2207-9LKHLM the Region must produce an annual performance report that must contain the following information:

a) Summary and interpretation of all monitoring data and a comparison to the effluent limits

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the plant's ECA. Table 2 Raw Influent Analyses summarizes the raw wastewater characteristics during the reporting period.

The plant operated at 48.3% of its rated capacity and received a maximum daily flow of 6,475 cubic metres per day (m³/d) on March 31, 2025.

- The E.coli monthly geometric mean density limit of 200 cfu/100mL was exceeded in 1 of 12 months (8.3%)

b) Description of any operating problems encountered and corrective actions taken

Higher than normal total phosphorous and total suspended solids were observed in 2025. These results are due to the tertiary filters plugging frequently with algae, grease, and solids. All four filters were rotated out for service for cleaning and topping up the sand. Routine maintenance of the filters is conducted to ensure filters remain operational. A pilot project using a cloth disc system was conducted and was proven to perform well and will replace the existing sand filters.



Nonquon Water Pollution Control Plant 2025 Annual Performance Report

Higher final effluent total phosphorus and total suspended solids results were observed due to the final effluent weighted weir breaking. Solids were trapped causing turbidity in the UV channel resulting in lower UV intensity. A repair is planned in early 2026.

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the Works

Major maintenance items in 2025 included:

- Replaced water solenoid valve on rag compactor screw conveyor
- Replaced six flights in secondary Number (No.) 1
- Installed four flush valves in secondary No. 1 and No. 2
- Replaced two knife gate valves in aeration No. 1
- Replaced dissolved oxygen probe in aeration No. 1
- Cleaned and topped up sand in all tertiary filters

d) Summary of any effluent quality assurance or control measures undertaken in the reporting period

In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment

Calibration of the flow meter was conducted on November 24, 2025.

Calibration of the Hach equipment was conducted on November 26, 2025.

Calibration of the pH meter is conducted regularly.

f) Description of efforts made and results achieved in meeting the effluent objectives

The Region continually strives to achieve the best effluent quality at all times and remain below the objectives specified in the ECA.

The Nonquon WPCP effluent objectives were met in 2025 except for:

- The total phosphorus objective of 0.08 milligrams per litre (mg/L) was exceeded in 147 of 362 samples (40.6%)
- The total suspended solids objective of 8.0 milligrams per litre (mg/L) was exceeded in 73 of 362 samples (20.2%)
- The E.coli monthly geometric mean density objective of 100 cfu/100mL was exceeded in 3 of 12 months (25%)

Filter maintenance was conducted frequently to reduce total suspended solids and total phosphorous values to maintain results below objectives.



Nonquon Water Pollution Control Plant 2025 Annual Performance Report

g) A tabulation of the volume of sludge generated in the reporting period, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed

Waste Activated Sludge is discharged into the lagoons on-site. No sludge was removed during the reported period. The volume of biosolids will be calculated and reported in the year when sludge is removed from the site for final treatment or disposal.

Even with the increase in population on a year-to-year basis, no significant changes to flows or processing are anticipated. Therefore, no significant changes in sludge generation are expected for the next year.

h) Summary of any complaints received during the reporting period and any steps taken to address the complaints

All complaints received from the public are administered and tracked through a central database. No complaints were received in 2025.

i) Summary of all By-pass, spill or abnormal discharge

No by-passes or spills occurred during the reporting period.

j) Copy of all Notice of Modifications and any implementation of Limited Operational Flexibility (Schedule B)

No notices of modifications were submitted in 2025.

k) Report summarizing modifications (Schedule B, Section 3)

There were no modifications in 2025.

l) Information required by Ministry of the Environment, Conservation and Parks Water Supervisor

No additional information was requested.

Ministry of the Environment, Conservation and Parks (MECP) Inspection

The plant was inspected by the MECP on March 5, 2019.



**Nonquon Water Pollution Control Plant
2025 Annual Performance Report**

Table 1 Final Effluent Flows

| Month | Total Plant Flow* cubic metre (m ³) | Average Daily Flow cubic metre per day (m ³ /d) | Maximum Daily Flow m ³ /d |
|----------------|---|--|--------------------------------------|
| January | 91,902 | 2,965 | 4,110 |
| February | 66,923 | 2,390 | 2,594 |
| March | 126,605 | 4,084 | 6,475 |
| April | 121,050 | 4,035 | 5,891 |
| May | 113,573 | 3,664 | 4,965 |
| June | 87,856 | 2,929 | 3,769 |
| July | 68,115 | 2,197 | 2,408 |
| August | 69,589 | 2,245 | 3,000 |
| September | 65,534 | 2,184 | 2,607 |
| October | 66,391 | 2,142 | 2,538 |
| November | 72,759 | 2,425 | 2,786 |
| December | 89,110 | 2,875 | 5,251 |
| Total | 1,039,407 | | |
| Annual Average | 86,617 | 2,848** | |
| Minimum | 65,534 | | |
| Maximum | 126,605 | | 6,475 |
| ECA Limit | | 5,900** | |
| Met Compliance | | Yes | |

*Metered at the Final Effluent

**Annual Average Daily Flow



**Nonquon Water Pollution Control Plant
2025 Annual Performance Report**

Table 2 Raw Influent Analyses

| Month | Biochemical Oxygen Demand (BOD ₅) average (avg.) concentration (conc.) milligrams per litre (mg/L) | Total Suspended Solids (TSS) avg conc. mg/L | Total Phosphorus (TP) avg conc. mg/L | Total Kjeldahl Nitrogen avg. conc. mg/L |
|------------------------------------|--|---|--------------------------------------|---|
| January | 195 | 246 | 4.5 | 30.62 |
| February | 265 | 346 | 5.7 | 47.35 |
| March | 143 | 219 | 3.1 | 21.88 |
| April | 117 | 178 | 3.2 | 25.50 |
| May | 143 | 195 | 3.6 | 27.18 |
| June | 169 | 228 | 4.0 | 30.63 |
| July | 176 | 251 | 4.8 | 36.58 |
| August | 156 | 255 | 4.9 | 38.40 |
| September | 202 | 389 | 6.2 | 46.00 |
| October | 169 | 315 | 5.2 | 40.14 |
| November | 151 | 226 | 4.9 | 34.93 |
| December | 196 | 274 | 4.6 | 37.57 |
| Average | 174 | 260 | 4.5 | 34.73 |
| Minimum | 117 | 178 | 3.1 | 21.88 |
| Maximum | 265 | 389 | 6.2 | 47.35 |
| Sampling Frequency Requirement Met | Yes | Yes | Yes | Yes |



**Nonquon Water Pollution Control Plant
2025 Annual Performance Report**

Table 3 Final Effluent Analyses

| Month | Carbonaceous Biochemical Oxygen Demand (CBOD ₅) average (avg.) concentration (conc.) milligrams per litre (mg/L) | CBOD ₅ loading kilograms per day (kg/d) year to date avg. | Total Suspended Solids (TSS) avg. conc. mg/L | TSS kg/d year to date avg. |
|------------------------------------|--|--|--|----------------------------|
| January | 1.3 | 3.8 | 8.4 | 24.9 |
| February | 1.0 | 3.1 | 8.2 | 22.3 |
| March | 1.2 | 3.7 | 7.3 | 25.2 |
| April | 1.2 | 4.0 | 6.4 | 25.6 |
| May | 1.3 | 4.1 | 4.7 | 24.1 |
| June | 1.7 | 4.3 | 7.5 | 23.8 |
| July | 1.7 | 4.2 | 6.7 | 22.4 |
| August | 1.0 | 4.0 | 2.7 | 19.9 |
| September | 1.0 | 3.7 | 4.4 | 18.6 |
| October | 1.0 | 3.6 | 2.9 | 17.0 |
| November | 1.0 | 3.4 | 3.0 | 16.0 |
| December | 1.3 | 3.5 | 5.2 | 16.0 |
| Annual Loading | | 3.4** | | 15.9** |
| Average | 1.2* | | 5.6* | |
| Minimum | 1.0 | 3.1 | 2.7 | 16.0 |
| Maximum | 1.7 | 4.3 | 8.4 | 25.6 |
| ECA Limit | 5.0* | 29.5** | 10.0* | 59.0** |
| ECA Objective | 4.0 | | 8.0 | |
| Within Compliance | Yes | Yes | Yes | Yes |
| Sampling Frequency Requirement Met | Yes | | Yes | |

*Annual Average Concentration

**Annual Average Loading



**Nonquon Water Pollution Control Plant
2025 Annual Performance Report**

Table 3 Final Effluent Analyses continued

| Month | Total Phosphorus (TP) average (avg.) concentration (conc.) milligrams per litre (mg/L) | TP kilograms per month (kg/m) monthly avg. | TP kilograms per year (kg/year) to date avg. |
|------------------------------------|--|--|--|
| January | 0.11 | | 10 |
| February | 0.11 | | 17 |
| March | 0.08 | | 29 |
| April | 0.08 | | 39 |
| May | 0.07 | 8.0 | 47 |
| June | 0.12 | 10.5 | 58 |
| July | 0.08 | 5.4 | 63 |
| August | 0.03 | 2.1 | 63 |
| September | 0.05 | 3.3 | 66 |
| October | 0.03 | 2.0 | 67 |
| November | 0.07 | | 72 |
| December | 0.10 | | 83 |
| Annual Loading | | | 83** |
| Average | 0.08 | 6.7 | |
| Minimum | 0.03 | 2.0 | |
| Maximum | 0.12 | 10.5 | |
| ECA Limit | | 14.2* May to October | 170** |
| ECA Objective | 0.08 | | |
| Within Compliance | | Yes | Yes |
| Sampling Frequency Requirement Met | Yes | Yes | Yes |

*Monthly Average Loading

**Annual Average Loading



**Nonquon Water Pollution Control Plant
2025 Annual Performance Report**

Table 3 Final Effluent Analyses continued

| Month | pH minimum | pH maximum | Temperature Degree Celsius average (avg.) |
|------------------------------------|------------|------------|---|
| January | 6.8 | 7.3 | 12.5 |
| February | 6.9 | 7.3 | 12.2 |
| March | 6.9 | 7.4 | 13.4 |
| April | 6.8 | 7.9 | 13.2 |
| May | 7.0 | 7.2 | 15.4 |
| June | 6.9 | 7.1 | 18.2 |
| July | 6.9 | 7.1 | 20.5 |
| August | 7.0 | 7.2 | 21.2 |
| September | 7.0 | 7.3 | 20.2 |
| October | 6.8 | 7.3 | 18.9 |
| November | 7.0 | 7.3 | 16.4 |
| December | 7.1 | 7.4 | 14.1 |
| Average | | | 16.4 |
| Minimum | 6.8 | | 12.2 |
| Maximum | | 7.9 | 21.2 |
| ECA Limit | 6.0 | 9.5 | |
| Within Compliance | Yes | Yes | |
| Sampling Frequency Requirement Met | Yes | Yes | Yes |



**Nonquon Water Pollution Control Plant
2025 Annual Performance Report**

Table 3 Final Effluent Analyses continued

| Month | Total Ammonia Nitrogen (TAN) average (avg.) concentration (conc.) milligrams per litre (mg/L) | TAN Effluent Objective conc. mg/L | TAN Effluent Limit Monthly avg. conc. mg/L |
|-------------------|---|-----------------------------------|--|
| January | 0.1 | 4.0 | 5.0 |
| February | 0.3 | 4.0 | 5.0 |
| March | 0.4 | 4.0 | 5.0 |
| April | 0.4 | 4.0 | 5.0 |
| May | 0.1 | 2.4 | 3.0 |
| June | 0.1 | 1.2 | 1.5 |
| July | 0.0 | 1.2 | 1.5 |
| August | 0.0 | 1.2 | 1.5 |
| September | 0.0 | 1.2 | 1.5 |
| October | 0.0 | 2.4 | 3.0 |
| November | 0.0 | 4.0 | 5.0 |
| December | 0.0 | 4.0 | 5.0 |
| Average | 0.1 | | |
| Minimum | 0.0 | | |
| Maximum | 0.4 | | |
| Within Compliance | Yes | | |



Table 5 *Escherichia coli* Sampling

| Month | Number of Samples | Monthly Geometric Mean Density |
|------------------------------------|--------------------------|---------------------------------------|
| January | 9 | 3 |
| February | 8 | 2 |
| March | 8 | 26 |
| April | 9 | 313 |
| May | 9 | 112 |
| June | 8 | 193 |
| July | 10 | 8 |
| August | 8 | 24 |
| September | 8 | 5 |
| October | 10 | 18 |
| November | 8 | 37 |
| December | 8 | 46 |
| ECA Objective | | 100 organisms/100mL |
| ECA Limit | | 200 organisms/100mL |
| Within Compliance | | No |
| Sampling Frequency Requirement Met | Yes | |



**Nonquon Water Pollution Control Plant
2025 Annual Performance Report**

Table 6 Energy and Chemical Usage

| Month | Aluminum Sulphate litres | Hydro kilowatt hours |
|--------------|-------------------------------------|---------------------------------|
| January | 18,239 | 108,116 |
| February | 16,748 | 115,726 |
| March | 18,586 | 92,294 |
| April | 17,749 | 85,070 |
| May | 17,076 | 75,035 |
| June | 18,369 | 82,419 |
| July | 20,894 | 65,175 |
| August | 16,611 | 66,419 |
| September | 15,417 | 55,302 |
| October | 14,616 | 67,324 |
| November | 14,606 | 88,046 |
| December | 19,327 | 124,762 |
| Total | 208,238 | 1,025,688 |