

# Sunderland Water Pollution Control Plant 2025 Annual Performance Report

I can help water by not littering in lakes, oceans, and rivers, and picking up litter from other people.

clear from me →



me ↓ trash  
body

stream





## **The Regional Municipality of Durham**

### **Sunderland Water Pollution Control Plant 2025 Annual Performance Report**

**Environmental Compliance Approval (ECA): 9252-8CUNBZ**

Dated June 28, 2012

**Amendment to ECA: 9252-8CUNBZ**

Dated June 28, 2017

The Sunderland Water Pollution Control Plant (WPCP) 2025 Annual Performance Report provides staff, stakeholders and customers an overview of the performance of the Sunderland WPCP. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment, Conservation and Parks (MECP). This report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

#### **Water Pollution Control Plant Process Description**

##### **General**

The Sunderland WPCP located in the Community of Sunderland in the Township of Brock is owned and operated by the Regional Municipality of Durham (Region). The plant is operated according to the terms and conditions of the ECA and its amendment. This MECP Class 1 wastewater treatment plant is designed to treat wastewater at a rated capacity of 632 cubic metres per day (m<sup>3</sup>/d) and utilizes a seasonal retention wastewater stabilization lagoon system. The Sunderland WPCP has a service population of approximately 1,575 residents.

##### **Raw Influent**

Wastewater is collected through 9.5 kilometres of sanitary sewers in the Sunderland service area and is conveyed to the treatment facility by a sanitary sewage pumping station (SSPS) located on River Street.

##### **Lagoon Treatment**

The Sunderland WPCP is a two-cell lagoon system where the wastewater enters a retention stabilization lagoon and overflows into an exfiltration cell giving a combined retention time of approximately 182.5 days. The ECA permits two seasonal discharges per year. Spring discharge is for 20 days in May and fall discharge is for 20 days in November. Additional discharges may be granted by the MECP. Prior to and during discharge to the Beaver River, samples are collected to verify the effluent meets the limits established in the ECA.

##### **Environmental Compliance Approval**

Under Condition 9(4) of ECA #9252-8CUNBZ the Region must produce an annual performance report that contains the following information:



**a) Summary and interpretation of all monitoring data and a comparison to the effluent limits**

The raw wastewater flowing into the lagoons is sampled and analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA. Table 2 Raw Influent Analyses summarizes the raw wastewater characteristics during the reporting period.

The Sunderland WPCP effluent was determined to be compliant with the approval limits during the reporting period. The plant operated at 47.8% of its rated capacity and received a maximum daily flow of 980 cubic metres per day (m<sup>3</sup>/d) on April 3, 2025. The total treated effluent discharged to the Beaver River in 2025 was calculated to be 81,317 cubic metres (m<sup>3</sup>).

**b) Description of any operating problems encountered and corrective actions taken**

In 2019, the Region contacted the MECP after two of the five newly installed groundwater monitoring wells showed elevated ammonia and total kjeldahl nitrogen (TKN) values when compared to historical results from decommissioned wells. The wells are used for the monitoring of groundwater levels and water quality around the lagoons. In 2020, ground penetrating radar technology was used to map water movement between the lagoon and groundwater to detect if the lagoon infrastructure was possibly breached or if the elevated results are due to a historical release that was not identified until the new wells were installed. In 2022, a third-party consultant was provided with all data collected to date to propose next steps. They proposed further studies to determine if the eastern containment structures of the lagoons could be contributing to the elevated ammonia and TKN results. The Region examined its operations at its other existing lagoons in Cannington. In the case of Cannington, a partial clean out of the lagoon around the influent inlet pipe was conducted. Sampling of the monitoring wells around the lagoon revealed that levels of ammonia and TKN decreased after the partial clean out. Based on the success in Cannington, a partial clean out of the inlet area of the Sunderland facultative lagoon was carried out in October 2022. Monthly sampling of the monitoring wells has been conducted and no visible trends have been observed in the upgradient wells since the clean out in 2022. Lagoon well 3 is located downgradient from the facultative lagoon and has shown increasing total ammonia, TKN, and BOD. Lagoon well 2 is located downgradient from the exfiltration lagoon and has shown a downward trend in total ammonia and TKN and an upward trend for total phosphorous. Further investigation will continue and include dye testing the sewer from the sanitary sewer pumping station to the lagoon.

**c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the Works**

The major maintenance item in 2025 included:

- Repaired pump number 1 at River Street sanitary sewage pumping station



**d) Summary of any effluent quality assurance or control measures undertaken in the reporting period**

In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. Temperature and pH are monitored in the field, all other routine process control tests are performed at the Lake Simcoe WPCP laboratory in Beaverton.

**e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment**

Calibration of the influent flow meter located at River Street Sanitary Sewage Pumping Station was conducted on November 25, 2025.

All monitoring and laboratory equipment is calibrated and maintained according to manufacturer's specifications at Lake Simcoe WPCP.

**f) Estimate of sludge settling capacity of the lagoons and its annual depletion**

The annual depletion of the sludge settling capacity is negligible. There was no removal of sludge during the reporting period.

**g) Efforts made and results achieved in meeting the effluent objectives**

The Region strives to achieve the best effluent quality at all times consistently remaining well below ECA limits:

- The maximum pH objective of 8.0 was exceeded in 5 of 9 samples (55.6%). pH is monitored three times per week to ensure values are within compliance.
- The maximum total suspended solids (TSS) objective of 15.0 mg/L was exceeded in 1 of 14 samples (7.1%).

Best efforts will continue to be applied to maintain results below objectives.

**h) Summary of any complaints received during the reporting period and any steps taken to address the complaints**

All complaints received from the public are administered and tracked through a central database. No complaints were received in 2025.

**i) Summary of all By-pass, spill or abnormal discharge**

No by-passes, spills or abnormal discharges occurred during the reporting period.

**j) Status update of the initial effluent characterization**

The initial effluent characterization report was submitted to Ministry of the Environment, Conservation and Parks (MECP) in April 2016.

**k) Information required by MECP District Manager**

No additional information was requested.

**MECP Inspection**

---



**Sunderland Water Pollution Control Plant  
2025 Annual Performance Report**

---

The plant was inspected by the MECP on September 21, 2023.



**Sunderland Water Pollution Control Plant  
2025 Annual Performance Report**

**Table 1 Raw Influent Flows**

Month	Total Flow to Plant* cubic metre (m <sup>3</sup> )	Average Daily Flow cubic metre per day (m <sup>3</sup> /d)	Maximum Daily Flow m <sup>3</sup> /d
January	9,324	301	334
February	7,868	281	324
March	14,078	454	667
April	14,097	470	980
May	10,246	331	362
June	8,465	282	329
July	7,479	241	258
August	7,218	233	273
September	7,203	240	268
October	7,270	235	262
November	8,125	271	301
December	9,180	296	360
Total	110,553		
Annual Average	9,213	302**	
Minimum	7,203		
Maximum	14,097		980
ECA Limit		632**	
Met Compliance		Yes	

\*Metered at River Street Pumping Station

\*\*Annual average daily flow



**Sunderland Water Pollution Control Plant  
2025 Annual Performance Report**

**Table 2 Raw Influent Analyses**

Month	Carbonaceous Biochemical Oxygen Demand average (avg.) concentration (conc.) milligrams per litre (mg/L)	Biochemical Oxygen Demand avg. conc. mg/L	Total Suspended Solids avg. conc. mg/L	Total Phosphorous avg. conc. mg/L
January	186	319	486	6.9
February	207	301	647	6.8
March	174	276	542	6.1
April	112	158	331	4.8
May	170	245	250	7.7
June	164	272	268	6.4
July	153	264	288	8.6
August	172	268	355	8.6
September	159	207	233	8.1
October	174	175	277	8.8
November	146	180	165	6.9
December	132	186	260	7.5
Average	162	237	342	7.3
Minimum	112	158	165	4.8
Maximum	207	319	647	8.8
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes



Table 2 Raw Influent Analyses continued

Month	Total Ammonia Nitrogen average (avg.) concentration milligrams per litre	pH minimum	pH maximum	Temperature Degree Celsius avg.
January	39.3	8.1	8.4	10.8
February	42.7	8.4	8.4	10.8
March	35.1	8.1	8.5	10.0
April	28.3	7.5	8.2	9.9
May	39.6	7.3	8.5	14.0
June	46.6	7.2	8.2	14.5
July	53.2	7.5	8.6	16.6
August	53.4	7.5	8.5	17.8
September	53.8	6.2	8.2	17.7
October	51.5	7.5	8.2	Not Applicable
November	42.6	7.2	8.1	14.7
December	45.2	6.8	8.1	11.1
Average	44.3			13.4
Minimum	28.3	6.2		9.9
Maximum	53.8		8.6	17.8
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes



**Sunderland Water Pollution Control Plant  
2025 Annual Performance Report**

**Table 3 Calculated Effluent Flows**

Month	Effluent Flow cubic metres
January	
February	
March	
April	
May	55,281
June	
July	
August	
September	
October	
November	26,036
December	
Total	81,317
Annual Average	40,659
Minimum	26,036
Maximum	55,281



**Sunderland Water Pollution Control Plant  
2025 Annual Performance Report**

**Table 4 Final Effluent Analyses**

Month	Carbonaceous Biochemical Oxygen Demand average (avg.) concentration (conc.) milligrams per litre (mg/L)	Biochemical Oxygen Demand avg. conc. mg/L	Total Suspended Solids avg. conc. mg/L	Total Phosphorous (TP) avg. conc. mg/L	TP loading kilogram per month
January					
February					
March					
April					
May	4.6	5.6	12.5	0.12	7
June					
July					
August					
September					
October					
November	3.1	3.6	4.8	0.07	2
December					
Annual Loading					8**
Average	3.8	4.6	8.6	0.10*	
Minimum	3.1	3.6	4.8	0.07	
Maximum	4.6	5.6	12.5	0.12	
ECA Limit	10*		15*	0.3*	69**
ECA Objective	10		15	0.5	
Lake Simcoe Phosphorus Reduction Strategy				0.25*	58**
Within Compliance	Yes		Yes	Yes	Yes
Sampling Frequency Requirement Met	Yes		Yes	Yes	

\*Annual Average Concentration

\*\*Total Annual Loading, kilogram per year (kg/year)



**Sunderland Water Pollution Control Plant  
2025 Annual Performance Report**

**Table 4 Final Effluent Analyses continued**

Month	Total Ammonia Nitrogen average (avg.) concentration (conc.) milligrams per litre (mg/L)	pH minimum	pH maximum	Temperature Degree Celsius avg.
January				
February				
March				
April				
May	11.60	7.6	8.3	16.7
June				
July				
August				
September				
October				
November	0.76	7.4	8.5	14.7
December				
Average	6.18			15.7
Minimum	0.76	7.4		14.7
Maximum	11.60		8.5	16.7
ECA Limit		6.0	9.5	
ECA Objective		6.5	8.0	
Within Compliance		Yes	Yes	
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes