



Uxbridge Water Pollution Control Plant 2025 Annual Performance Report





The Regional Municipality of Durham

Uxbridge Brook Water Pollution Control Plant 2025 Annual Performance Report

Environmental Compliance Approval (ECA): 8357-8CTQ5V

Dated June 28, 2012

Environmental Compliance Approval (Air): 6581-67GRPR

Dated December 10, 2004

The Uxbridge Brook Water Pollution Control Plant (WPCP) 2025 Annual Performance Report provides staff, stakeholders and customers with an overview of the performance of the Uxbridge Brook WPCP in 2025. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of Environment, Conservation and Parks (MECP). This report demonstrates the commitment to ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

Water Pollution Control Plant Process Description

General

The Uxbridge Brook WPCP located in the Community of Uxbridge in the Township of Uxbridge is owned and operated by the Regional Municipality of Durham (Region). The plant is operated according to the terms and conditions of the ECA. This MECP Class 3 wastewater treatment plant utilizes an extended aeration process with tertiary treatment and is designed to treat wastewater at a rated capacity of 5,221 cubic metres per day (m³/d). The Uxbridge Brook WPCP has a service population of 12,247 residents.

Uxbridge Brook WPCP treats wastewater from the Uxbridge service area utilizing the following processes:

- Raw influent pumping
- Preliminary treatment
- Phosphorus removal
- Secondary treatment
- Tertiary filtration
- Disinfection
- Solids management

Raw Influent Pumping

Wastewater is collected through approximately 51.2 kilometres of sanitary sewers in Uxbridge and is conveyed to the WPCP by gravity and the Sandy Hook sanitary sewage pumping station (SSPS).

Preliminary Treatment

Screening: There are two bar screens in the screening room for the removal of paper products and large material that could harm pumps and process equipment. One channel contains an automatic, mechanically raked bar screen and the other is equipped with a manually raked bar screen to provide



screening on an emergency basis. Screenings are removed in this process and transported to landfill for disposal.

Grit Removal: The vortex grit removal chamber removes sand and small stones (grit) for the protection of mechanical equipment from unnecessary wear and to reduce formation of heavy deposits in pipelines, channels and process tanks. The vortex grit removal chamber uses centrifugal force to separate the grit from the wastewater. Grit is collected in the lower portion of the grit tank and is pumped to a grit classifier for dewatering. The dewatered grit is conveyed to the grit/screenings bin for landfill disposal.

Phosphorus Removal

The phosphorous removal system lowers the total phosphorous level in the final effluent by adding a chemical coagulant, aluminum sulphate, as part of the treatment process. Aluminum sulphate can be added at multiple locations throughout the plant.

Secondary Treatment

Aeration Tanks: Preliminary effluent flow is directed to two aeration tanks. Fine bubbled air is diffused into the wastewater to assist bacteria in removing dissolved and suspended organics and nutrients.

Secondary Clarifiers: The effluent from the aeration tanks is directed to three secondary clarifiers where solids settle quickly as activated sludge leaving a clear effluent. A portion of the activated sludge collected on the bottom of the clarifiers is pumped back to the front of the aeration tanks and any excess activated sludge is sent to the aerobic digester.

Tertiary Filtration

Tertiary Sand Filter: Effluent from the secondary clarifiers is filtered through two automatic self-cleaning sand filters. The automatic backwash is initiated by an increase in head pressure or on a programmed timer. The backwash water is returned to the front of the plant for further treatment.

Disinfection

Ultraviolet (UV) Irradiation: The effluent flow from the sand filter is then directed to the UV channel for disinfection. The effluent passes two banks of UV lamps connected in series. The treated final effluent is discharged to the Uxbridge Brook.

Solids Management

Aerobic Digester: Waste activated sludge from the secondary clarifiers is pumped to a two-stage aerobic digester for stabilization. A coarse bubble diffuser provides oxygen for the microorganisms. The diffusers are turned off to allow solids to settle for removal and the supernatant is returned to the front of the plant for further treatment.



Uxbridge Brook Water Pollution Control Plant 2025 Annual Performance Report

Sludge Management: Stabilized biosolids from the digester are transported to Duffin Creek WPCP for further treatment and incineration.

Environmental Compliance Approval (ECA)

Under Condition 9(5) of ECA #8357-8CTQ5V the Region must produce an annual performance report that must contain the following information:

a) Summary and interpretation of all monitoring data and a comparison to the effluent limits

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA. Table 2 Raw Influent Analyses summarizes the raw wastewater characteristics during the reporting period.

The Uxbridge Brook WPCP effluent was compliant with the approval limits during the reporting period. The plant operated at 69% of its rated capacity and received a maximum daily flow of 8,342 cubic metres per day (m³/d) on April 3, 2025.

b) Description of any operating problems encountered and corrective actions taken

No operating problems were encountered in 2025.

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the Works

Major maintenance items in 2025 included:

- Replaced electrical cord and seals on Raw Lift Pump Number (No.) 2
- Replaced impeller on Waste Activated Sludge pump No. 1
- Replaced miltronics unit for tertiary filter No. 2

d) Summary of any effluent quality assurance or control measures

In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment

Calibration of the final effluent flow meter was conducted on November 24, 2025.

Calibration of the Hach equipment was conducted on November 24, 2025.

Calibration and verification of the pH meter is conducted regularly.

f) Description of efforts made and results achieved in meeting the effluent objectives

The Region continually strives to achieve the best effluent quality at all times and remain below the objectives specified in the ECA:



Uxbridge Brook Water Pollution Control Plant 2025 Annual Performance Report

- The total suspended solids objective of 5.0 milligrams per litre (mg/L) was exceeded in 46 of 353 samples (13.0%). Total suspended solids results are monitored daily, and adjustments are made to the process as required.
- The total phosphorus objective of 0.1 mg/L was exceeded in 29 of 358 samples (8.1%). Total phosphorus results are monitored daily, and adjustments are made to the process as required.
- The total ammonia nitrogen objective of 2 mg/L (summer season) was exceeded in 1 of 357 samples (0.3%). Total ammonia results are monitored daily, and adjustments are made to the process as required.
- The minimum effluent pH objective of 6.5 was exceeded in 1 of 256 samples (0.4%). Alkalinity is monitored twice per week to ensure there is enough buffering capacity to maintain pH within compliance.

g) A tabulation of the volume of sludge generated in the reporting period, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed

The volume of sludge removed from Uxbridge Brook WPCP in 2025 was 15,636 cubic metres (m³). The sludge produced was transported to Duffin Creek WPCP for further treatment and incineration. Even with the increase in population on a year-to-year basis, no significant changes to flows or processing are anticipated. Therefore, no significant changes in sludge generation are expected for the next year.

h) Summary of any complaints received during the reporting period and any steps taken to address the complaints

All complaints received from the public are administered and tracked through a central database. No complaints were received in 2025.

i) Summary of all By-pass, spill or abnormal discharge

No by-passes, spills or abnormal discharges occurred during the reporting period.

j) Status update of the initial effluent characterization

The initial effluent characterization report was submitted to Ministry of the Environment, Conservation and Parks (MECP) in 2016.

k) Information required by MECP District Manager

No additional information was requested.

Ministry of the Environment, Conservation and Parks (MECP) Inspection

The plant was inspected by the MECP on March 7, 2019.



**Uxbridge Brook Water Pollution Control Plant
2025 Annual Performance Report**

Table 1 Final Effluent Flows

Month	Total Plant Flow* cubic metre (m ³)	Average Daily Flow In cubic metre per day (m ³ /d)	Maximum Daily Flow m ³ /d
January	103,591	3,342	3,819
February	89,559	3,199	3,398
March	140,475	4,531	6,612
April	148,681	4,956	8,342
May	123,645	3,989	4,329
June	108,470	3,616	4,044
July	101,935	3,288	3,664
August	99,461	3,208	3,512
September	96,640	3,221	3,612
October	98,129	3,165	3,454
November	99,185	3,306	3,642
December	108,181	3,490	4,999
Total	1,317,952		
Average	109,829	3,611**	
Minimum	89,559		
Maximum	148,681		8,342
ECA Limit		5,221**	15,110
Met Compliance		Yes	Yes

*Metered at the Final Effluent

**Annual average daily flow



**Uxbridge Brook Water Pollution Control Plant
2025 Annual Performance Report**

Table 2 Raw Influent Analyses

Month	Biochemical Oxygen Demand (BOD ₅) average (avg.) concentration (conc.) milligrams per litre (mg/L)	Total Suspended Solids (TSS) avg. conc. mg/L	Total Phosphorus (TP) avg. conc. mg/L	Dissolved Phosphorus avg. conc. mg/L
January	195	267	4.0	2.1
February	192	316	4.4	2.2
March	154	180	3.5	1.4
April	148	171	3.3	1.4
May	170	264	3.8	1.7
June	181	211	4.0	2.3
July	174	182	4.4	2.4
August	147	200	4.8	2.6
September	149	192	4.9	2.6
October	151	264	4.6	2.7
November	147	234	4.6	2.6
December	163	221	4.2	2.2
Average	164	225	4.2	2.2
Minimum	147	171	3.3	1.4
Maximum	195	316	4.9	2.7
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes



**Uxbridge Brook Water Pollution Control Plant
2025 Annual Performance Report**

Table 2 Raw Influent Analyses continued

Month	Total Kjeldahl Nitrogen (TKN) average (avg.) concentration (conc.) milligrams per litre (mg/L)	Total ammonia nitrogen (TAN) avg. conc. mg/L	Alkalinity Calcium Carbonate mg/L	pH minimum	pH maximum	Temperature Degree Celsius avg.
January	33.27	25.9	336	6.9	8.5	12.7
February	37.83	26.7	338	7.9	8.6	12.1
March	27.98	19.1	311	7.8	8.4	11.9
April	28.43	18.8	325	7.6	9.4	12.2
May	31.89	23.7	336	8.0	8.5	15.0
June	36.30	27.2	336	8.1	8.5	16.6
July	39.11	28.5	336	8.1	8.5	18.2
August	41.00	28.5	333	6.8	8.6	18.8
September	41.40	27.3	337	7.8	8.5	18.5
October	40.91	28.8	335	6.8	8.6	17.4
November	38.34	27.8	343	8.1	8.6	15.5
December	37.04	24.9	330	7.0	8.7	13.5
Average	36.13	25.6	333			15.2
Minimum	27.98	18.8	311	6.8		11.9
Maximum	41.40	28.8	343		9.4	18.8
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes	Yes	Yes



**Uxbridge Brook Water Pollution Control Plant
2025 Annual Performance Report**

Table 3 Final Effluent Analyses

Month	Carbonaceous Biochemical Oxygen Demand (CBOD ₅) average (avg.) concentration (conc.) milligrams per litre (mg/L)	CBOD ₅ kilograms per day (kg/d) year to date avg.	Total Suspended Solids (TSS) avg. conc. mg/L	TSS kg/d year to date avg.
January	1.0	3.3	6	21.2
February	1.0	3.3	7	21.3
March	1.0	3.7	3	20.0
April	1.0	4.0	3	19.3
May	1.3	4.3	2	16.9
June	1.0	4.2	1	14.2
July	1.2	4.2	1	12.2
August	1.0	4.0	1	10.8
September	1.0	3.9	0	9.6
October	1.1	3.9	1	8.7
November	1.2	3.9	1	8.1
December	1.0	3.9	0	7.4
Annual Loading		3.9**		7.4**
Average	1.1		2	
Minimum	1.0		0	
Maximum	1.3		7	
ECA Limit	8.5*	30.9**	10*	36.3**
ECA Objective	5		5	
Within Compliance	Yes	Yes	Yes	Yes
Sampling Frequency Requirement Met	Yes		Yes	

*Monthly Average Concentration

**Annual Average Loading



**Uxbridge Brook Water Pollution Control Plant
2025 Annual Performance Report**

Table 3 Final Effluent Analyses continued

Month	Total Phosphorus (TP) average (avg.) concentration (conc.) milligrams per litre (mg/L)*	TP kilograms per day (kg/d) monthly avg.**	TP kilograms per year (kg/yr) year to date avg.
January	0.08	0.27	8
February	0.10	0.32	17
March	0.03	0.14	23
April	0.05	0.25	31
May	0.04	0.16	36
June	0.03	0.11	39
July	0.03	0.10	42
August	0.03	0.10	45
September	0.07	0.23	52
October	0.04	0.13	56
November	0.07	0.23	63
December	0.04	0.14	67
Annual Loading			67***
Average	0.05****	0.18	
Minimum	0.03	0.10**	
Maximum	0.10	0.32**	
ECA Limit	0.15*	0.78**	286***
ECA Objective	0.1		
Lake Simcoe Phosphorus Reduction Strategy	0.15****		286***
Within Compliance	Yes	Yes	Yes
Sampling Frequency Requirement Met	Yes		

*Monthly Average Concentration
 **Monthly Average Loading
 ***Total Annual Average Loading
 ****Annual Average Concentration



**Uxbridge Brook Water Pollution Control Plant
2025 Annual Performance Report**

Table 3 Final Effluent Analyses continued

Month	Dissolved Phosphorus average (avg.) concentration (conc.) milligrams per litre (mg/L)	Total Ammonia Nitrogen (TAN) Winter avg. conc. mg/L	TAN Winter kilograms per day (kg/d) monthly avg.	TAN Summer avg. conc. mg/L	TAN Summer kg/d monthly avg.	Unionized Ammonia Nitrogen avg. conc. mg/L
January	0.01	0	0.1			0.0
February	0.01	0	0.2			0.0
March	0.01	0	0.1			0.0
April	0.01	0	0.1			0.0
May	0.01			0	1.1	0.0
June	0.01			0	0.1	0.0
July	0.01			0	0.3	0.0
August	0.02			0	0.1	0.0
September	0.05			0	0.3	0.0
October	0.02			0	0.1	0.0
November	0.03			0	0.1	0.0
December	0.02	0	0.1			0.0
Average	0.02	0	0.1	0	0.3	0.0
Minimum	0.01	0	0.1	0	0.1	0.0
Maximum	0.05	0	0.2	0	1.1	0.0
ECA Limit		6*	21.8**	3*	10.9**	0.1*
ECA Objective		5		2		
Within Compliance		Yes	Yes	Yes	Yes	Yes
Sampling Frequency Requirement Met	Yes	Yes		Yes		Yes

*Monthly Average Concentration

**Monthly Average Loading



**Uxbridge Brook Water Pollution Control Plant
2025 Annual Performance Report**

Table 3 Final Effluent Analyses continued

Month	Nitrate Nitrogen average (avg.) concentration (conc.) milligrams per litre (mg/L)	Alkalinity calcium carbonate mg/L	pH minimum.	pH maximum.	Temp. Degree Celsius avg.
January	27.1	97	6.2	7.2	11.0
February	30.3	91	6.6	6.9	10.8
March	22.6	123	6.7	7.1	11.7
April	22.2	141	6.9	7.3	12.3
May	26.9	111	6.8	7.0	15.5
June	29.5	104	6.6	7.1	18.0
July	30.4	87	6.5	7.0	20.1
August	28.1	82	6.5	7.2	20.0
September	32.1	84	6.5	7.1	19.5
October	30.6	82	6.6	7.2	17.5
November	32.6	96	6.8	7.1	15.2
December	29.0	126	6.9	7.2	12.5
Average	28.5	102			15.3
Minimum	22.2	82	6.2		10.8
Maximum	32.6	141		7.3	20.1
ECA Limit			6.0	9.5	
ECA Objective			6.5	9.0	
Within Compliance			Yes	Yes	
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes	Yes



Uxbridge Brook Water Pollution Control Plant 2025 Annual Performance Report

Table 4 *Escherichia coli* Sampling

Month	Number of Samples	Monthly Geometric Mean Density
January	9	1
February	8	1
March	8	1
April	9	1
May	8	1
June	8	1
July	10	1
August	8	1
September	8	1
October	10	1
November	8	1
December	8	1
ECA Objective		200 organisms/100mL
Sampling Frequency Requirement Met	Yes	



**Uxbridge Brook Water Pollution Control Plant
2025 Annual Performance Report**

Table 5 Chemical and Energy Usage

Month	Aluminum Sulphate litres	Hydro kilowatt hours	Natural Gas cubic metres
January	19,788	128,931	4,322
February	17,838	116,216	148
March	24,088	128,001	140
April	22,521	124,266	1,183
May	18,701	113,046	595
June	16,321	106,800	173
July	15,884	110,154	121
August	13,680	111,643	167
September	13,016	104,580	59
October	13,674	109,407	953
November	13,499	117,444	1,805
December	15,829	135,751	3,001
Total	204,839	1,406,238	12,667