

## **The Regional Municipality of Durham**

### **Orono Drinking Water System 2016 Annual Report**

**Drinking Water System Number:** 220004769

**Municipal Drinking Water Licence Number:** 003-108

**Drinking Water System Owner:** The Regional Municipality of Durham

**Drinking Water System Category:** Large Municipal Residential

This Annual Report for the calendar year 2016 is designed to inform you about your drinking water system. This report has been prepared to satisfy Section 11 of Ontario Regulation (O. Reg.) 170/03. O. Reg. 170/03 sets requirements for drinking water systems with regard to sampling and testing, levels of treatment, certification of staff, and notification of authorities and the public about water quality. Hard copies of this report are available at the Regional Municipality of Durham Headquarters building located at 605 Rossland Road East, Whitby or on the [Region of Durham's website](http://www.durham.ca) at [www.durham.ca](http://www.durham.ca). Further information on the Drinking Water Regulations can be found on the [Ministry of the Environment and Climate Change's website](http://www.ontario.ca/ministry-environment-and-climate-change) at [www.ontario.ca/ministry-environment-and-climate-change](http://www.ontario.ca/ministry-environment-and-climate-change).

#### **Drinking Water System Process Description**

##### **General**

The Orono Drinking Water System provides potable water to consumers in the Village of Orono in the Municipality of Clarington. Orono has three municipal wells designated Well No. 3, Well No. 4 and Well No. 5. Well No. 5 is currently not in service. Orono is a Class Two Distribution and Supply System with an approved combined capacity of 1,745 cubic metres per day (m<sup>3</sup>/d). The Orono treatment and distribution system is owned and operated by the Regional Municipality of Durham.

The water supply system includes the following three processes:

- Disinfection (sodium hypochlorite),
- Water storage/pressurization
- Distribution.

##### **Raw Water Supply**

Water is pumped from two municipal wells within the Village of Orono. Well No. 3 and Well No. 4 are each drilled to a depth of 13.7 metres (m). Water is delivered to the system by the well pumps.

##### **Disinfection**

The main pumphouse contains the disinfection equipment for both Well No. 3 and 4. The water is disinfected with sodium hypochlorite. The free chlorine residual and turbidity are monitored continuously by online analyzers.

**Distribution System**

The distribution system delivers the treated water through approximately 11.3 kilometres of watermains in two pressure zones, and includes a booster station and a 680 cubic metre standpipe for storage and pressure equalization.

**Major Monetary expenses (above \$10,000)**

Under Section 11 of O. Reg. 170/03, a description of any major expenses incurred during this reporting period to install, repair or replace required equipment must be included in the annual report. The details of major expenses for this drinking water system are as follows:

Foam swabbing of watermains - \$16,000

## Tables

For a description of terms and abbreviations in all tables, refer to the glossary at the end of the report.

### Orono Drinking Water System (DWS) Table 1

Summary of all Adverse Water Quality Incidents (AWQI) in 2016 Reported to Spills Action Centre in Accordance with Schedule 16-3 and 16-4 of O. Reg. 170/03.

Incident Date	Parameter	Result	Corrective Action	Corrective Action Date
November 3	Total Coliforms (distribution)	2 Colony Forming Units per 100 Millilitres	Flushed, resampled. Results met Ontario Drinking Water Quality Standards (ODWQS).	November 4

### Orono DWS Table 2

Membrane Filtration (MF) Testing Under Schedule 10 of O. Reg. 170/03.

Type of Sample	Number of Samples	Range of Escherichia Coli MF Colony Forming Units per 100 Millilitres	Range of Total Coliforms MF Colony Forming Units per 100 Millilitres
Raw	106	Non-Detect (ND)	ND
Treated	0	N/A	N/A
Distribution	20	ND	ND - 2(1)*

\*Number in parenthesis represents number of exceedance(s).

### Orono DWS Table 3

Presence Absence (P/A) Testing Under Schedule 10 of O. Reg. 170/03.

Type of Sample	Number of Samples	Escherichia Coli P/A per 100 Millilitres	Total Coliforms P/A per 100 Millilitres
Treated	104	Absence (A)	A
Distribution	155	A	A

**Orono DWS Table 4**

**Heterotrophic Plate Count (HPC) Testing Under Schedule 10 of O. Reg. 170/03.**

Type of Sample	Number of Samples	Range of HPC Samples Colony Forming Units per Millilitre
Treated	104	Non-Detect (ND) - 3
Distribution	175	ND - 22

**Orono DWS Table 5**

**Operational Testing Done Under Schedule 7 of O. Reg. 170/03.**

Test	Number of Samples	Range of Results	Unit of Measure	Parameter Description
<b>Turbidity - Raw Water</b>	153	0.05 - 0.15	Nephelometric Turbidity Units (NTU)	Turbidity is a measure of particles in water.
<b>Free Chlorine - Plant</b>	Continuous	1.42 - 3.11*	Milligram per Litre (mg/L)	Must be sufficient to ensure disinfection has been achieved.
<b>Free Chlorine - Distribution</b>	Continuous	0.36 - 1.99*	mg/L	Recommended level of at least 0.20 mg/L in the distribution system to maintain secondary disinfection, 0.05 mg/L is the minimum required.

\*Results include all analyzers and grab samples.

## Orono DWS Table 6

### Summary of Treated Water Inorganic Parameters Tested Under Schedule 13 and 23 of O. Reg. 170/03.

Parameter	Number of Samples	Results Range	M.A.C.	Unit of Measure	M.A.C. Exceedance	Potential Sources <sup>1</sup>
<b>Antimony</b>	10	Non-Detect (ND)	0.006	Milligram per Litre (mg/L)	No	Fire retardants, ceramics, electronics, solder.
<b>Arsenic</b>	10	ND	0.025	mg/L	No	Mining.
<b>Barium</b>	2	0.077 - 0.101	1.0	mg/L	No	Metal refineries, oil drilling.
<b>Boron</b>	2	0.0184 - 0.0242	5.0	mg/L	No	Industrial.
<b>Cadmium</b>	10	ND	0.005	mg/L	No	Industrial.
<b>Chromium</b>	10	ND	0.05	mg/L	No	Industrial.
<b>Mercury</b>	2	ND - 0.00003	0.001	mg/L	No	Industrial.
<b>Selenium</b>	9	ND - 0.0012	0.01	mg/L	No	Refineries, mines, chemical manufacturing.
<b>Sodium<sup>2</sup></b>	9	18.4 - 37.5	20	mg/L	Yes (8) <sup>3</sup>	Runoff from road salt.
<b>Uranium</b>	2	0.0017 - 0.0019	0.02	mg/L	No	Power generation.
<b>Fluoride</b>	9	0.04 - 0.08	1.5	mg/L	No	Mining.
<b>Nitrite</b>	9	ND	1.0	mg/L	No	Agriculture runoff, landfill leachate and animal waste.
<b>Nitrate</b>	9	0.61 - 2.43	10.0	mg/L	No	Fertilizer.

1 Parameters may occur naturally in the environment.

2 Sodium does not have a Maximum Acceptable Concentration (MAC); only an aesthetic objective of 200 mg/L. Sodium results exceeding 20 mg/L are to be reported to the Medical Officer of Health as per Schedule 16-3 (8) of O. Reg. 170/03.

3 Number in parenthesis represents number of exceedance(s).

**Orono DWS Table 7**

**Summary of Lead Testing Under Schedule 15.1 of O. Reg. 170/03. No lead samples from plumbing were required in 2016.**

Location Type	Number of Samples	Range of Lead Results Milligram per Litre	MAC	Number of Exceedances	pH	Alkalinity Milligram per Litre
<b>Plumbing</b>	0	N/A	0.01	0	N/A	N/A
<b>Distribution</b>	4	Non-Detect (ND) - 0.0085	0.01	0	7.38 - 7.41	251 - 263

**Orono DWS Table 8**

**Summary of Treated Water Organic Parameters Tested Under Schedule 24 of O. Reg. 170/03.**

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources
<b>Alachlor</b>	2	Non-Detect (ND)	5	Microgram per Litre (ug/L)	No	Agricultural herbicide.
<b>Atrazine + N-dealkylated metabolites</b>	2	ND	5	ug/L	No	Agricultural herbicide.
<b>Azinphos-methyl</b>	2	ND	20	ug/L	No	Insecticide.
<b>Benzene</b>	2	ND	5	ug/L	No	Plastics manufacturing, leaking fuel tanks.
<b>Benzo(a)pyrene</b>	2	ND	0.01	ug/L	No	Formed from the incomplete burning of organic matter.
<b>Bromoxynil</b>	2	ND	5	ug/L	No	Agricultural herbicide.
<b>Carbaryl</b>	2	ND	90	ug/L	No	Agricultural, forestry, household insecticide.

**Orono DWS Table 8 continued**

<b>Parameter</b>	<b>Number of Samples</b>	<b>Results Range</b>	<b>MAC</b>	<b>Unit of Measure</b>	<b>MAC Exceedance</b>	<b>Potential Sources</b>
<b>Carbofuran</b>	2	Non-Detect (ND)	90	Microgram per Litre (ug/L)	No	Agricultural insecticide.
<b>Carbon Tetrachloride</b>	2	ND	5	ug/L	No	Chemical and industrial activities.
<b>Chlorpyrifos</b>	2	ND	90	ug/L	No	Agricultural, household insecticide.
<b>Diazinon</b>	2	ND	20	ug/L	No	Agricultural, livestock, operation, residential insecticide.
<b>Dicamba</b>	2	ND	120	ug/L	No	Agricultural herbicide
<b>1,2-Dichlorobenzene</b>	2	ND	200	ug/L	No	Chemical and industrial factories.
<b>1,4-Dichlorobenzene</b>	2	ND	5	ug/L	No	Chemical and industrial factories.
<b>1,2-Dichloroethane</b>	2	ND	5	ug/L	No	Industrial chemical factories.
<b>1,1-Dichloroethylene (vinylidene chloride)</b>	2	ND	14	ug/L	No	Industrial chemical factories.
<b>Dichloromethane</b>	2	ND	50	ug/L	No	Pharmaceutical and chemical factories.
<b>2,4-dichlorophenol</b>	2	ND	900	ug/L	No	Industrial contamination, reaction with chlorine.
<b>2,4-Dichlorophenoxy acetic acid (2,4-D)</b>	2	ND	100	ug/L	No	Agricultural, residential herbicide.

**Orono DWS Table 8 continued**

<b>Parameter</b>	<b>Number of Samples</b>	<b>Results Range</b>	<b>MAC</b>	<b>Unit of Measure</b>	<b>MAC Exceedance</b>	<b>Potential Sources</b>
<b>Diclofop-methyl</b>	2	Non-Detect (ND)	9	Microgram per Litre (ug/L)	No	Agricultural herbicide.
<b>Dimethoate</b>	2	ND	20	ug/L	No	Agricultural, livestock, operation, residential insecticide.
<b>Diquat</b>	2	ND	70	ug/L	No	Agricultural, aquatic herbicide.
<b>Diuron</b>	2	ND	150	ug/L	No	Agricultural, industrial herbicide.
<b>Glyphosate</b>	2	ND	280	ug/L	No	Agricultural, forestry, household herbicide.
<b>Malathion</b>	2	ND	190	ug/L	No	Pest control insecticide.
<b>2-Methyl-4-chlorophenoxyacetic acid (MCPA)</b>	2	ND	100	ug/L	No	Agricultural herbicide.
<b>Metolachlor</b>	2	ND	50	ug/L	No	Agricultural herbicide.
<b>Metribuzin</b>	2	ND	80	ug/L	No	Agricultural herbicide.
<b>Monochlorobenzene</b>	2	ND	80	ug/L	No	Industrial and agricultural chemical factories and dry cleaning facilities.
<b>Paraquat</b>	2	ND	10	ug/L	No	Agricultural, aquatic herbicide.
<b>Pentachlorophenol</b>	2	ND	60	ug/L	No	Pesticide, wood preservative residue.



**Orono DWS Table 8 continued**

<b>Parameter</b>	<b>Number of Samples</b>	<b>Results Range</b>	<b>MAC</b>	<b>Unit of Measure</b>	<b>MAC Exceedance</b>	<b>Potential Sources</b>
<b>Phorate</b>	2	Non-Detect (ND)	2	Microgram per Litre (ug/L)	No	Agricultural insecticide.
<b>Picloram</b>	2	ND	190	ug/L	No	Industrial herbicide.
<b>Polychlorinated Biphenyls(PCB)</b>	2	ND	3	ug/L	No	Residue from various industrial uses.
<b>Prometryne</b>	2	ND	1	ug/L	No	Agricultural herbicide.
<b>Simazine</b>	2	ND	10	ug/L	No	Agricultural herbicide.
<b>THM - Distribution (annual average)</b>	4	34.1	100	ug/L	No	By-product of chlorination of drinking water.
<b>Terbufos</b>	2	ND	1	ug/L	No	Agricultural insecticide.
<b>Tetrachloroethylene (perchloroethylene)</b>	2	ND	30	ug/L	No	Leaching from PVC pipes; discharge from factories; dry cleaners and auto shops (metal degreaser).
<b>2,3,4,6 - Tetrachlorophenol</b>	2	ND	100	ug/L	No	Wood preservative.
<b>Triallate</b>	2	ND	230	ug/L	No	Agricultural herbicide.
<b>Trichloroethylene</b>	2	ND	5	ug/L	No	Metal degreasing sites and other factories.
<b>2,4,6-Trichlorophenol</b>	2	ND	5	ug/L	No	Pesticide manufacturing.

**Orono DWS Table 8 continued**

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources
Trifluralin	2	Non-Detect (ND)	45	Microgram per Litre (ug/L)	No	Agricultural herbicide.
Vinyl Chloride	2	ND	2	ug/L	No	Leaching from PVC pipes; discharge from plastics factories.

**Orono DWS Table 9**

**Inorganic or Organic Parameter(s) that Exceed Half the Standard Prescribed in Schedule 2 of the Ontario Drinking Water Quality Standards.**

No inorganic or organic parameters exceeded half the maximum allowable concentration in 2016.

Parameter	Result	Unit of Measure	Date of Sample
Not Applicable (NA)	NA	NA	NA