

The Regional Municipality of Durham

Uxbridge Drinking Water System 2014 Annual Report

Drinking Water System Number: 220000763

Municipal Drinking Water License Number: 003-105

Drinking Water System Owner: The Regional Municipality of Durham

Drinking Water System Category: Large Municipal Residential

This Annual Report for the calendar year 2014 is designed to inform you about your drinking water system. This report has been prepared to satisfy Section 11 of Ontario Regulation (O. Reg.) 170/03. O. Reg. 170/03 sets requirements for drinking water systems with regard to sampling and testing, levels of treatment, certification of staff, and notification of authorities and the public about water quality. Hard copies of this report are available at the Regional Municipality of Durham Headquarters building located at 605 Rossland Road East, Whitby or on the [Region of Durham's website](http://www.durham.ca) at www.durham.ca. Further information on the Drinking Water Regulations can be found on the [Ministry of the Environment and Climate Change's website](http://www.ontario.ca/ministry-environment-and-climate-change) at www.ontario.ca/ministry-environment-and-climate-change.

Drinking Water System Process Description

General

The Uxbridge Drinking Water System provides potable water to consumers in the Town of Uxbridge in the Township of Uxbridge. Uxbridge has three municipal wells designated Well No. 5, Well No. 6 and Well No. 7. Uxbridge is a Class II Water Distribution and Supply System with an approved combined capacity of 12,182 cubic metres per day (m³/d). The Uxbridge Drinking Water System feeds a Class One Distribution System and a Class Two Trunk Distribution System. The Uxbridge treatment and distribution system is owned and operated by the Regional Municipality of Durham.

The water supply system includes the following five processes:

- Disinfection (sodium hypochlorite, chlorine gas),
- Iron sequestering (sodium silicate),
- Ultraviolet (UV) disinfection (Well No. 5 and Well No. 7 only),
- Distribution, and
- Storage.

Raw Water Supply

Water is pumped from three municipal wells in Uxbridge. Wells No. 5, 6 and 7 are drilled to depths of 76.5 metres (m), 58.2 m and 66.5 m respectively. Water is delivered to the system by the well pumps.

Disinfection/Iron Sequestering

Sodium silicate is added to the water at each well facility for iron sequestering (control). Sodium hypochlorite is added to provide disinfection in Well 6, while Wells 5 and 7 use chlorine gas. UV treatment provides additional disinfection at Wells No. 5 & Well No. 7. The free chlorine residual and turbidity are monitored continuously by online analyzers.

The UV and chlorination systems will shut down the well pumps if an alarm occurs. This ensures the water is disinfected.

Water Storage/Pressurization

Treated water is pumped to the distribution system and to the Quaker Hill Reservoir, which has a capacity of 2,841 cubic metres. The zone two pumping station, located at the Quaker Hill Reservoir, is equipped with four high lift in-line centrifugal pumps, and a sodium hypochlorite disinfection system.

Distribution System

The distribution system delivers the treated water through approximately 59 kilometres of watermains in two pressure zones which includes the Quaker Hill Reservoir and zone two pumping station.

Major Monetary expenses(above \$10,000)

Under Section 11 of O. Reg. 170/03, a description of any major expenses incurred during this reporting period to install, repair or replace required equipment must be included in the annual report.

Chlorinator replacement Wells No. 5 and 7 - \$10,107.85

Tables

For a description of terms and abbreviations in all tables, refer to the glossary at the end of the report.

Uxbridge Drinking Water System (DWS) Table 1

Summary of all Adverse Water Quality Incidents (AWQI) in 2014 Reported to Spills Action Centre in Accordance with Schedule 16-3 and 16-4 of O. Reg. 170/03.

Incident Date	Parameter	Result	Corrective Action	Corrective Action Date
November 1	Low Pressure (Distribution)	Not Available (N/A)	Pressure restored, system flushed, samples collected. Results met Ontario Drinking Water Quality Standards (ODWQS)	November 1
November 17	Low Pressure (Distribution)	N/A	Pressure restored, system flushed, samples collected. Results met ODWQS	November 17
November 19	Low Pressure (Distribution)	N/A	Pressure restored, system flushed, samples collected. Results met ODWQS	November 19
December 19	Low Pressure (Distribution)	N/A	Pressure restored, system flushed, samples collected. Results met ODWQS	December 19
December 19	Low Pressure (Distribution)	N/A	Pressure restored, system flushed, samples collected. Results met ODWQS	December 19

Uxbridge DWS Table 2

Membrane Filtration (MF) Testing Under Schedule 10 of O. Reg. 170/03.

Type of Sample	Number of Samples	Range of Escherichia Coli MF Colony Forming Units per 100 millilitres	Range of Total Coliforms MF Colony Forming Units per 100 millilitres
Raw	156	Non-Detect (ND)	ND
Treated	1	ND	ND
Distribution	22	ND	ND

Uxbridge DWS Table 3

Presence Absence (P/A) Testing Under Schedule 10 of O. Reg. 170/03.

Type of Sample	Number of Samples	Escherichia Coli P/A per 100 millilitres	Total Coliforms P/A per 100 millilitres
Treated	156	Absence (A)	A
Distribution	304	A	A

Uxbridge DWS Table 4

Heterotrophic Plate Count (HPC) Testing Under Schedule 10 of O. Reg. 170/03.

Type of Sample	Number of Samples	Range of HPC Samples Colony Forming Units per millilitre
Treated	157	Non-Detect (ND) - 27
Distribution	168	ND - 10

Uxbridge DWS Table 5

Operational Testing Done Under Schedule 7 of O. Reg. 170/03.

Test	Number of Samples	Range of Results	Unit of Measure	Parameter Description
Turbidity - Raw Water	158	0.06 - 0.31	Nephelometric Turbidity Units (NTU)	Turbidity is a measure of particles in water.
Free Chlorine - Plant	Continuous	0.7 - 2.46*	Milligram per Litre (mg/L)	Must be sufficient to ensure disinfection has been achieved.
Free Chlorine - Distribution	Continuous	0.43 - 1.47*	mg/L	Recommended level of at least 0.20 mg/L in the distribution system to maintain secondary disinfection, 0.05 mg/L is the minimum required.

*Results include all analyzers and grab samples.

Uxbridge DWS Table 6

Summary of Treated Water Inorganic Parameters Tested Under Schedule 13 and 23 of O. Reg. 170/03.

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources ¹
Antimony	15	0.0002 - 0.0007	0.006	Milligram per Litre (mg/L)	No	Fire retardants, ceramics, electronics, solder.
Arsenic	15	Non-Detect(ND) - 0.0002	0.025	mg/L	No	Mining.
Barium	3	0.107 - 0.116	1.0	mg/L	No	Metal refineries, oil drilling.
Boron	3	0.010 - 0.012	5.0	mg/L	No	Industrial.
Cadmium	15	ND - 0.0001	0.005	mg/L	No	Industrial.
Chromium	15	ND - 0.0033	0.05	mg/L	No	Industrial.
Mercury	3	ND	0.001	mg/L	No	Industrial.
Selenium	15	ND - 0.0005	0.01	mg/L	No	Refineries, mines, chemical manufacturing.
Sodium²	12	5.3 - 11.6	20	mg/L	No	Runoff from road salt.
Uranium	3	ND	0.02	mg/L	No	Power generation.
Fluoride	12	0.04 - 0.10	1.5	mg/L	No	Mining.
Nitrite	12	ND	1.0	mg/L	No	Agriculture runoff, landfill leachate and animal waste.
Nitrate	12	ND - 0.010	10.0	mg/L	No	Fertilizer.

1 Parameters may occur naturally in the environment.

2 Sodium does not have a Maximum Acceptable Concentration (MAC); only an aesthetic objective of 200 mg/L Sodium results exceeding 20 mg/L are to be reported as per the Medical Officer of Health Schedule 16-3 (8) of O. Reg. 170/03.

Uxbridge DWS Table 7

Summary of Lead Testing Under Schedule 15.1 of O. Reg. 170/03 No plumbing samples were required to be taken in 2014.

Location Type	Number of Samples	Range of Lead Results milligram per litre	MAC	Number of Exceedences
Plumbing	0	Not Applicable (N/A)	0.01	N/A
Distribution	8	Non-Detect (ND) - 0.0033	0.01	0

Uxbridge DWS Table 8

Summary of Treated Water Organic Parameters Tested Under Schedule 24 of O. Reg. 170/03.

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources
Alachlor	3	Non-Detect (ND)	5	microgram/litre (ug/L)	No	Agricultural herbicide.
Aldicarb	3	ND	9	ug/L	No	Agricultural insecticide.
Aldrin + Dieldrin	3	ND	0.7	ug/L	No	Residue from banned insecticide.
Atrazine + N-dealkylated metabolites	3	ND	5	ug/L	No	Agricultural herbicide.
Azinphos-methyl	3	ND	20	ug/L	No	Insecticide.
Bendiocarb	3	ND	40	ug/L	No	Insecticide.
Benzene	3	ND	5	ug/L	No	Plastics manufacturing, leaking fuel tanks.
Benzo(a)pyrene	3	ND	0.01	ug/L	No	Formed from the incomplete burning of organic matter.
Bromoxynil	3	ND	5	ug/L	No	Agricultural herbicide.

Uxbridge DWS Table 8 continued

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources
Carbaryl	3	Non-Detect (ND)	90	microgram/litre (ug/L)	No	Agricultural, forestry, household insecticide.
Carbofuran	3	ND	90	ug/L	No	Agricultural insecticide.
Carbon Tetrachloride	3	ND	5	ug/L	No	Chemical and industrial activities.
Chlordane (Total)	3	ND	7	ug/L	No	Residue from banned insecticide.
Chlorpyrifos	3	ND	90	ug/L	No	Agricultural, household insecticide.
Cyanazine	3	ND	10	ug/L	No	Agricultural, residential herbicide.
Diazinon	3	ND	20	ug/L	No	Agricultural, livestock, operation, residential insecticide.
Dicamba	3	ND	120	ug/L	No	Agricultural herbicide.
1,2-Dichlorobenzene	3	ND	200	ug/L	No	Chemical and industrial factories.
1,4-Dichlorobenzene	3	ND	5	ug/L	No	Chemical and industrial factories.
Dichlorodiphenyltrichloroethane (DDT) + metabolites	3	ND	30	ug/L	No	Residue from banned insecticide.
1,2-Dichloroethane	3	ND	5	ug/L	No	Industrial chemical factories.
1,1-Dichloroethylene (vinylidene chloride)	3	ND	14	ug/L	No	Industrial chemical factories.
Dichloromethane	3	ND	50	ug/L	No	Pharmaceutical and chemical factories.

Uxbridge DWS Table 8 continued

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources
2,4-dichlorophenol	3	Non-Detect (ND)	900	microgram/litre (ug/L)	No	Industrial contamination, reaction with chlorine.
2,4-Dichlorophenoxy acetic acid (2,4-D)	3	ND	100	ug/L	No	Agricultural, residential herbicide.
Diclofop-methyl	3	ND	9	ug/L	No	Agricultural herbicide.
Dimethoate	3	ND	20	ug/L	No	Agricultural, livestock, operation, residential insecticide.
Dinoseb	3	ND	10	ug/L	No	Herbicide residue.
Diquat	3	ND	70	ug/L	No	Agricultural, aquatic herbicide.
Diuron	3	ND	150	ug/L	No	Agricultural, industrial herbicide.
Glyphosate	3	ND	280	ug/L	No	Agricultural, forestry, household herbicide.
Heptachlor + Heptachlor Epoxide	3	ND	3	ug/L	No	Residue from banned insecticide.
Lindane (Total)	3	ND	4	ug/L	No	Agricultural, pharmaceutical insecticide.
Malathion	3	ND	190	ug/L	No	Pest control insecticide.
Methoxychlor	3	ND	900	ug/L	No	Agricultural, livestock, operation, residential insecticide.
Metolachlor	3	ND	50	ug/L	No	Agricultural herbicide.

Uxbridge DWS Table 8 continued

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources
Metribuzin	3	Non-Detect (ND)	80	microgram/litre (ug/L)	No	Agricultural herbicide.
Monochlorobenzene	3	ND	80	ug/L	No	Industrial and agricultural chemical factories and dry cleaning facilities.
Paraquat	3	ND	10	ug/L	No	Agricultural, aquatic herbicide.
Parathion	3	ND	50	ug/L	No	Agricultural insecticide.
Pentachlorophenol	3	ND	60	ug/L	No	Pesticide, wood preservative residue.
Phorate	3	ND	2	ug/L	No	Agricultural insecticide.
Picloram	3	ND	190	ug/L	No	Industrial herbicide.
Polychlorinated Biphenyls (PCB)	3	ND	3	ug/L	No	Residue from various industrial uses.
Prometryne	3	ND	1	ug/L	No	Agricultural herbicide.
Simazine	3	ND	10	ug/L	No	Agricultural herbicide.
Trihalomethane (THM) - Distribution (annual average)	4	10.9	100	ug/L	No	By-product of chlorination of drinking water.
Temephos	3	ND	280	ug/L	No	Insecticide for mosquito, black fly control.
Terbufos	3	ND	1	ug/L	No	Agricultural insecticide.
Tetrachloroethylene	3	ND	30	ug/L	No	Leaching from PVC pipes; discharge from factories; dry cleaners and auto shops (metal degreaser).

Uxbridge DWS Table 8 continued

Parameter	Number of Samples	Results Range	MAC	Unit of Measure	MAC Exceedance	Potential Sources
2,3,4,6 - Tetrachlorophenol	3	Non-Detect (ND)	100	microgram/litre (ug/L)	No	Wood preservative.
Triallate	3	ND	230	ug/L	No	Agricultural herbicide.
Trichloroethylene	3	ND	5	ug/L	No	Metal degreasing sites and other factories.
2,4,6-Trichlorophenol	3	ND	5	ug/L	No	Pesticide manufacturing.
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	3	ND	280	ug/L	No	Industrial herbicide residue.
Trifluralin	3	ND	45	ug/L	No	Agricultural herbicide.
Vinyl Chloride	3	ND	2	ug/L	No	Leaching from PVC pipes; discharge from plastics factories.

Uxbridge DWS Table 9

Inorganic or Organic Parameter(s) that Exceed Half the Standard Prescribed in Schedule 2 of the Ontario Drinking Water Quality Standards.

No inorganic or organic parameters exceeded half the maximum allowable concentration in 2014.

Parameter	Result	Unit of Measure	Date of Sample
Not Applicable (N/A)	N/A	N/A	N/A