



**Cannington Water Pollution Control Plant
Annual Performance Report 2016**





The Regional Municipality of Durham

Cannington Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 8730-8CYU2X Dated June 28, 2012

The Cannington Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers an overview of the performance of the Cannington WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

Water Pollution Control Plant Process Description

General

The Cannington WPCP located in the Community of Cannington in the Township of Brock is owned and operated by the Regional Municipality of Durham. The plant is operated according to the terms and conditions of the ECA. This MOECC Class One wastewater treatment plant is designed to treat wastewater at a rated capacity of 1,068 cubic metres per day (m³/d) and utilizes two seasonal wastewater stabilization lagoons. The Cannington WPCP has a service population of 2,292 residents. The treated effluent is discharged to the Beaver River in accordance with the conditions listed in the ECA.

Raw Influent Pumping

Wastewater is collected in approximately 12.7 km of sanitary sewers in the Cannington service area and is conveyed to the treatment facility by a sanitary sewage pumping station located on Laidlaw Street. Aluminum sulphate is added at Laidlaw Street Pumping Station to enhance the settling of solids and phosphorus removal.

Lagoon Treatment

The Cannington WPCP is a seasonal wastewater stabilization lagoon facility consisting of a two cell lagoon system that is operated as a seasonal retention facultative waste stabilization pond providing a retention time of approximately 190 days. Flow to the Cannington WPCP is distributed to each cell through an influent distribution chamber. Each cell is equipped with an outlet chamber and one outfall pipe. The ECA permits two seasonal discharge periods per year. Spring discharge is from March 1st to May 31st and fall discharge is from October 1st to December 31st. Prior to and during discharging to the Beaver River, samples are collected to verify the effluent meets the limits established in the ECA.



Environmental Compliance Approval

Under Condition 9 (4) of ECA #8730-8CYU2X the Region of Durham must produce an annual report that must contain the following information:

a) Summary and interpretation of all monitoring data and a comparison to the effluent limits outlined in Condition 5, including an overview of the success and adequacy of the works

The raw wastewater flowing into the Cannington WPCP is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA.

The Cannington WPCP effluent was determined to be compliant with the approval limits during the reporting period. The plant operated at 77.5% of its rated capacity and received a maximum daily flow of 2,853 m³/d on March 31, 2016. An Inflow and Infiltration study is proposed in 2017. The total treated effluent discharged to the Beaver River in 2016 was calculated to be 315,489 m³.

b) Description of any operating problems encountered and corrective actions taken

No operating problems were encountered in 2016.

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the works

No maintenance was performed on major equipment during the reporting period.

d) Summary of any effluent quality assurance or control measures undertaken in the reporting period

In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. Results were found to be in a comparable range.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment

- Calibration of the influent flow meter located at Laidlaw Street Pumping Station was conducted in May and November, 2016.
- Temperature and pH are monitored in the field, all other routine process control tests are performed at the Lake Simcoe WPCP laboratory in Beaverton. All monitoring and laboratory equipment is calibrated and maintained according to manufacturer's specifications.

f) Estimate of the sludge settling capacity of the lagoons and its annual depletion

The annual depletion of the sludge settling capacity is negligible. There was no removal of biosolids during the reporting period.

g) Description of efforts made and results achieved in meeting the effluent objectives

- The Regional Municipality of Durham strives to achieve the best effluent quality at all times consistently remaining well below ECA limits.
- All effluent objectives were met in 2016 except for CBOD₅ and Total Suspended Solids on March 14, 2016 during spring discharge. In house lab test results were below the



objectives, the discharge was discontinued for an odour issue prior to receiving results from the Regional Environmental Laboratory.

- Best efforts will continue to be applied to maintain results below objectives.
- h) Summary of any complaints received during the reporting period and any steps taken to address the complaint**

A summary of complaints received from the public is administered through a central database. Two odour complaints were received during spring discharge on March 9th and 14th, the odour is deemed to be caused by the melting of ice on the lagoon allowing trapped gases to escape. The discharge was closed March 14th upon receipt of complaints.

i) Summary of all By-pass, Spill or Abnormal Discharge Events

No by-passes, spills or abnormal discharges occurred during the reporting period.

j) Status Update of the Initial Effluent Characterization

The initial effluent characterization report was submitted in April of 2016.

k) Information required by MOECC District Manager

No additional information was requested.

MOECC Inspection

This plant was not inspected by the MOECC in 2016.



Cannington Water Pollution Control Plant
Annual Performance Report 2016

Summary of Tables

Table 1 Raw Influent Flows

Month	Total Flow to Plant -metered at the Laidlaw Street Pumping Station m ³	Average Daily Flow m ³ /d	Maximum Daily Flow m ³ /d	Minimum Daily Flow m ³ /d
January	28,252	911	1,265	638
February	29,190	1,007	1,347	757
March	47,446	1,531	2,853	899
April	43,527	1,451	2,752	950
May	25,397	819	980	709
June	19,590	653	783	526
July	18,756	605	698	508
August	19,141	617	1,379	486
September	16,934	564	655	471
October	17,096	551	610	434
November	17,347	578	625	510
December	20,395	658	1,060	528
Total	303,070			
Annual Average	25,256	828		
Minimum	16,934			434
Maximum	47,446		2,853	
ECA Requirement		1068*		
Met Compliance		Yes		

*Annual Average



Table 2 Raw Influent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d
January	90	82	138	126	186	170	4.8	4.4
February	78	78	109	110	153	154	3.7	3.8
March	88	135	110	169	256	391	3.3	5.0
April	65	94	78	113	101	147	3.3	4.7
May	107	88	132	108	172	141	4.9	4.0
June	179	117	211	138	257	168	7.7	5.0
July	189	114	242	146	242	146	6.4	3.8
August	152	94	243	150	226	140	6.7	4.1
September	183	103	243	137	241	136	7.0	3.9
October	172	95	226	125	247	136	7.8	4.3
November	156	90	195	113	200	116	7.0	4.1
December	125	82	154	101	191	126	6.2	4.1
Average	132	109	173	144	206	171	5.7	4.7
Minimum	65	78	78	101	101	116	3.3	3.8
Maximum	189	135	243	169	257	391	7.8	5.0
Sampling Frequency Requirement Met	Yes		Yes		Yes		Yes	



Cannington Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses continued

Month	DP avg. conc. mg/L	TKN avg. conc. mg/L	TKN loading kg/d	TAN avg. conc. mg/L	TAN loading kg/d	pH min.	pH max.	Temp. Degrees Celsius Min	Temp. Degrees Celsius Max
January	2.4	41.75	38	23.15	21	7.46	8.00	9.8	11.0
February	1.6	30.16	30	18.84	19	7.36	7.90	9.0	10.7
March	1.4	25.53	39	13.53	21	7.27	7.90	8.6	10.5
April	1.7	28.35	41	16.71	24	7.26	8.00	7.8	10.2
May	2.3	44.78	37	28.17	23	7.40	8.01	10.0	13.8
June	4.0	58.38	38	37.39	24	7.50	8.00	12.8	15.2
July	3.5	56.18	34	40.76	25	7.65	8.11	14.8	18.8
August	3.7	58.38	36	39.56	24	8.09	8.12	16.8	17.4
September	3.9	64.18	36	41.59	23	7.81	8.24	16.7	25.0
October	4.5	71.60	39	47.35	26	7.94	8.34	14.5	17.1
November	4.1	66.65	39	48.49	28	7.73	8.12	13.5	15.9
December	3.7	53.18	35	35.36	23	7.28	7.90	10.6	13.4
Average	3.1	49.92	41	32.57	27				
Minimum	1.4	25.53	30	13.53	19	7.26		7.8	
Maximum	4.5	71.60	41	48.49	28		8.34		25.0
Sampling Frequency Requirement Met				Yes		Yes	Yes	Yes	Yes



Table 3 Calculated Effluent Flows

Month	Effluent Flow m ³
January	
February	
March	95,249
April	97,466
May	20,087
June	
July	
August	
September	
October	74,246
November	13,180
December	15,261
Total	315,489
Annual Average	52,581
Minimum	13,180
Maximum	97,466



Table 4 Final Effluent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d	TP loading kg/month
January									
February									
March	9.4	69	11.6	84	13.8	100.6	0.18	1.3	17.3
April	3.2	28	3.6	31	7.4	65.8	0.10	0.9	9.4
May	4.6	24	5.3	27	6.1	31.4	0.07	0.4	1.4
June									
July									
August									
September									
October	3.5	34	6.1	59	8.4	81.2	0.12	1.1	8.6
November	2.7***	10***	5.9***	23***	15.9	61.4	0.22	0.8	2.9
December	6.7	49	9.5	70	8.3	61.2	0.14	1.1	2.2
Total									41.7
Average	5.0	39	7.0	54	10.0	76.7	0.14	1.1	8.1
Minimum	2.7	10	3.6	23	6.1	31.4	0.07	0.4	1.4
Maximum	9.4	69	11.6	84	15.9	100.6	0.22	1.3	17.3
ECA Limit	25**				30**				117*
ECA Objective	15				20		0.5		
LSPRS							0.25**		97*
Within Compliance	Yes				Yes		Yes		Yes
Sampling Frequency Requirement Met	Yes		Yes		Yes		Yes		Yes

*Total Annual Loading, kg/year

**Annual Average Concentration

*** October 31st results, no samples were submitted in November as the discharge stopped November 4th. The weekly sampling requirement was met.



Cannington Water Pollution Control Plant
Annual Performance Report 2016

Table 4 Final Effluent Analyses continued

Month	DP avg. conc. mg/L	TKN avg. conc. mg/L	TAN avg. conc. mg/L	TAN loading kg/d	Un-ionized Ammonia avg. conc. mg/L	pH min.	pH max.	Temp. °C min.	Temp. °C max.
January									
February									
March	0.03	15.23	14.4	105.5	0.02	6.8	7.6	2.4	6.1
April	0.01	6.92	5.4	47.6	0.05	7.3	7.9	4.5	15.8
May	0.01	13.30	12.8	66.1	0.11	7.3	7.8	13.4	18.2
June									
July									
August									
September									
October	0.01	7.56	6.02	58.5	0.04	7.6	7.7	4.2	9.4
November	0.00***	7.72***	6.61	25.5	0.01	7.1	7.1	6.7	10.0
December	0.02	17.40	15.1	110.7	0.02	6.8	7.1	2.1	3.0
Average	0.01	11.35	10.1	77.2	0.04				
Minimum	0.00	6.92	5.4	25.5	0.01	6.8		2.1	
Maximum	0.03	17.40	15.1	110.7	0.11		7.9		18.2
ECA Limit						6.0	9.5		
ECA Objective						6.5	8.0		
Within Compliance						Yes	Yes		
Sampling Frequency Requirement Met			Yes		Yes	Yes	Yes	Yes	Yes



Table 5 Chemical Usage

Month	Aluminum Sulphate (litres)
January	8,395
February	9,794
March	20,383
April	11,357
May	11,117
June	9,107
July	7,503
August	4,369
September	2,132
October	7,562
November	7,373
December	7,228
Total	106,320

Glossary of Terms

Annual Average Concentration

An arithmetic mean of the seasonal average concentrations of a contaminant in the effluent calculated for any particular year.

Annual Average Loading

The value obtained by multiplying the seasonal average concentration of a contaminant by the Average Daily Flow over the same calendar year.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.



By-pass

Any discharge from any portion of the works other than in accordance with the conditions of the ECA.

CBOD₅ -Five Day Carbonaceous Biochemical Oxygen Demand

Means a five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample.

Conc. Concentration

The abundance of a constituent divided by the total volume of a mixture.

Daily Concentration

Means the concentration of a contaminant in the effluent discharged over any single day, as measured by a composite or grab sample, whichever is required.

DP – Dissolved Reactive Phosphorus

This is the soluble form of phosphorus present in the wastewater.

ECA Environmental Compliance Approval

The primary regulatory instrument for each water pollution control plant.

E. coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius.

Final Effluent

Means sewage discharge via the water pollution control plant outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.

Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, when tested provides a snapshot of the conditions at the time the sample was retrieved.

kg - kilogram

Basic unit of mass in the metric system

kg/d – kilogram per day



LSPRS - Lake Simcoe Phosphorus Reduction Strategy

The ECA issued on June 28, 2012 introduced additional phosphorus objectives to comply with the requirements of the Lake Simcoe Phosphorus Reduction Strategy (2010) prepared under the Lake Simcoe Protection Plan (2009).

m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metre Per Day)

Flow measurement, 1m³ = 1000 litres or 220 imperial gallons. Volume of liquid treated in a day.

Max-Maximum

The peak or highest value recorded during a specific time period usually a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.

mg/L - (Milligram Per Litre)

This is a measure of the concentration of a parameter in water, sometimes referred to as parts per million (ppm).

Min-Minimum

The lowest value recorded during a specific time period usually in a day.

mm-(millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.

MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly Average Concentration

Means the arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.

Monthly Average Loading

Is calculated by multiplying the monthly average concentration of a contaminant in the effluent sampled or measured, or both, during a calendar month.



N/A - Not Applicable

N/D - No Discharge

Peak Flow Rate

The maximum rate of sewage flow for which the plant or process unit was designed.

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.

Rated Capacity

The average daily flow for which the works are approved to handle.

Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Seasonal Average Concentration

Means the arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured or both during the seasonal discharge period.

Sludge

The settleable solids separated from liquids during processing.

TAN - Total Ammonia Nitrogen

Ammonia exists in two forms in the water: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.

Total Annual Loading

Is calculated by summarizing the total monthly loadings within a calendar year.

Total Monthly Loading

Is calculated by multiplying the total monthly flow by the monthly average concentration.

TP - Total Phosphorus

A laboratory analyses to determine the total amount of non-soluble and soluble phosphorus present in the wastewater.



TSS - Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS - Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Unionized Ammonia Nitrogen

Un-ionized ammonia refers to all forms of ammonia in water with the exception of the ammonium ion (NH₄⁺).

WPCP - Water Pollution Control Plant

A facility composed of a variety of treatment processes that collectively treat wastewater.

If this information is required in an accessible format, please contact 1-800-372-1102 extension 3488



Corbett Creek Water Pollution Control Plant Annual Performance Report 2016





The Regional Municipality of Durham

Corbett Creek Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 7560-9PPRJC Dated November 12, 2014

Environmental Compliance Approval (Air): 1581-9URJFE Dated May 13, 2015

The Corbett Creek Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers a performance overview of the Corbett Creek WPCP for 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

Water Pollution Control Plant Process Description

General

The Corbett Creek WPCP located in the Town of Whitby and is owned and operated by the Regional Municipality of Durham. The plant is operated according to the terms and conditions of the ECA.

Corbett Creek WPCP treats wastewater from the Whitby, Brooklin and Oshawa service areas. The Corbett Creek WPCP services approximately 143,238 residents.

The Corbett Creek WPCP is designed to treat wastewater at an average daily flow rate of 84,350 cubic metres per day (m³/d). The plant is an MOECC Class Four conventional activated sludge treatment plant that utilizes the following processes to treat wastewater:

- raw influent pumping,
- preliminary treatment,
- primary treatment,
- phosphorus removal
- secondary treatment,
- disinfection (chlorination/dechlorination),
- solids treatment.

Raw Influent Pumping

Wastewater is collected through approximately 450 km of sanitary sewers in the Town of Whitby, the Brooklin urban area, and the City of Oshawa. It is conveyed to the plant by gravity and by several sanitary sewage pumping stations located in the collection system.

Preliminary Treatment

Screening: Two automatic, mechanically cleaned screens remove paper products and large material that could harm pumps and process equipment. Screenings removed in this process are compacted for landfill disposal.



Grit Removal: Heavy suspended material such as sand and small stones (grit) is removed in the two aerated grit tanks. The velocity of the wastewater rolling in the tanks is controlled by the quantity of air added to produce conditions that allow heavy grit material to settle, while keeping the lighter organic material in suspension to proceed to the next process tank. The grit removed in this process is dewatered and transported to landfill.

Primary Treatment

The four primary clarifiers utilize the physical process of sedimentation which allows suspended material to settle to the bottom of the tank as sludge. This raw sludge, along with excess activated sludge from the secondary treatment process is collected by a sweep mechanism which pushes the sludge into hoppers. The sludge is then pumped to the anaerobic digesters for further treatment. Any material floating on the surface of the clarifier (scum) is also removed to the digester.

Secondary Treatment

Aeration: The aeration tank is where fine bubbled air is diffused into the sewage to assist bacteria in removing dissolved and suspended organics, and nutrients from the wastewater. Biological activity is controlled to assimilate the organic material.

Secondary Clarifier: The effluent from the bioreactors is directed to the seven secondary clarifiers where the solids settle quickly to the bottom as activated sludge leaving clear supernatant. A portion of the activated sludge collected on the bottom of the clarifier is pumped back to the head of the bioreactors and the excess activated sludge is wasted to the primary clarifiers.

Phosphorous Removal

The phosphorous removal system is intended to lower the total phosphorous level in the final effluent by adding a chemical coagulant (ferrous chloride). Ferrous chloride is added at the primary effluent.

Disinfection (chlorination/dechlorination)

Chlorine in the form of liquid sodium hypochlorite is metered into the effluent stream for pathogen control. Adequate contact time is provided by the two chlorine contact chambers. Disinfected effluent is dechlorinated with a sodium bisulphite solution before being discharged to Lake Ontario through the 1,800 mm diameter outfall extending 409 m into Lake Ontario.

Solids Treatment

Anaerobic Digestion: The raw sludge that is collected from the primary clarifiers is pumped into the anaerobic digesters where anaerobic bacteria reduce the volume of sludge. As a result of digestion the plant produces a more stabilized sludge, water, carbon dioxide, methane, and hydrogen sulphide. The water is returned to the head of the plant for further treatment.

Biosolids: All digested sludge produced is pumped to the biosolids holding facility. From there the treated biosolids can be utilized on approved agricultural fields or be shipped to Duffin Creek WPCP for incineration. Biosolids are transported plant to plant in accordance with ECA #A820250 and ECA #4400-4LBLEXD for land application.



Environmental Compliance Approval

Under Condition 10 (6) of ECA #7560-9PPRJ the Region of Durham must produce an annual report that contains the following information:

a) Summary and interpretation of all monitoring data and a comparison to the effluent limits

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA. Table 2 summarizes the raw wastewater characteristics during the reporting period.

The Corbett Creek WPCP effluent was determined to be compliant with the ECA approval limits during the reporting period except for one limit exceedance noted below. The plant operated at an average of 56% of its annual average rated flow capacity and received a maximum daily flow of 94,674 m³/d on January 11.

b) Description of any operating problems encountered and corrective actions taken:

- A process difficulty occurred in December on one of the aeration tanks causing extremely high nitrites. This resulted in a large chlorine demand and caused two high individual E.coli results. The monthly geometric mean average for December exceeded the limit of 200cfu/100ml with a result of 205cfu/100ml. The MOECC was notified on January 4, 2017.

c) Maintenance of major equipment

Major maintenance items in 2016 included:

- Rebuilt raw sludge pump #4.
- Rewired travelling bridge #6.
- Rebuilt raw lift pump #1.
- Installed new Variable Frequency Drive (VFD) on Return Activated Sludge (RAS) pump #1.
- Rebuilt RAS pump #1.
- Installed new scum pump in building I.
- Installed new screenings packer auger.
- Rebuilt RAS pump #5 in building I.
- Conducted electrical substation maintenance.
- Installed secondary travelling bridge drives on #5 and #6.

d) Summary of any effluent quality assurance or control measures

- In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. Results were found to be in a comparable range.
- On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.

e) Summary of the calibration and maintenance carried out

- Calibration of the raw influent flow meters was conducted in April and September 2016.
- Calibration of the AutoCat 9000 chlorine analyzer was conducted on July 28th 2016.
- Calibration of the in-house lab pH meter was conducted regularly.



f) Effluent Objectives

The Regional Municipality of Durham strives to achieve the best effluent quality at all times, remaining below the ECA compliance limits.

The annual average daily flow did not exceed the rated capacity of 84,350 m³/d.

The total suspended solids objective of 15.0 mg/L was exceeded in 37 of 397 samples (9%). These exceedances were investigated and no direct cause could be found. The plant was operating properly and the exceeding samples were sporadic through the year.

Total phosphorus objective of 0.8 mg/L was exceeded in 42 of 301 samples (14%). This was due primarily to chemical feed pump issues. Chemical dosing was increased accordingly for all events.

The total chlorine residual objective of “non-detect” was exceeded in 64 of 340 samples (19%). The ECA requests an objective concentration of “non-detect”, however the instrumentation used has a detection limit of 0.0012 mg/L so it is typical to have results detected. Sodium bisulphite dosing is monitored to ensure low total chlorine residuals..

The pH objective of not less than 6.5 was exceeded 3 of 310 samples (1%). The pH meter was calibrated regularly.

The E.coli objective of 150cfu/100ml was exceeded in 1 of 12 (8%) monthly geometric mean averages which coincided with the limit exceedance reported for December.

Best efforts and process adjustments will continue to be applied to maintain results below objectives.

g) Biosolids Production:

Tabulation of Volume of Sludge Generated:

The volume of sludge removed from Corbett Creek WPCP in 2016 was 81,236 m³.

Outline of Anticipated Volumes to be Generated in the next Reporting Period:

There is no increase of sludge volume expected in the next reporting period.

Summary of Locations to Where Sludge was Disposed:

Duffin Creek WPCP – 40,790 m³ or 50.2%

Agricultural Fields – 40,446 m³ or 49.8%

h) Summary of Complaints and Steps Taken to Address the Complaint:

One odour complaint was received in August from a local resident. The concern was investigated and could not be confirmed as an odour from the treatment plant. The MOECC was notified of the incident.

i) By-passes and Spills

No by-passes occurred at the plant in 2016.

j) Notice of Modifications submitted to Water Supervisor and Status Report of Limited Operational Flexibility



No modifications under “Limited Operational Flexibility” were conducted.

k) Modifications Arising under section 3 of Schedule A

No modifications under section 3 of Schedule A were conducted.

l) Information Required by MOECC Water Supervisor

No additional information was requested.

MOECC Inspection

No MOECC inspection occurred in 2016.



Corbett Creek Water Pollution Control Plant
Annual Performance Report 2016

Table 1 Raw Influent Flows

Month	Total Flow to Plant -metered at the final effluent m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d
January	1,669,898	53,868	94,674
February	1,521,684	52,472	66,350
March	1,708,183	55,103	67,953
April	1,796,377	59,879	89,784
May	1,447,975	46,709	54,459
June	1,312,223	43,741	47,605
July	1,316,728	42,475	52,410
August	1,340,882	43,254	53,538
September	1,259,437	41,981	46,580
October	1,304,521	42,081	46,957
November	1,251,234	41,708	48,767
December	1,367,260	44,105	57,641
Total	17,296,402		
Average	1,441,367	47,258*	
Maximum	1,796,377		94,674
ECA Limit		84,350	
Met Compliance		Yes	

*Annual Average Daily Flow



Corbett Creek Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d
January	62	3,314	82	4,390	113	6,062	3.7	197
February	66	3,442	79	4,161	112	5,887	3.2	167
March	79	4,352	115	6,354	114	6,277	3.1	173
April	49	2,298	83	3,890	141	6,591	2.8	131
May	115	5,352	128	5,988	171	7,974	3.9	180
June	132	5,791	159	6,935	193	8,463	4.0	177
July	121	5,128	150	6,371	187	7,960	4.1	176
August	111	4,799	140	6,056	158	6,834	4.3	185
September	129	5,416	144	6,035	175	7,360	4.0	169
October	88	3,689	127	5,324	106	4,444	4.1	172
November	97	4,054	128	5,355	146	6,075	3.9	162
December	98	4,326	141	6,211	102	4,497	4.8	212
Average	95	4,513	123	5,811	143	6,765	3.8	181
Minimum	49	2,298	79	3,890	102	4,444	2.8	131
Maximum	132	5,791	159	6,935	193	8,463	4.8	212
Sampling Frequency Requirement Met			Yes		Yes		Yes	



Corbett Creek Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses continued

Month	DP avg. conc. mg/L	TKN avg. conc. mg/L	TAN avg. conc. mg/L	TAN loading kg/d	pH min.	pH max.
January	1.94	31.05	26	1,374	6.63	7.80
February	1.81	32.48	18	962	7.20	7.75
March	1.85	41.62	22	1,209	7.30	8.43
April	1.53	27.10	15	685	6.60	7.85
May	1.83	33.95	23	1,054	6.70	7.89
June	1.88	39.22	24	1,068	7.67	7.96
July	1.79	35.53	23	966	7.27	7.91
August	2.12	41.36	25	1,103	7.41	8.02
September	1.82	36.40	25	1,055	7.56	7.90
October	2.09	34.48	24	990	7.60	8.06
November	2.06	35.36	28	1,184	7.60	7.98
December	2.26	39.28	38	1,672	7.56	8.20
Average	1.91	35.65	24	1,144		
Minimum	1.53	27.10	15	685	6.60	
Maximum	2.26	41.62	38	1,672		8.43
Sampling Frequency Requirement Met		Yes				



Corbett Creek Water Pollution Control Plant
Annual Performance Report 2016

Table 3 Final Effluent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d	TAN avg. conc. mg/L summer	TAN avg. conc. mg/L winter	TAN loading kg/d
January	2.8	151	6.7	359	0.61	32.8	2.16	--	116.2
February	3.0	160	6.6	344	0.55	28.9	0.55	--	28.6
March	3.2	179	7.4	408	0.37	20.1	0.54	--	29.6
April	5.0	234	12.5	584	0.50	23.5	1.79	--	83.5
May	3.4	158	7.8	363	0.48	22.3	--	0.38	17.6
June	3.3	144	11.1	486	0.47	20.6	--	0.74	32.3
July	2.9	124	8.8	374	0.40	16.9	--	0.46	19.7
August	2.8	121	9.8	425	0.71	30.8	--	0.53	22.9
September	2.7	113	8.9	372	0.76	32.0	--	0.41	17.1
October	2.6	110	6.8	287	0.57	23.8	--	0.61	25.9
November	3.0	127	7.5	314	0.65	27.0	0.91	--	37.8
December	3.0	133	10.7	474	0.74	32.8	0.22	--	9.9
Average	3.2	149	8.7	412	0.57	26.8	1.03	0.52	36.8
Minimum	2.6	110	6.6	287	0.37	16.9	0.22	0.38	9.9
Maximum	5.0	234	12.5	584	0.76	32.8	2.16	0.74	116.2
ECA Requirement	25	2108	25	2108	1.0	84	16	24	1350 (summer) /2024 (winter)
ECA Objective	15		15		0.8		8	18	
Within Compliance	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Sampling Frequency Requirement Met	Yes		Yes		Yes		Yes	Yes	



Table 3 Final Effluent Analyses continued

Month	Unionized NH3 avg. conc. mg/L	TKN avg. conc. mg/L	DP avg. conc. mg/L	TCR avg. conc. mg/L	TCR loading kg/d	pH min.	pH max.	Temp. °C min.	Temp. °C max.
January	0.0	3.42	0.31	0.01	0.3	7.25	7.80	13.0	15.5
February	0.0	2.05	0.24	0.00	0.0	7.20	7.80	11.2	14.7
March	0.0	2.47	0.16	0.00	0.0	6.89	7.83	12.0	14.5
April	0.0	3.96	0.29	0.01	0.3	6.30	7.30	11.9	15.2
May	0.0	1.99	0.28	0.00	0.0	6.34	7.80	12.0	17.8
June	0.0	3.29	0.21	0.01	0.5	6.95	7.50	17.9	20.4
July	0.0	1.86	0.17	0.00	0.1	6.89	7.57	12.0	22.0
August	0.0	2.93	0.39	0.01	0.3	7.21	7.80	22.0	23.0
September	0.0	2.06	0.55	0.00	0.0	6.96	7.50	21.6	24.5
October	0.0	2.08	0.37	0.00	0.0	7.10	7.60	12.0	23.0
November	0.0	2.46	0.46	0.00	0.0	7.00	7.75	16.7	20.0
December	0.0	1.90	0.41	0.00	0.1	7.17	7.55	15.0	18.0
Average	0.0	2.54	0.32	0.00	0.1				
Minimum	0.0	1.86	0.16	0.00	0.0	6.30		11.2	
Maximum	0.0	3.96	0.55	0.01	0.5		7.83		24.5
ECA Requirement				0.02		6.0	9.0		
ECA Objective				Non-detect		6.5	8.5		
Within Compliance				Yes		Yes	Yes		
Sampling Frequency Requirement Met	Yes			Yes		Yes	Yes	Yes	Yes



Table 4 Escherichia Coliform Sampling

Month	Number of Samples	Geometric Mean Density
January	4	14
February	4	32
March	5	20
April	4	26
May	4	17
June	4	36
July	4	44
August	5	45
September	4	37
October	4	59
November	5	130
December	6	205
ECA Requirement		200
ECA Objective		150
Within Compliance		No
Sampling Frequency Requirement Met	Yes	



Table 6 Energy and Chemical Usage

Month	Total Plant Flow (cubic metres)	Ferrous Chloride (litres)	Sodium Hypochlorite (kilograms as chlorine)	Sodium Bisulphite (Litres)	Hydro (kWh)	Natural Gas (cubic metres)
January	1,669,898	183,950	7,513	17,579	739,078	59,244
February	1,521,684	152,640	7,067	14,921	736,197	46,579
March	1,708,183	176,490	9,387	16,440	770,147	43,305
April	1,796,377	154,740	10,167	19,856	732,518	49,336
May	1,447,975	177,060	8,181	19,625	758,339	32,662
June	1,312,223	175,020	8,465	23,058	703,560	24,536
July	1,316,728	169,360	8,804	28,154	710,566	24,473
August	1,340,882	157,470	9,433	34,723	722,277	20,323
September	1,259,437	166,060	7,482	9,917	715,567	20,333
October	1,304,521	170,680	5,827	8,412	713,438	29,845
November	1,251,234	141,000	6,187	7,582	711,819	33,230
December	1,367,260	163,710	9,238	9,854	757,639	41,190
Total	17,296,402	1,988,180	97,751	210,121	8,771,145	425,056



Glossary of Terms

Aeration Tank

A vessel in which a biological process is carried out which involves bacterial organisms or biochemically active substances derived from such organisms. This encompasses a combination of aerobic, and anoxic processes.

Anaerobic Digestion

Is a series of biological processes in which microorganisms break down biodegradable material in the absence of oxygen.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

Biosolids

Organic material recovered from wastewater sludge.

BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

A diversion of sewage around one or more unit processes within the Sewage Treatment Plant with the diverted sewage flows being returned to the Sewage Treatment Plant treatment train upstream of the Final effluent sampling location, and discharging to the environment through the Sewage Treatment Plant outfall.

CBOD₅ -Five day Carbonaceous Biochemical Oxygen Demand

A five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample.

conc. – Concentration

A measure of the amount of dissolved substance contained per unit of volume.

DP – Dissolved Phosphorus

This is the soluble form of phosphorus present in the wastewater.

ECA - Environmental Compliance Approval

The primary regulatory instrument for each WPCP.

E. coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius.

Final Effluent

Sewage discharge via the WPCP outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.

Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.



Grab Sample

A single sample taken at a specific moment in time, a snapshot of the conditions at the time the sample was retrieved.

m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metres Per Day)

Flow measurement, 1m³ = 1000 litres or 220 imperial gallons. Volume of liquid treated in a day.

Max. – Maximum

The peak or highest value recorded during a specific time period usually in a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.

mg/L - (Milligram Per Litre)

This is a measure of the concentration of a parameter in water or wastewater, sometimes referred to as parts per million (ppm).

Min. – Minimum

The lowest value recorded during a specific time period usually in a day.

mm - (millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.

MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly Average Concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.

Monthly Average Loading

Calculated by multiplying the monthly average concentration of a contaminant in the effluent sampled or measured, or both, during a calendar month.

N/A - Not Applicable

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.

Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Septage

Partially treated sludge from a septic tank.

Sludge

The settleable solids separated from liquids during processing.



TAN -Total Ammonia Nitrogen

Ammonia exists in two forms in the water: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

TCR -Total Chlorine Residual

The total amount of chlorine in water, including the combined chlorine and the free available chlorine.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.

TP -Total Phosphorus

A laboratory analyses to determine the total amount of particulate and soluble phosphorus present in the wastewater.

TSS -Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS -Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Unionized Ammonia Nitrogen

Un-ionized ammonia refers to all forms of ammonia in water with the exception of the ammonium ion (NH_4^+).

WPCP - Water Pollution Control Plant

Is typically a facility composed of a variety of treatment processes that collectively treat the wastewater.



**Courtice Water Pollution Control Plant
Annual Performance Report 2016**

**Courtice Water Pollution Control Plant
Annual Performance Report 2016**





The Regional Municipality of Durham

Courtice Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 3393-68RLD4 Dated January 28, 2005

Environmental Compliance Approval (Air): 7446-6AGNQZ Dated April 30, 2005

The Courtice Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers a performance overview of the Courtice WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

Water Pollution Control Plant Process Description

General

The Courtice WPCP is located in the Municipality of Clarington (Courtice) and is owned and operated by the Regional Municipality of Durham. The plant is operated according to the terms and conditions of the ECA.

The Courtice WPCP treats wastewater from the Oshawa and Courtice service areas in the Regional Municipality of Durham. The Courtice WPCP receives the majority of its flow from the Harmony Creek catchment area via the Harmony Creek Sanitary Sewage Pumping Station (SSPS), servicing approximately 122,133 residents or 70% of the total catchment population.

The Courtice WPCP is designed to treat wastewater at an average daily flow rate of 68,200 cubic metres per day (m^3/d) with a peak flow rate of 180,000 m^3/d . The plant is an MOECC Class Four conventional activated sludge treatment plant that utilizes the following processes to treat wastewater:

- raw influent pumping,
- preliminary treatment,
- primary treatment,
- secondary treatment,
- phosphorus removal,
- disinfection (chlorination/dechlorination),
- solids treatment.

Raw Influent Pumping

Wastewater collected through approximately 656 km of sanitary sewers in Oshawa and Courtice is conveyed to the Harmony Creek SSPS located at the Harmony Creek WPCP. Approximately 70% of the Harmony Creek WPCP influent flow is diverted to the Harmony Creek SSPS and conveyed 6.4 km in a 1050 mm diameter force main to the Courtice WPCP.



In addition, an existing small service area in Courtice is serviced by the Courtice WPCP which includes the Durham/York Energy center, OPG office building and the OPG Darlington Generating Station.

Preliminary Treatment

Screening: Two automatic, mechanically cleaned screens remove paper products and large material that could harm pumps and process equipment. Screenings removed in the process are compacted for landfill disposal.

Grit Removal: Heavy suspended material such as sand and small stones (grit) is removed in the two aerated grit tanks. The velocity of the wastewater rolling in the tanks is controlled by the quantity of air added to produce conditions that allow heavy grit material to settle, while keeping the lighter organic material in suspension to proceed to the next process tank. The grit removed in the process is dewatered and transported to landfill.

Primary Treatment

The two primary clarifiers utilize the physical process of sedimentation which allows the suspended material to settle to the bottom of the tank as sludge. This raw sludge, along with excess activated sludge from the secondary treatment process is collected by a flight and chain mechanism which pushes the sludge into hoppers. The sludge is then pumped to the anaerobic digesters for further treatment. Any material floating on the surface of the clarifier (scum) is also removed to the digester.

Secondary Treatment

Aerated Bioreactor: The bioreactors are comprised of two distinct sections. The first section is an anoxic zone, where no oxygen is introduced and allows for potential denitrification. Subsequently, the flow leaves the anoxic zone and enters the aerated zone where fine bubbled air is diffused into the sewage to assist bacteria in removing dissolved and suspended organics, and nutrients from the wastewater. Biological activity is controlled to assimilate the organic material.

Secondary Clarifier: The effluent from the bioreactors is directed to the two secondary clarifiers where the solids settle quickly to the bottom as activated sludge leaving clear supernatant. A portion of the activated sludge collected on the bottom of the clarifier is pumped back to the head of the bioreactors and the excess activated sludge is wasted to the primary clarifiers.

Phosphorus Removal

The phosphorous removal system is intended to lower the total phosphorous level in the final effluent by adding a chemical coagulant (ferrous chloride). Ferrous chloride can be added at multiple locations within the plant.

Disinfection: Chlorine in the form of liquid sodium hypochlorite is metered into the secondary effluent stream for pathogen control. Adequate contact time is provided by the two chlorine contact chambers. Disinfected effluent is dechlorinated with a sodium bisulphite solution before being discharged through the 1,676 mm diameter outfall extending 770 meters into Lake Ontario.

Solids Treatment

Anaerobic Digestion: The raw sludge that is collected from the primary clarifiers is pumped into the anaerobic digesters where anaerobic bacteria reduce the volume of sludge. As a result of digestion



the plant produces a more stabilized sludge, water, carbon dioxide, methane, and hydrogen sulphide. The water is returned to the head of the plant for further treatment and the methane is used to meet the heating requirements of the digesters and for heating areas of the treatment facility.

Biosolids management: All digested sludge produced at the Courtice WPCP is pumped to the biosolids holding facility. From there the treated biosolids can be utilized on approved agricultural fields or be shipped to Duffin Creek WPCP for incineration. Biosolids are transported plant to plant in accordance with ECA #A820250 and ECA #4400-4LBLXD for land application.

Environmental Compliance Approval

Under Condition 10 (6) of ECA #3393-68RLD4 the Region of Durham must produce an annual report that must contain the following information:

a) Summary and interpretation of all monitoring data and a comparison to the effluent limits, including an overview of the success and adequacy of the works.

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA. Table 2 summarizes the raw wastewater characteristics during the reporting period.

The Courtice WPCP effluent was determined to be compliant with the ECA approval limits during the reporting period. The plant operated at 69% of its annual average rated flow capacity and received a maximum daily flow of 91,226 m³/d on January 11, 2016.

b) Description of any operating problems encountered and corrective actions taken:

There were no operating issues encountered in 2016.

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the works.

Major maintenance items in 2016 included:

- Insulated all flight and chain gear boxes.
- Repaired waste gas burner stack, motor, and replaced thermocouple.
- Repaired motor on bioreactor blower #4.
- Replaced drive motor on north primary cross collector.
- Conducted maintenance on north secondary clarifier cross collector.
- Replaced liners on grit conveyor.
- Repaired cross collector on north primary clarifier.
- Emptied and cleaned the south chlorine contact chamber.
- Repaired mixer on secondary digester.

d) Summary of any effluent quality assurance or control measures undertaken in the reporting period.

- In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. All results were found to be within a comparable range.
- On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.



e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment.

- Calibration of the effluent flow meter and the secondary clarifier flow meters was conducted in June and September 2016.
- Calibration of the AutoCat 9000 chlorine analyzer was conducted July 28, 2016.
- Calibration of the in-house lab pH meter was conducted monthly.

f) Description of efforts made and results achieved in meeting the effluent objectives.

The Regional Municipality of Durham continually strives to achieve the best effluent quality at all times, remaining below the ECA compliance limits.

The average daily rated flow capacity of 68,200 m³/d was not exceeded. The rated peak flow capacity of 180,000 m³/d was not exceeded.

The total phosphorus objective of 0.8 mg/L was exceeded in 32 of 259 samples (12%). This was due primarily to insufficient ferrous chloride dosing. Ferrous chloride feed was increased as required.

One of 12 (8%) E.coli samples exceeded the objective of 200 cfu/100 ml. This occurred due to one elevated sample. Chlorine dosage was increased to maintain a higher chlorine residual.

Best efforts and process adjustments will continue to be applied to maintain results below objectives.

g) Tabulation of Volume of Sludge Generated:

The volume of sludge removed from Courtice WPCP in 2016 was 62,660m³.

Outline of Anticipated Volumes to be Generated in the Next Reporting Period:

There is no increase of sludge volume expected in the next reporting period.

Summary of Locations to Where Sludge was Disposed:

Duffin Creek WPCP – 28,032 m³ or 44.7%

Agricultural Fields – 34,628 m³ or 55.3%

h) Summary of any complaints received during the reporting period and any steps taken to address the complaint:

No odour complaints were made regarding the treatment plant in 2016.

i) Summary of all By-pass, spill or abnormal discharge events.

There were no by-passes during the reporting period. There are no anticipated by-passes planned during the next reporting period.

There were no spills during the reporting period.

j) Any other information the District Manager requires from time to time.

No additional information was requested.

MOECC Inspection

No MOECC inspection occurred in 2016.



Courtice Water Pollution Control Plant
Annual Performance Report 2016

Table 1 Raw Influent Flow

Month	Total Flow to Plant - metered at the final effluent m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d
January	1,561,224	50,362	91,226
February	1,187,644	40,953	49,239
March	1,496,586	48,277	56,946
April	1,563,399	52,113	87,303
May	1,090,575	35,180	43,372
June	869,316	28,977	35,148
July	794,194	25,619	32,079
August	877,933	28,320	39,578
September	1,005,438	33,515	38,255
October	1,008,537	32,533	36,934
November	1,058,254	35,275	38,478
December	1,227,865	39,609	55,355
Total	13,740,964		
Average	1,145,080	37,544*	
Minimum	794,194		
Maximum	1,563,399		91,226
ECA Requirement		68,200	180,000
Met Compliance		Yes	Yes

*Annual Average Daily Flow



Courtice Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ avg. loading kg/d	BOD ₅ avg. conc. mg/L	BOD ₅ avg. loading kg/d	TSS avg. conc. mg/L	TSS avg. loading kg/d	TP avg. conc. mg/L	TP avg. loading kg/d
January	138	6,925	225	11,331	242	12,174	4.0	201
February	116	4,740	207	8,467	260	10,640	4.1	169
March	91	4,413	146	7,056	235	11,359	3.7	177
April	70	3,657	103	5,375	209	10,916	3.2	165
May	171	6,025	290	10,185	320	11,242	5.0	176
June	150	4,347	239	6,937	314	9,091	6.3	182
July	167	4,285	276	7,071	415	10,640	7.1	181
August	183	5,190	292	8,277	395	11,193	7.4	210
September	268	8,989	388	12,990	518	17,346	8.3	277
October	244	7,922	327	10,630	571	18,577	5.7	185
November	240	8,466	319	11,235	497	17,516	7.1	251
December	209	8,286	320	12,675	752	29,797	7.0	278
Average	171	6,406	261	9,796	394	14,791	5.7	215
Minimum	70	3,657	103	5,375	209	9,091	3.2	165
Maximum	268	8,989	388	12,990	752	29,797	8.3	278
Sampling Frequency Requirement Met			Yes		Yes		Yes	



Courtice Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses continued

Month	DP avg. conc. mg/L	TKN avg. conc. mg/L	TAN avg. conc. mg/L	TAN avg. loading kg/d	pH min.	pH max.	Temp. min.	Temp. max.	Alkalinity avg. conc. mg/L
January	2.25	40.78	24.37	1,227	6.93	7.88	9.7	17.8	308
February	2.27	38.98	26.71	1,094	6.32	8.01	3.2	18.2	267
March	2.06	36.28	25.27	1,220	7.07	8.07	7.9	17.2	307
April	1.68	30.33	21.32	1,111	7.42	7.98	7.3	20.0	285
May	2.71	48.50	29.13	1,025	7.05	7.95	14.4	20.9	274
June	3.23	46.90	32.01	927	6.47	8.19	17.5	25.1	296
July	3.46	56.60	32.67	837	7.18	7.91	13.2	23.0	281
August	3.51	48.33	33.06	936	6.00	7.81	13.8	24.4	273
September	3.73	59.36	34.03	1,140	6.88	7.90	11.6	24.8	310
October	2.93	51.78	33.42	1,087	6.79	7.80	12.0	22.7	255
November	3.56	52.95	36.43	1,285	6.99	7.90	14.4	21.2	306
December	2.77	47.34	32.83	1,300	6.48	8.23	12.2	17.7	292
Average	2.85	46.51	30.10	1,130					288
Minimum	1.68	30.33	21.32	837	6.00		3.2		255
Maximum	3.73	59.36	36.43	1,300		8.23		25.1	310
Sampling Frequency Requirement Met	Yes	Yes	Yes		Yes	Yes	Yes	Yes	Yes



Table 3 Final Effluent Analyses

Summary of the final effluent sample analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ avg. loading kg/d	TSS avg. conc. mg/L	TSS avg. loading kg/d	TP avg. conc. mg/L	TP avg. loading kg/d	TAN avg. conc. mg/L winter	TAN avg. conc. mg/L summer	TAN avg. loading kg/d
January	2.2	111	3.3	164	0.60	30.3	0.16	--	8.0
February	2.0	81	2.8	117	0.52	21.2	0.18	--	7.5
March	2.1	101	2.9	139	0.60	28.9	0.35	--	16.9
April	1.5	77	4.4	230	0.63	32.6	0.16	--	8.1
May	2.0	69	2.4	83	0.58	20.4	--	0.16	5.8
June	1.5	45	3.7	107	0.59	17.1	--	0.45	13.0
July	2.0	52	3.8	96	0.68	17.4	--	0.17	4.4
August	2.0	57	4.4	124	0.61	17.4	--	0.16	4.4
September	1.5	50	2.3	76	0.59	19.9	--	0.21	7.2
October	1.7	54	3.4	111	0.59	19.1	--	1.13	36.6
November	1.8	64	3.9	138	0.64	22.5	0.09	--	3.2
December	1.9	75	3.8	151	0.74	29.3	0.06	--	2.4
Average	1.8	69	3.4	128	0.61	23.0	0.17	0.38	9.8
Minimum	1.5	45	2.3	76	0.52	17.1	0.06	0.16	2.4
Maximum	2.2	111	4.4	230	0.74	32.6	0.35	1.13	36.6
ECA Requirement	25		25		1.0		24	15	
ECA Objective	15		15		0.8		12	8	
Within Compliance	Yes		Yes		Yes		Yes	Yes	
Sampling Frequency Requirement Met	Yes		Yes		Yes		Yes	Yes	



**Courtice Water Pollution Control Plant
Annual Performance Report 2016**

Table 3 Final Effluent Analyses continued

Month	Unionized NH3 avg. conc. mg/L	TKN avg. conc. mg/L	DP avg. conc. mg/L	Nitrate avg. conc. mg/L	Alkalinity avg. conc. mg/L
January	0.0	1.31	0.59	21.53	113
February	0.0	1.53	0.43	20.40	91
March	0.0	1.49	0.54	19.58	109
April	0.0	1.24	0.53	21.41	159
May	0.0	1.47	0.53	20.35	80
June	0.0	1.66	0.55	23.07	48
July	0.0	1.56	0.63	23.84	51
August	0.0	1.47	0.56	22.60	34
September	0.0	1.39	0.61	22.46	59
October	0.0	1.96	0.78	23.56	43
November	0.0	1.64	0.71	24.90	44
December	0.0	1.36	0.74	22.80	40
Average	0.0	1.51	0.60	22.21	73
Minimum	0.0	1.24	0.43	19.58	34
Maximum	0.0	1.96	0.78	24.90	159
ECA Requirement	0.2				
ECA Objective	0.1				
Within Compliance	Yes				
Sampling Frequency Requirement Met	Yes		Yes	Yes	Yes



Table 3 Final Effluent Analyses continued

Month	TCR avg. conc. mg/L	TCR avg. loading kg/d	pH min.	pH max.	Temp. °C min.	Temp. °C max.
January	0.00	0.1	7.04	7.46	13.7	15.9
February	0.00	0.1	7.05	7.95	7.7	15.9
March	0.00	0.1	7.14	7.51	12.0	15.2
April	0.00	0.1	6.96	7.55	11.7	15.6
May	0.00	0.0	7.12	7.49	15.0	19.0
June	0.00	0.1	6.74	7.44	17.6	20.3
July	0.00	0.0	7.03	7.59	19.6	22.1
August	0.00	0.1	6.88	7.52	21.2	23.8
September	0.00	0.1	6.64	7.62	21.1	23.6
October	0.00	0.0	6.78	7.52	17.4	22.7
November	0.00	0.1	6.81	7.61	16.2	19.1
December	0.00	0.1	6.91	7.30	13.2	17.8
Average	0.00	0.1				
Minimum	0.00	0.0	6.64		7.7	
Maximum	0.00	0.1		7.95		23.8
ECA Requirement			6.0	9.5		
ECA Objective			6.5	9.0		
Within Compliance			Yes	Yes		
Sampling Frequency Requirement Met	Yes		Yes	Yes	Yes	Yes



Table 4 Escherichia Coliform Sampling

Month	Number of Samples	Geometric Mean Density
January	4	27
February	4	6
March	5	110
April	4	61
May	4	4
June	6	43
July	5	114
August	4	62
September	5	9
October	4	7
November	4	295
December	5	74
ECA Requirement		N/A
ECA Objective		200
Within Compliance		Yes
Sampling Frequency Requirement Met	Yes	



Table 5 Energy and Chemical Usage

Month	Total Plant Flow (cubic metres)	Ferrous Chloride (litres)	Sodium Hypochlorite (kilograms as chlorine)	Sodium Bisulphite (Litres)	Hydro (kWh)	Natural Gas (cubic metres)
January	1,561,224	99,260	4,072	8,685	632,506	10,972
February	1,187,644	112,840	3,763	7,139	616,564	16,469
March	1,496,586	87,920	4,851	7,765	716,992	2,629
April	1,563,399	102,200	5,072	8,685	636,386	1,264
May	1,090,575	85,540	3,793	6,624	663,940	2,124
June	869,316	103,740	2,940	5,152	708,114	1,093
July	794,194	76,720	3,352	5,336	584,529	1,238
August	877,933	91,700	3,263	6,330	589,529	910
September	1,005,438	106,680	2,749	6,403	616,919	2,413
October	1,008,537	108,780	2,778	6,661	712,586	1,823
November	1,058,254	93,380	2,822	6,771	702,726	1,799
December	1,227,865	84,980	3,690	8,170	776,652	5,928
Total	13,740,964	1,153,740	43,145	83,720	7,957,443	48,662

Glossary of Terms

Anaerobic Digestion

A series of biological processes in which microorganisms break down biodegradable material in the absence of oxygen.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

Biosolids

Organic material recovered from wastewater sludge.

Bioreactor

A bioreactor is a vessel in which a biological process is carried out which involves bacterial organisms or biochemically active substances derived from such organisms. This encompasses a combination of aerobic, and anoxic processes.



BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) Five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

Any discharge from the Works that does not undergo any treatment or only undergoes partial treatment before it is discharged to the environment.

CBOD₅ -Five day Carbonaceous Biochemical Oxygen Demand

A five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample.

conc. – Concentration

A measure of the amount of dissolved substance contained per unit of volume.

District Manager

The District Manager of the York-Durham District Office of the Ministry.

DP – Dissolved Phosphorus

The soluble form of phosphorus present in the wastewater.

Denitrification -

The biological process of nitrate reduction to nitrogen gases occurring in low dissolved oxygen environments.

ECA - Environmental Compliance Approval

The primary regulatory instrument for each WPCP.

E. coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius.

Final Effluent

Sewage discharge via the Sewage Treatment Plant outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.

Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, a snapshot of the conditions at the time the sample was retrieved.



m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metres Per Day)

Flow measurement, 1m³ = 1000 litres or 220 imperial gallons. Volume of liquid treated in a day.

Max. – Maximum

The peak or highest value recorded during a specific time period usually a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.

mg/L - (Milligram Per Litre)

This is a measure of the concentration of a parameter in wastewater, sometimes referred to as parts per million (ppm).

Min. – Minimum

The lowest value recorded during a specific time period usually in a day.

mm - (millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.

MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly average concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.

Monthly average loading

is calculated by multiplying the monthly average concentration of a contaminant in the effluent sampled or measured, or both, during a calendar month.

N/A - Not Applicable

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.

Rated Capacity

The average daily flow for which the works are approved to handle.



Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Septage

Partially treated sludge from a septic tank.

Sludge

The settleable solids separated from liquids during processing.

Substantial completion – has the same meaning as “substantial performance” in the Construction Lien Act.

TAN -Total Ammonia Nitrogen

Ammonia exists in two forms in the water: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

TCR -Total Chlorine Residual

The total amount of chlorine in water, including the combined chlorine and the free available chlorine.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.

TP -Total Phosphorus

A laboratory analyses to determine the total amount of particulate and soluble phosphorus present in the wastewater.

TSS -Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS -Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Unionized Ammonia Nitrogen

Un-ionized ammonia refers to all forms of ammonia in water with the exception of the ammonium ion (NH_4^+).

Works

The sewage works described in the owner’s application, and the ECA, and includes both proposed works and previous works.



WPCP - Water Pollution Control Plant

Is typically a facility composed of a variety of treatment processes that collectively treat the wastewater.

If this information is required in an accessible format, please contact 1-800-372-1102 extension 3488



Duffin Creek Water Pollution Control Plant Annual Performance Report 2016





Duffin Creek Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 5531-9FJJT5

Dated March 3, 2014

Environmental Compliance Approval (Air): 1110-9AJP5C

Dated September 13, 2013

International Organization for Standardization (ISO) 14001 Certification: CA05/3563/E

The Duffin Creek Water Pollution Control Plant (WPCP) Annual Performance Report provides staff, stakeholders and customers an overview of the performance of the Duffin Creek WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

Water Pollution Control Plant Process Description

General

The Duffin Creek WPCP is jointly owned by the Regional Municipality of Durham and the Regional Municipality of York and operated in accordance with the terms and conditions of the ECA noted above. The Regional Municipality of Durham is responsible for all plant operations at the Duffin Creek WPCP. The plant is located in the City of Pickering, and operated by the Regional Municipality of Durham. This MOECC Class Four conventional activated sludge treatment plant is designed to treat wastewater at an average daily flow rate of 630,000 cubic metres per day (m³/d) with a limit of 520,000 m³/d as noted in the outfall capacity limitations in the ECA. Duffin Creek WPCP is ISO 14001 certified.

Duffin Creek WPCP treats wastewater from the Town of Ajax and the City of Pickering service areas in the Regional Municipality of Durham as well as the following service areas in the Regional Municipality of York: Vaughan, King, Newmarket, Whitchurch-Stouffville, Aurora, East Gwillimbury, Richmond Hill, and Markham.

The Duffin Creek WPCP utilizes the following processes to treat wastewater:

- raw influent pumping,
- preliminary treatment,
- primary treatment,
- phosphorous removal,
- secondary treatment,
- disinfection (chlorination/dechlorination)
- solids treatment,
- incineration.

Raw Influent Pumping

Wastewater collected through approximately 654 km of sanitary sewers in Ajax and Pickering is conveyed to the treatment plant by gravity and by the following sanitary sewage pumping stations located in the collection system: Bayly St., Jodrel Rd., Toy Ave., Finch Av. and Liverpool Rd. Wastewater collected from the Regional Municipality of York is conveyed to the WPCP via the Primary Trunk Sewer and South East Collector which are part of the York Durham Sewage System



(YDSS). This accounted for an estimated 81.9% of the wastewater treated in 2016. The remaining 18.1% (estimated) was generated by the Town of Ajax and the City of Pickering. The combined flows enter a diversion chamber which then splits the flow between Stages 1 & 2 and Stage 3 at the Duffin Creek WPCP.

Stages 1 & 2:

Preliminary Treatment

Screening: Twelve automatic, mechanically cleaned bar screens remove paper products and large material that could harm pumps and process equipment. The bar screens discharge the screenings onto a series of conveyers which in turn discharge into bins for landfill disposal.

Grit Removal: The eight grit tanks are sized such that the flow-through velocity will allow the grit material such as sand and small stones to settle to the bottom of the tanks. The grit collecting mechanism, which has rotating arms with blades, scrapes the grit into a collection pit where a rake deposits the grit onto a series of conveyers and into bins for landfill disposal.

Primary Treatment

Eight primary clarifiers each equipped with a travelling bridge system utilize the physical process of sedimentation which causes heavy particles to settle to the bottom of the tank as raw sludge and lighter particles to float to the surface as scum. The sludge, along with return activated sludge from the secondary treatment process is collected by scraper blades which push the sludge into hoppers. The sludge is then pumped to the digester tanks or to the dewatering building. The scum is collected by the travelling bridge and sent to the digesters.

Phosphorous Removal

The phosphorous removal system is intended to lower the total phosphorous level in the final effluent by adding chemicals (ferrous chloride) as part of the treatment process. It also improves the settling of solids which reduces the total solids concentration in the final effluent. Ferrous chloride can be added at multiple locations throughout the WPCP.

Secondary Treatment

Aerated Bioreactor: Effluent from the primary clarifiers is treated with ferrous chloride in order to aid in phosphorus removal. There are eight aerated bioreactors each containing anoxic and aerobic zones. In the first part of the tank no oxygen is introduced (anoxic), this is for denitrification. The second part of the tank is where fine bubbled air is diffused into the sewage (aerobic) to remove dissolved and suspended organics and nutrients from the wastewater. Biological activity is controlled to assimilate the organic material.

Secondary Clarifier: The effluent from the aerated bioreactor is directed to its associated secondary clarifier where solids settle quickly as activated sludge leaving a clear effluent. A portion of the activated sludge collected on the bottom of the clarifier is pumped back to the head of the bioreactor and any excess activated sludge is pumped to the primary clarifier to co-settle.

Disinfection (chlorination/dechlorination)

Chlorine in the form of liquid sodium hypochlorite is metered into the effluent stream for pathogen control. Adequate contact time is provided by the chlorine contact chambers. Disinfected effluent is



dechlorinated with a sodium bisulphite solution before being discharged to Lake Ontario through a 3.05 m diameter outfall pipe, approximately 1,100 m long with a 183 m long diffuser pipe.

Stage 3:

Preliminary Treatment

Screening: Six automatic, mechanically cleaned screens remove paper products and large material that could harm pumps and process equipment. Screenings are compacted for disposal to landfill.

Grit Removal: There are four grit tanks equipped with coarse bubble diffusers to provide aeration in the grit removal process. Heavy suspended material such as sand and small stones (grit) is settled to the bottom of the tanks while lighter organic particles are kept in suspension and passed through the tanks for further treatment. The grit removed is dewatered for landfill disposal.

Primary Treatment

Six primary clarifiers each equipped with a travelling bridge system utilize the physical process of sedimentation which causes heavy particles to settle to the bottom of the tank as raw sludge and lighter particles to float to the surface as scum. The sludge, along with return activated sludge from the secondary treatment process is collected by scraper blades which push the sludge into hoppers. The sludge is then pumped to the digester tanks or to the dewatering building. The scum is collected by the travelling bridge and sent to the digesters.

Phosphorous Removal

The phosphorous removal system is intended to lower the total phosphorous level in the final effluent by adding chemicals (ferrous chloride) as part of the treatment process. It also improves the settling of solids which reduces the total solids concentration in the final effluent. Ferrous chloride can be added at multiple locations throughout the WPCP.

Secondary Treatment

Aerated Bioreactor: Effluent from the primary clarifiers is treated with ferrous chloride in order to aid in phosphorus removal. There are six aerated bioreactors each containing anoxic and aerobic zones. In the first part of the tank no oxygen is introduced (anoxic), this is for denitrification. The second part of the tank is where fine bubbled air is diffused into the sewage (aerobic) to remove dissolved and suspended organics and nutrients from the wastewater. Biological activity is controlled to assimilate the organic material.

Secondary Clarifier: The effluent from the aerated bioreactor is directed to its associated secondary clarifier where solids settle quickly as activated sludge leaving a clear effluent. A portion of the activated sludge collected on the bottom of the clarifier is pumped back to the head of the bioreactor and any excess activated sludge is 'wasted' to the primary clarifier to co-settle.

Disinfection (chlorination/dechlorination)

Chlorine in the form of liquid sodium hypochlorite is metered into the effluent stream for pathogen control. Adequate contact time is provided by the chlorine contact chambers. Disinfected effluent is dechlorinated with a sodium bisulphite solution before being discharged to Lake Ontario through a 3.05 m diameter outfall pipe, approximately 1,100 m long with a 183 m long diffuser pipe.



Solids Management

Anaerobic Digestion: The sludges that are collected from the primary clarifiers are pumped into one of the four primary digesters followed by two secondary digesters. There are four blending tanks where raw sludges are blended with digested sludges before they are pumped to be dewatered. All solids produced are dewatered and incinerated on site.

Imported Biosolids

Durham's Regional Biosolids Management Program (ECA #H120110009-03) imports sludges from facilities in the Regional of Municipality of York and the Regional Municipality of Durham. Durham's biosolids are transported by Terratec Environmental Ltd. under C of A # A820250 and York's biosolids are transported by GFL Environmental Corp. under C of A # A841293.

Dewatering

Duffin Creek WPCP utilizes eight dewatering solid bowl centrifuges in order to separate the heavier material and the liquid supernatant. All dewatered solids (sludge cake) are sent to incineration.

Incineration

There are four fluidized bed process trains which through the combustion process burns the organic substances contained in the sludge cake and converts the cake into ash and flue gas. Steam boilers are utilized for waste heat recovery. All solids at Duffin Creek WPCP were incinerated during the reporting period.

The ash from the incineration process is sent to St. Mary's Cement in Bowmanville, Ontario for reuse. No land application or landfill of biosolids occurred in 2016. Ash disposal was hauled to St. Mary's Cement by BFI Canada Inc. under ECA #A840506.

Environmental Compliance Approval

Under Condition 10. (6) of ECA # 5531-9FJJT5 the Region of Durham must produce an annual performance report that contains the following information:

- a) Summary and interpretation of all monitoring data and a comparison to the effluent limits**
 - The Duffin Creek WPCP effluent was determined to be compliant with the ECA approval limits during the reporting period.
 - The plant operated at 61.1% of its approved capacity for this reporting period. The plant received a maximum daily flow of 579,279 m³ on April 1, 2016.
- b) Description of any operating problems encountered and corrective actions taken:**
 - Challenges arose when accommodating ongoing construction with processes being offline, electrical interruptions, flow diversions etc. These challenges were overcome with careful planning and communication.
 - Stage1 was restarted in December of 2016 after completion of the liquid process upgrades. Challenges arose with reseeded in the winter months. Close monitoring, pumping and testing made the startup possible.



- Plant computer server upgrades required multiple coordinated shut downs and created unexpected plant wide communication issues. Plant staff along with contracted personnel worked to successfully integrate the updated software with existing software.

c) Maintenance of major equipment

Major maintenance items in 2016 included:

Operations

- Stage 1 & 2 and 3 Substation Maintenance – servicing of all 4,160V and certain 600V switches, breakers, transformers/protection relays etc.
- Generators 1100, 1200, 1300, 1400, 5401, 5501,5601 – regular monthly runs as well as all oils and filters changed, fuel system checks.
- Digester preventative maintenance, Waste Gas Burners – servicing of all gas protection, including; pressure relief valves, gas valves, flame arrestors, roof pressure tests etc.
- Stage 3 Influent pumping station – all eight pumps lifted and inspected.
- Repaired and re-chained secondary clarifiers #19 & 22.
- Repaired and re-chained primary cross collector #14.
- Replaced Stage 3 grit pump screw gear boxes
- Repaired chlorination piping and fittings in underground chemical containment vaults.
- Repaired influent pumping station (IPS) biofilters.

Dewatering

- Repaired centrifuge screw.
- Completed repairs/upgrades to filtrate station platforms and piping.
- Modified/upgrade odour control system.

Incineration

- Replacement of scrubber piping.
- #1 Auxiliary boiler, refractory replacement.
- Replacement of boiler tube in #4 hot water boiler.
- Installation of equipment guarding.
- Replacement of effluent piping in south incineration building.

d) Summary of any effluent quality assurance or control measures

- In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. All results were found to be within a comparable range.
- On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.
- Analytical balances are calibrated by Fisher Scientific Company Ltd.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment;

Plant flows are measured at the influent of this plant.

- All influent flow meters were calibrated in February, 2016.
- All monitoring and laboratory equipment is calibrated and maintained according to manufacturer's specifications.



f) Efforts made and results achieved in meeting effluent objectives

The objective for pH was exceeded in the months of January and February. A new pH meter was purchased when efforts to alleviate drifting were unsuccessful. Best efforts and process adjustments were and will continue to be applied to maintain results below objectives.

g) The average E.coli count exceeded the objective in August. Investigation revealed multiple fractures on PVC fittings and corroded hose clamps in underground chemical containment vaults. Leaks were repaired and a procedure was created to inspect all lines and vaults.

h) An outline of anticipated volumes of sludge to be generated in the next reporting period.

There is no increase of sludge volume expected in the next reporting period.

i) Summary of any complaints received during the reporting period

Noise complaint – On March 18, 2016, a noise concern that was originally being dealt with by the Town of Ajax was forwarded to the attention of the Region of Durham. A resident from Ajax raised a concern that there was a persistent high frequency hum that was perceived to be emanating from the Duffin Creek WPCP. Notification of the concern was provided to the MOECC. There was no abnormal noise or major maintenance activities undertaken during the period in question. Noise levels outside of the plant and residential area were measured. Results were typical of industrial and residential areas. Technical Support staff is continuing to work with the resident to establish when the resident feels the noise is of concern so that plant conditions can be monitored.

j) Summary of all by-passes, spill or abnormal discharge events

There is no mechanism for by-passing untreated wastewater at this facility. There are no anticipated by-passes planned for the next reporting period.

Spill

On September 20, 2016 the Stage 3 headworks building experienced an overflow of influent wastewater. The influent flow flooded the basement, up to the ground floor, out of the doors of the building and onto the road. Once on the road, it flowed to stormwater catch basins. Standard operating procedures for spill response were followed and as a result less than 100 cubic meters reached Lake Ontario.

A variety of conditions contributed to the spill including, annual substation maintenance, construction and emergency repairs. An internal review and corrective actions have been implemented.

The MOECC was notified of the spill on September 20, 2016.

k) Notice of modifications and any implementation of Limited Operational Flexibility

No notice of modifications were submitted in 2016.

l) Extra Information

The fixed bed carbon adsorption units in the incineration complex were by-passed. The MOECC was notified on October 13, 2015. Investigations continue in 2017 in order to determine better operating conditions for the units.



Proposed Alterations, Extensions or Replacements

- Replacement of the Stage 1 and 2 Headworks and influent pumping station Contract T-13-50 (in progress, estimated completion date March, 2017).
- Improvements to Stage 1 and 2 Contract T-13-86 (Stage 2 complete and returned to service, Stage 1 off-line, estimated completion date March, 2017).
- Capital restoration plan for damaged sludge blending tank and biofilter works. Construction estimated to start in 2018.
- Standby power closed transition modifications to Stage 3 electrical substation (completion date March 2017).
- Stage 1 and 2 digester mixing improvements and motor control center replacements (detailed design to begin June 2017).
- Detailed design is planned to commence the summer of 2017 for replacement of incineration facility reactor 1 and 2, subject to Regional Council approval.
- Facility phosphorous optimization trials to begin April 2017 as a component of the outfall EA program.

MOECC Inspection

This plant was inspected by the MOECC on February 12, 2015. No action items were identified in the report.



Table 1 Raw Influent Flows

Month	York Region Plant Flow m ³	Durham Region Plant Flow m ³	Total Flow to Plant metered at the raw influent m ³	Average Daily Flow m ³ /d	Maximum Daily Flow m ³ /d	Minimum Daily Flow m ³ /d
January	8,342,229	1,843,643	10,185,872	328,577	455,638	300,859
February	7,828,970	1,730,212	9,559,182	329,627	412,100	299,109
March	9,218,475	2,037,294	11,255,769	363,089	464,915	320,834
April	9,128,634	2,017,439	11,146,074	371,536	579,279	321,820
May	8,097,647	1,789,590	9,887,236	318,943	340,532	298,896
June	7,601,386	1,679,916	9,281,302	309,377	337,732	295,820
July	7,649,784	1,690,612	9,340,396	301,303	330,112	281,219
August	8,020,023	1,772,435	9,792,458	315,886	365,251	281,253
September	7,083,632	1,565,491	8,649,124	288,304	309,969	267,989
October	7,465,581	1,649,902	9,115,483	294,048	318,636	278,963
November	7,136,072	1,577,081	8,713,153	290,438	332,610	276,364
December	7,658,535	1,692,546	9,351,081	301,648	405,588	277,903
Total (percentage (%)) *	95,230,969 (81.9%)	21,046,161 (18.1%)	116,277,130 (100%)			
Average *	7,935,914	1,753,847	9,689,761	317,731		
Minimum	7,083,632	1,565,491	8,649,124			267,989
Maximum	9,218,475	2,037,294	11,255,769		579,279	
ECA Requirement				520,000		
ECA Objective						
Met Compliance				Yes		

*Note – total and average reflect rounding of decimal places



Table 2 Raw Influent Analyses

Month	BOD ₅ average conc. mg/L	BOD ₅ average loading kg/d	TSS average conc. mg/L	TSS average loading kg/d	TP average conc. mg/L	TP average loading kg/d	DP average conc. mg/L	TKN average conc. mg/L
January	174	57,172	268	88,059	5.4	1,774	2.5	44.10
February	200	65,925	300	98,888	5.7	1,889	2.7	46.60
March	194	70,439	322	116,915	6.2	2,248	3.0	46.90
April	198	73,564	269	99,943	5.8	2,166	2.9	47.00
May	224	71,443	323	103,019	6.7	2,127	3.5	50.40
June	224	69,300	300	92,813	7.0	2,153	3.7	55.80
July	213	64,178	287	86,474	6.8	2,043	3.6	52.88
August	300	94,766	298	94,134	7.2	2,271	3.7	49.84
September	247	71,211	344	99,177	7.2	2,073	3.9	53.94
October	215	63,220	320	94,095	7.1	2,088	4.0	52.00
November	218	63,315	309	89,745	7.3	2,120	5.2	51.80
December	196	59,123	292	88,081	6.7	2,021	3.7	49.80
Average	217	69,103	303	96,420	6.6	2,098	3.5	50.09
Minimum	174	57,172	268	86,474	5.4	1,774	2.5	44.10
Maximum	300	94,766	344	116,915	7.3	2,271	5.2	55.80
Sampling Frequency Requirement Met	Yes		Yes		Yes			Yes



Table 2 Raw Influent Analyses continued

Month	TAN average conc. mg/L	TAN average loading kg/d	pH min.	pH max.	Temperature min. °C	Temperature max. °C
January	27.6	9,069	7.10	7.80	10.7	15.9
February	28.6	9,427	6.74	7.70	10.1	17.1
March	29.6	10,729	6.80	8.06	10.1	17.9
April	31.3	11,637	7.06	7.75	10.9	17.8
May	36.2	11,555	6.83	7.70	14.0	20.4
June	38.8	11,988	6.90	7.60	15.8	19.3
July	35.4	10,666	6.94	7.59	19.2	24.7
August	34.5	10,898	7.14	7.43	19.8	24.0
September	36.4	10,491	6.67	7.69	19.7	23.7
October	36.7	10,792	6.63	7.56	16.5	21.2
November	36.2	10,514	6.80	7.47	13.4	20.7
December	32.1	9,683	6.92	7.77	8.0	18.0
Average	33.6	10,708				
Minimum	27.6	9,069	6.63		8.0	
Maximum	38.8	11,988		8.06		24.7



Table 3 Final Effluent Analyses

Month	CBOD ₅ average conc. mg/L	CBOD ₅ average loading kg/d	TSS average conc. mg/L	TSS average loading kg/d	TP average conc. mg/L	TP average loading kg/d	TAN average conc. mg/L summer	TAN average conc. mg/L winter	TAN average loading kg/d
January	2.4	772	7.3	2,399	0.51	168		0.58	191
February	2.8	936	7.6	2,505	0.42	138		0.27	89
March	3.7	1,333	9.4	3,399	0.46	167		0.74	89
April	4.3	1,609	10.0	3,704	0.58	215		0.70	269
May	3.0	970	9.3	2,966	0.54	172	1.44		459
June	2.1	656	5.4	1,680	0.53	164	0.38		118
July	1.8	542	5.0	1,507	0.55	166	0.47		142
August	2.6	812	6.5	2,053	0.51	161	0.46		145
September	3.4	969	8.2	2,364	0.55	159	1.52		438
October	2.2	647	6.0	1,764	0.50	147	0.39		115
November	1.9	537	5.6	1,626	0.53	154		0.36	105
December	2.0	603	5.5	1,659	0.52	157		0.42	127
Average	2.7	853	7.1	2,277	0.52	165	0.78	0.51	205
Minimum	1.8	537	5.0	1,507	0.42	138	0.38	0.27	89
Maximum	4.3	1,609	10.0	3,704	0.58	215	1.52	0.74	459
ECA Requirement	25.0		25.0		0.8	311	6.0	10.0	
ECA Objective	15.0		15.0		0.6		5.0	5.0	
Within Compliance	Yes		Yes		Yes	Yes	Yes	Yes	
Sampling Requirement Frequency Met	Yes		Yes		Yes		Yes	Yes	



Table 3 Final Effluent Analyses continued

Month	Unionized Ammonia Nitrogen average conc. mg/L	TKN average conc. mg/L	DP average conc. mg/L	TCR average conc. mg/L	TCR average loading kg/d	pH min.	pH max.	Temp. °C min.	Temp. °C max.
January	0.0	1.76	0.33	0.00	0.00	6.2	7.3	9.7	17.4
February	0.0	1.47	0.26	0.00	0.00	6.4	7.3	7.1	17.6
March	0.0	2.16	0.27	0.00	0.00	6.9	7.4	8.5	18.8
April	0.0	2.09	0.37	0.00	0.00	6.7	7.1	8.2	18.1
May	0.0	2.65	0.36	0.00	0.00	6.7	7.0	15.2	21.2
June	0.0	1.41	0.42	0.00	0.00	6.5	7.0	16.9	22.4
July	0.0	1.55	0.44	0.00	0.00	6.6	7.1	18.7	23.8
August	0.0	1.62	0.37	0.00	0.00	6.7	7.2	20.8	24.6
September	0.0	2.61	0.36	0.00	0.00	6.7	7.8	20.2	24.2
October	0.0	1.57	0.34	0.00	0.00	6.7	7.2	11.2	23.2
November	0.0	1.46	0.39	0.00	0.00	6.6	7.3	15.0	20.6
December	0.0	1.51	0.36	0.00	0.00	6.5	7.2	11.6	18.1
Average	0.0	1.82	0.36	0.00	0.00				
Minimum	0.0	1.41	0.26	0.00	0.00	6.2		7.1	
Maximum	0.0	2.65	0.44	0.00	0.00		7.8		24.6
ECA Requirement	0.2			0.02		6.0	9.5		
ECA Objective	0.1			Non-detectable		6.5	8.5		
Within Compliance	Yes			Yes		Yes	Yes		
Sampling Frequency Requirement Met	Yes			Yes		Yes	Yes	Yes	Yes



Table 4 Escherichia Coliform Sampling

Month	Number of Samples	Geometric Mean Density
January	20	58
February	20	100
March	21	26
April	21	74
May	21	40
June	22	70
July	20	38
August	24	144
September	20	93
October	19	22
November	21	22
December	20	41
ECA Requirement	52	200
ECA Objective		100
Within Compliance		Yes
Sampling Frequency Requirement Met	Yes	



Table 5 Imported Wastewater Analyses

Month	BOD ₅ average conc. mg/L	TSS average conc. mg/L	TKN average conc. mg/L	TP average conc. mg/L
January	4604	7102	1219.13	185.5
February	3201	7345	721.25	204.1
March	5035	23260	811.10	168.2
April	5261	10938	1140.00	100.4
May	2878	4183	857.78	64.0
June	3026	13414	750.00	187.3
July	2737	29862	828.75	96.9
August	2017	10439	443.00	124.5
September	3814	10810	1381.00	224.0
October	6966	24270	744.00	162.0
November	7209	37585	1400.00	175.8
December	5013	16262	972.00	122.0
Average	4313	16289	939.00	151.2
Minimum	2017	4183	443.00	64.0
Maximum	7209	37585	1400.00	224.0
Sampling Requirement Frequency Met	Yes	Yes	Yes	Yes



Table 6 Energy and Chemical Usage

Month	Plant Flow m ³	Ferrous Chloride L	Sodium Hypochlorite L	Sodium Bisulphite L	Hydro kWh	Natural Gas m ³
January	10,185,872	859,959	206,289	34,688	5,287,203	305,601
February	9,559,182	732,777	190,477	27,328	4,657,885	291,486
March	11,255,769	697,232	263,457	37,209	5,042,572	252,189
April	11,146,074	828,278	310,573	41,898	4,880,240	201,925
May	9,887,236	972,020	167,765	26,185	5,200,472	53,404
June	9,281,302	890,632	166,588	22,983	5,181,579	133,644
July	9,340,396	754,086	152,998	21,449	5,159,514	10,174
August	9,792,458	1,026,184	206,648	28,947	5,609,280	91,575
September	8,649,124	1,130,121	220,014	28,005	5,122,303	124,615
October	9,115,483	1,075,486	180,676	24,710	5,041,775	183,285
November	8,713,153	947,909	137,545	18,020	4,607,086	192,107
December	9,351,081	1,103,749	145,541	16,690	5,016,907	279,097
Total	116,277,130	11,018,435	2,348,572	328,113	60,806,816	2,119,102



Table 7 Summary of sludge produced and imported

Month	York Influent Solids (dry tonnes)	Durham Influent Solids (dry tonnes)	Total Influent Solids (dry tonnes)	York Imported Solids (dry tonnes)	Durham Imported Solids (dry tonnes)	Total Imported Solids (dry tonnes)
January	2,236	494	2,730	83	451	534
February	2,349	519	2,868	81	411	492
March	2,968	656	3,624	89	366	455
April	2,456	543	2,998	109	384	493
May	2,616	578	3,194	107	105	212
June	2,280	504	2,784	106	65	171
July	2,195	485	2,681	115	147	262
August	2,390	528	2,918	110	58	168
September	2,437	539	2,975	93	97	190
October	2,389	528	2,917	91	101	192
November	2,205	487	2,692	95	260	355
December	2,236	494	3,164	97	483	580
Total	28,757	6,355	35,546	1,176	2,928	4,104



Table 8 Summary Hauled Septage & Incinerated Sludge

Month	York Septage Solids (dry tonnes)	Durham Septage Solids (dry tonnes)	Total Septage Solids (dry tonnes)	Dewatered Sludge Incinerated (dry tonnes)	Ash Produced (tonnes)
January	1.7	4.7	6.4	2,724	1,002
February	2.1	5.0	7.1	1,934	664
March	6.7	20.0	26.7	2,147	819
April	3.6	12.1	15.7	2,008	844
May	1.5	5.0	6.5	2,327	958
June	5.2	17.2	22.4	2,489	1,005
July	10.0	30.8	40.8	1,898	693
August	4.3	13.9	18.2	2,020	760
September	2.4	12.2	14.6	1,895	786
October	6.9	29.3	36.2	2,292	817
November	11.5	44.7	56.2	1,732	676
December	5.4	11.6	17.0	1,859	681
Total	61.2	206.7	267.9	25,324	9,705



Table 9 Dewatering Summary

Month	Average Feed Solids % TS	Average Sludge Cake % TS	Average Polymer Dosage kg/tonne	Total Sludge Output dry tonnes
January	3.3	20.3	7.0	2,433
February	3.6	23.3	6.9	2,400
March	3.3	19.0	7.1	2,535
April	3.4	26.1	7.6	2,796
May	3.1	25.8	7.6	3,186
June	2.9	26.6	7.4	3,012
July	2.6	26.2	7.3	2,648
August	2.5	25.6	6.7	2,198
September	2.3	25.1	7.7	1,695
October	2.3	26.1	6.9	2,532
November	2.5	24.7	7.6	2,561
December	2.0	25.4	7.7	3,955
Total				31,951
Average	2.8	24.5	7.3	2,663
Min	2.0	19.0	6.7	1,695
Max	3.6	26.6	7.7	3,955



Glossary of Terms

Aerated Bioreactor

A vessel in which a biological process is carried out which involves bacterial organisms or biochemically active substances derived from such organisms. This encompasses a combination of aerobic, anoxic, and anaerobic processes.

Anaerobic Digestion

Is a series of biological processes in which microorganisms break down biodegradable material in the absence of oxygen.

Annual Average Concentration

An arithmetic mean of the monthly average concentrations of a contaminant in the effluent calculated for any particular year.

Annual Average Loading

The value obtained by multiplying the Annual Average Concentration of a contaminant by the Average Daily Flow over the same calendar year.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

Biosolids

Organic material recovered from wastewater sludge.

BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

Means a diversion of sewage around one or more unit processes within the Sewage Treatment Plant with the diverted sewage flows being returned to the Sewage Treatment Plant treatment train upstream of the Final effluent sampling location, and discharging to the environment through the Sewage Treatment Plant outfall.

CBOD₅ - Five day Carbonaceous Biochemical Oxygen Demand

Means a five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample.

conc. - Concentration

A measure of the amount of a dissolved substance contained per unit of volume.



DP - Dissolved Phosphorus

This is the soluble form of phosphorus present in the wastewater.

ECA - Environmental Compliance Approval

The primary regulatory instrument for each WPCP.

E. coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius.

Final Effluent

Sewage discharge via the WPCP outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.

Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, a snapshot of the conditions at the time the sample was retrieved.

m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metres Per Day)

Flow measurement, 1m³ = 1000 litres or 220 imperial gallons. Volume of liquid treated in a day.

Max. – Maximum

The peak or highest reading recorded during a specific time period (usually in a day)

Maximum Flow Rate

The peak or highest flow recorded during a specific time period (usually in a day).

mg/L - (Milligram Per Litre)

This is a measure of the concentration of a parameter in water or wastewater, sometimes referred to as parts per million (ppm).

Min. – Minimum

The lowest reading recorded during a specific time period (usually in a day)

mm - (millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.



MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater facilities in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly Average Concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.

Monthly Average Loading

Calculated by multiplying the monthly average concentration of a contaminant in the effluent sampled or measured, or both, during a calendar month.

N/A - Not Applicable

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.

Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Septage

Partially treated sludge from a septic tank.

Sludge

The settleable solids separated from liquids during processing.

TAN -Total Ammonia Nitrogen

Ammonia exists in two forms in the water: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

TCR -Total Chlorine Residual

The total amount of chlorine in water, including the combined chlorine and the free available chlorine.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identifies as degrees Celsius.



TP -Total Phosphorus

A laboratory analyses to determine the total amount of particulate and soluble phosphorus present in the wastewater.

TSS -Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS -Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Unionized Ammonia Nitrogen

Un-ionized ammonia refers to all forms of ammonia in water with the exception of the ammonium ion (NH_4^+).

WPCP - Water Pollution Control Plant

Is typically a facility composed of a variety of treatment processes that collectively treat the wastewater.



**Harmony Creek Water Pollution Control Plant
Annual Performance Report 2016**

**Harmony Creek Water Pollution Control Plant
Annual Performance Report 2016**





The Regional Municipality of Durham

Harmony Creek Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 3580-9PXLVG Dated December 3, 2014

Environmental Compliance Approval (Air): 0488-6X5PZD Dated November 16, 2007

The Harmony Creek Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers a performance overview of the Harmony Creek WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

Water Pollution Control Plant Process Description

General

The Harmony Creek WPCP located in the City of Oshawa and is owned and operated by the Regional Municipality of Durham. The plant is operated according to the terms and conditions of the ECA.

The Harmony Creek WPCP treats wastewater from the Oshawa and Courtice service areas in the Regional Municipality of Durham. The Harmony Creek WPCP shares its catchment area flows with the Courtice WPCP. The Harmony Creek WPCP services approximately 52,343 residents or 30% of the total catchment population.

The Harmony Creek WPCP is designed to treat wastewater at an average flow rate of 34,100 cubic metres per day (m^3/d). The plant is an MOECC Class Four conventional activated sludge treatment plant that utilizes the following processes to treat wastewater:

- raw influent,
- preliminary treatment,
- primary treatment,
- secondary treatment,
- phosphorus removal,
- disinfection (chlorination/dechlorination),
- solids treatment.

Raw Influent

Wastewater is collected through approximately 655 km of sanitary sewers in Oshawa and Courtice and is conveyed to the Harmony Creek WPCP and Harmony Creek sanitary sewage pumping station (SSPS). Approximately 70% of the influent flow is diverted to the Harmony Creek SSPS and conveyed to the Courtice WPCP. The remaining flow is treated at the Harmony Creek WPCP.



Preliminary Treatment

Grit Removal: Heavy suspended material such as sand and small stones (grit) is removed in the aerated grit tank. The velocity of the wastewater flowing in the tanks is controlled by the quantity of air added to produce conditions that allow heavy grit material to settle, while keeping the lighter organic material in suspension to proceed to the next process tank. The grit removed in this process is transported to landfill.

Screening: One automatic, mechanically cleaned screen removes paper products and large material that could harm pumps and process equipment. Screenings are removed in this process and transported to landfill for disposal.

Primary Treatment

The primary clarifier utilizes the physical process of sedimentation which allows suspended material to settle to the bottom of the tank as sludge. This raw sludge, along with excess activated sludge from the secondary treatment process is collected by a flight and chain mechanism which pushes the sludge into hoppers. The sludge is then pumped to the anaerobic digester for further treatment. Any material floating on the surface of the clarifier (scum) is also removed to the digester.

Secondary Treatment

Aeration: The Harmony Creek WPCP has a flexible aeration system which can operate as two individual aeration tanks or as one large aeration tank. The current configuration is as one large aeration tank. The effluent from the primary clarifier flows into the aeration tanks. Here fine bubbled air is diffused into the sewage to assist bacteria in removing dissolved and suspended organics, and nutrients from the wastewater. Biological activity is controlled to assimilate the organic material.

Secondary Clarifier: The effluent from the bioreactor is directed to the secondary clarifier where the solids settle quickly to the bottom as activated sludge leaving clear supernatant. A portion of the activated sludge collected on the bottom of the clarifier is pumped back to the head of the bioreactor and the excess activated sludge is wasted to the primary clarifier.

Phosphorus Removal

The phosphorus removal system is intended to lower the total phosphorus level in the final effluent by adding a chemical coagulant (ferrous chloride). Ferrous chloride is added at the primary clarifier effluent.

Disinfection (chlorination/dechlorination)

Disinfection: Chlorine, in the form of liquid sodium hypochlorite, is metered into the secondary effluent stream for pathogen control. Adequate contact time is provided by the two chlorine contact chambers. Disinfected effluent is dechlorinated with a sodium bisulphite solution before being discharged to Lake Ontario.

Solids Treatment

Anaerobic Digestion: The raw sludge that is collected from the primary clarifier is pumped into the anaerobic digester where anaerobic bacteria reduce the volume of sludge. As a result of digestion the plant produces a more stabilized sludge, water, carbon dioxide, methane, and hydrogen sulphide. The water is returned to the head of the plant for further treatment and the methane is used to offset the natural gas requirements of the digester.



Biosolids: All sludge produced is pumped to the biosolids holding facility. From there the treated biosolids can be utilized on approved nurseries, approved agricultural fields, or be shipped to Duffin Creek WPCP for incineration. Biosolids are transported plant to plant in accordance with ECA #A820250 and ECA #4400-4LBLXD for land application.

Environmental Compliance Approval

Under Condition 9 (5) of the ECA #3580-9PXLVG the Region of Durham must produce an annual report that contains the following information:

a) Summary and interpretation of all monitoring data and a comparison to the effluent limits

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA. Table 2 summarizes the raw wastewater characteristics during the reporting period.

The Harmony Creek WPCP effluent was determined to be compliant with the ECA approval limits during the reporting period. The plant operated at an average of 42% of its annual average rated flow capacity and received a maximum daily flow of 24,142 m³/d on April 1, 2016.

b) Description of any operating problems encountered and corrective actions taken:

No major operating problems were encountered in 2016.

c) Maintenance of major equipment

Major maintenance items in 2016 included:

- Repaired west secondary clarifier flight and chain drive shaft.
- Repaired west secondary scum trough.
- Replaced boiler #1 tubes.
- Rebuilt Plant #2 bar screen.
- Rebuilt plant #2 by-pass bar screen.
- Rebuilt pumping station pump #210.
- Rebuilt #1 sludge transfer pump.
- Rebuilt #1 sludge recirculation pump.
- Replaced ferrous chloride feed pump #2.

d) Summary of any effluent quality assurance or control measures

- In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. All results were found to be within a comparable range.

e) Summary of the calibration and maintenance carried out

- Calibration of the secondary clarifier flow meter occurred in September 2016.
- The effluent flow meter was replaced on July 5 by Monitario.
- Calibration of the AutoCat 9000 chlorine analyzer was conducted July 28, 2016.
- Calibration of the in-house lab pH meter was conducted regularly.



f) Effluent Objectives

The Regional Municipality of Durham continually strives to achieve the best effluent quality at all times, remaining below the ECA compliance limits.

The average daily rated flow capacity of 34,100 m³/d was not exceeded.

The total suspended solids objective of 15.0 mg/L was exceeded in eight of 288 samples (3%). This was the result of additional loading from Port Darlington WPCP sludge to the plant, and the accumulation of solids on the chlorine contact chamber due to excessive retention time. Half of the chlorine contact chamber was removed from service to reduce solids accumulation, while still maintaining required contact time.

The total phosphorus objective of 1 mg/L was exceeded in nine of 293 (3%) samples. This is also attributed to the additional sludge loading to the plant. Samples were monitored and ferrous chloride was increased as required.

The E.coli monthly average objective of 200 cfu/100 ml was exceeded on four occasions. These results occurred during the non-disinfection period of January to April prior to the new disinfection system being operational.

Best efforts and process adjustments will continue to be applied to maintain results below objectives.

g) Tabulation of Volume of Sludge Generated:

The volume of sludge removed from Harmony Creek WPCP in 2016 was 21,994 m³.

Outline of Anticipated Volumes to be Generated in the Next Reporting Period:

There is a decrease of sludge volume expected in the next reporting period due to Port Darlington sludge no longer being received at Harmony Creek WPCP.

Summary of Locations to Where Sludge is Disposed:

Duffin Creek WPCP – 19,892 m³ or 90.4%

Agricultural Fields – 738 m³ or 3.4%

Nursery – 1,364 m³ or 6.2%

h) Summary of Complaints and Steps Taken to Address the Complaint:

There were no documented complaints in 2016.

i) Summary of By-passes and Spills

A planned by-pass was approved by the MOECC on November 14th allowing the influent raw flow to be diverted around the primary clarifier so that raw sewage could go directly to the aeration tank. This was done so that the primary digester could undergo approved essential maintenance. The influent sewage was being fully treated through the preliminary and secondary processes and sampling was conducted to ensure compliance with the ECA. Approval for the by-pass commenced November 14th 2016 and is permitted to carry through until March 2018.

There were no spills during the reporting period.



j) Schedule 'A', Section 1 Notice of Modifications and Status Update

No schedule 'A', Section 1 Notice of Modifications were submitted in 2016.

k) Schedule 'A', Section 3 Notice of Modifications

No schedule 'A', Section 3 Notice of Modifications were submitted in 2016.

l) Additional Information Required by MOECC Water Supervisor

No additional information was requested.

MOECC Inspection

An MOECC inspection occurred January 26, 2016. MOECC recommendation to have operating chlorination/dechlorination facilities was completed in 2016.



Harmony Creek Water Pollution Control Plant
Annual Performance Report 2016

Table 1 Raw Influent Flows

Month	Total Flow to Plant -metered at the final effluent m³	Average Day Flow m³/d	Maximum Day Flow m³/d
January	468,031	15,098	20,903
February	477,219	16,456	22,257
March	430,370	13,883	18,449
April	475,899	15,863	24,142
May	460,665	14,860	16,570
June	455,186	15,173	16,769
July	445,477	14,370	18,389
August	475,562	15,341	18,578
September	436,869	14,562	15,296
October	420,344	13,559	14,878
November	364,427	12,148	15,052
December	370,722	11,959	14,051
Total	5,280,770		
Average	440,064	14,428*	
Minimum	364,427		
Maximum	477,219		24,142
ECA Requirement		34,100	
Met Compliance		Yes	

*Annual Average Daily Flow



**Harmony Creek Water Pollution Control Plant
Annual Performance Report 2016**

Table 2 Raw Influent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d
January	141	2,131	229	3,454	306	4,618	6.6	99
February	149	2,449	276	4,534	381	6,266	6.5	107
March	128	1,777	307	4,262	428	5,938	7.2	100
April	140	2,221	256	4,057	388	6,154	5.8	92
May	226	3,358	399	5,929	496	7,367	6.0	90
June	167	2,526	325	4,937	441	6,692	6.8	104
July	168	2,414	212	3,043	260	3,742	5.3	76
August	144	2,209	168	2,580	202	3,105	4.7	72
September	120	1,747	168	2,439	235	3,428	5.3	77
October	151	2,047	190	2,580	260	3,527	6.1	83
November	119	1,446	212	2,578	296	3,590	6.0	72
December	122	1,453	276	3,301	365	4,361	6.6	79
Average	148	2,133	251	3,628	338	4,879	6.1	88
Minimum	119	1,446	168	2,439	202	3,105	4.7	72
Maximum	226	3,358	399	5,929	496	7,367	7.2	107
Sampling Frequency Requirement Met			Yes		Yes		Yes	



**Harmony Creek Water Pollution Control Plant
Annual Performance Report 2016**

Table 2 Raw Influent Analyses continued

Month	DP avg. conc. mg/L	COD avg. conc. mg/L	TKN avg. conc. mg/L	TAN avg. conc. mg/L	TAN loading kg/d*	Nitrate plus Nitrite mg/L	pH min.	pH max.
January	1.44	608	42.35	25.20	380	0.18	6.42	7.57
February	1.52	537	48.25	24.73	407	0.22	6.61	7.43
March	0.77	590	49.04	24.57	341	0.20	6.71	7.54
April	0.99	536	40.40	21.04	334	0.22	6.96	7.49
May	1.81	455	49.70	27.48	408	0.25	7.17	7.62
June	1.82	463	53.36	31.06	471	0.20	6.59	7.69
July	2.09	367	47.25	32.98	474	0.16	6.73	7.44
August	1.64	255	35.46	26.41	405	0.26	7.02	7.41
September	1.72	404	43.20	29.61	431	0.19	6.95	7.39
October	2.04	327	42.00	29.46	399	0.27	6.83	7.31
November	2.38	330	48.24	32.91	400	0.25	6.97	7.39
December	1.70	477	48.98	26.72	319	0.27	6.98	7.42
Average	1.66	446	45.69	27.68	399	0.22		
Minimum	0.77	255	35.46	21.04	319	0.16	6.42	
Maximum	2.38	608	53.36	32.98	474	0.27		7.69
Sampling Frequency Requirement Met		Yes	Yes			Yes	Yes	Yes

*Annual Average loading



**Harmony Creek Water Pollution Control Plant
Annual Performance Report 2016**

Table 3 Final Effluent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d	TAN avg. conc. mg/L	TAN loading kg/d
January	2.4	36.6	5.6	84.4	0.54	8.2	0.32	1.84
February	4.5	73.2	9.7	158.9	0.46	7.6	0.19	3.59
March	2.5	35.3	4.3	59.7	0.31	4.3	0.12	1.60
April	2.4	37.7	5.9	93.7	0.29	4.6	0.16	1.59
May	5.5	82.1	12.2	181.4	0.69	10.2	0.38	2.83
June	3.4	51.0	8.2	124.4	0.81	12.3	0.58	2.09
July	3.1	43.8	6.9	99.6	0.83	11.9	0.67	2.02
August	4.0	61.4	7.3	111.5	0.54	8.2	0.35	2.19
September	2.1	30.6	7.4	108.3	0.38	5.6	0.19	2.31
October	2.1	28.5	3.5	47.9	0.48	6.5	0.36	2.17
November	3.6	44.2	5.0	60.1	0.74	9.0	0.58	2.70
December	3.7	44.5	6.6	79.0	0.53	6.4	0.26	2.48
Average	3.3	47.4	6.9	99.6	0.55	8.0	0.35	2.28
Minimum	2.1	28.5	3.5	47.9	0.29	4.3	0.12	1.59
Maximum	5.5	82.1	12.2	181.4	0.83	12.3	0.67	3.59
ECA Requirement	25.0	852.5*	25.0	852.5*	1.0	34.1		
ECA Objective	15.0		15.0		1.0			
Within Compliance	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
Sampling Frequency Requirement Met	Yes		Yes		Yes		Yes	

*Annual Average loading



Harmony Creek Water Pollution Control Plant
Annual Performance Report 2016

Table 3 Final Effluent Analyses continued

Month	Unionized NH3 avg. conc. mg/L	TKN avg. conc. mg/L	DP avg. conc. mg/L	TCR avg. conc. mg/L	Nitrate plus Nitrite mg/L	pH min.	pH max.	Temp. °C min.	Temp. °C max.
January	0.00	1.84	0.32	N/A	21.83	6.61	7.32	10.2	16.1
February	0.00	3.59	0.19	N/A	21.60	6.65	7.26	8.2	16.0
March	0.00	1.60	0.12	N/A	24.44	6.83	7.42	8.6	13.5
April	0.00	1.59	0.16	N/A	23.73	6.61	7.49	10.0	19.1
May	0.00	2.83	0.38	0.00	23.03	7.07	7.50	14.7	19.2
June	0.00	2.09	0.58	0.00	24.92	6.60	7.58	17.5	20.9
July	0.00	2.02	0.67	0.01	30.88	6.69	7.23	20.9	23.3
August	0.00	2.19	0.35	0.00	21.54	6.48	7.21	22.0	24.6
September	0.00	2.31	0.19	0.00	24.40	6.70	7.22	20.5	24.2
October	0.00	2.17	0.36	0.00	22.13	6.66	7.16	15.3	22.0
November	0.00	2.70	0.58	0.00	22.88	6.69	7.36	15.7	18.9
December	0.00	2.48	0.26	0.00	17.08	6.89	7.29	10.8	17.2
Average	0.0	2.28	0.35	0.00	23.20				
Minimum	0.0	1.59	0.12	0.00	17.08	6.48		8.2	
Maximum	0.0	3.59	0.67	0.01	30.88		7.58		24.6
ECA Requirement									
ECA Objective				0.5		6.0	9.5		
Within Compliance									
Sampling Frequency Requirement Met	Yes	Yes		Yes	Yes	Yes	Yes	Yes	Yes



Table 4 Escherichia coliform Sampling

- Seasonal disinfection period is from May 15 to October 15.

Month	Number of Samples	Geometric Mean Density
January	4	3,911
February	4	11,537
March	5	1,773
April	4	2,752
May	4	108
June	5	46
July	4	20
August	5	28
September	4	39
October	4	19
November	5	40
December	4	109
ECA Requirement (Seasonal)		N/A
ECA Objective (Seasonal)		200
Within Compliance		N/A
Sampling Frequency Requirement Met	Yes	



Table 5 Energy and Chemical Usage

Month	Total Plant Flow (cubic metres)	Ferrous Chloride (litres)	Sodium Hypochlorite (kilograms as chlorine)	Sodium Bisulphite (Litres)	Hydro (kWh)	Natural Gas (cubic metres)
January	468,031	11,798	0	0	638,546	23,191
February	477,219	25,553	0	0	516,271	15,361
March	430,370	17,039	0	0	593,930	15,782
April	475,899	16,017	0	0	537,136	10,084
May	460,665	18,053	753	1,398	444,773	3,010
June	455,186	25,158	1134	1,569	424,506	3,936
July	445,477	31,525	1093	1,089	475,171	8,126
August	475,562	41,185	1052	1,450	380,055	3,471
September	436,869	37,562	1065	1,238	379,034	10,237
October	420,344	39,187	933	1,277	422,165	14,122
November	364,427	24,027	774	1,130	434,473	19,544
December	370,722	31,949	1495	1,283	504,996	19,658
Total	5,280,770	319,053	8,300	10,435	5,751,056	146,522

Glossary of Terms

Aeration Tank

Is a vessel in which a biological process is carried out which involves bacterial organisms or biochemically active substances derived from such organisms. This encompasses a combination of aerobic, anoxic processes.

Anaerobic Digestion

Is a series of biological processes in which microorganisms break down biodegradable material in the absence of oxygen.

Annual Average Concentration

An arithmetic mean of the monthly average concentrations of a contaminant in the effluent calculated for any particular year.



Annual Average Loading

The value obtained by multiplying the Annual Average Concentration of a contaminant by the Average Daily Flow over the same calendar year.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

Biosolids

Organic material recovered from wastewater sludge.

BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

A diversion of sewage around one or more unit processes within the Sewage Treatment Plant with the diverted sewage flows being returned to the Sewage Treatment Plant treatment train upstream of the Final effluent sampling location, and discharging to the environment through the Sewage Treatment Plant outfall.

CBOD₅ -Five day Carbonaceous Biochemical Oxygen Demand

A five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample.

conc. – Concentration

A measure of the amount of dissolved substance contained per unit of volume.

DP – Dissolved Phosphorus

This is the soluble form of phosphorus present in the wastewater.

ECA - Environmental Compliance Approval

The primary regulatory instrument for each WPCP.

E. coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius. Calculated using a monthly geometric mean density.

Final Effluent

Sewage discharge via the WPCP outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.



Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, a snapshot of the conditions at the time the sample was retrieved.

m³ - (Cubic Metre)

Volume measurement, 1 m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metres Per Day)

Flow measurement, 1 m³ = 1000 litres or 220 imperial gallons. Volume of liquid treated in a day.

Max. – Maximum

The peak or highest value recorded during a specific time period usually in a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.

mg/L - (Milligram Per Litre)

This is a measure of the concentration of a parameter in wastewater, sometimes referred to as parts per million (ppm).

Min. – Minimum

The lowest value recorded during a specific time period usually in a day.

mm - (millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.

MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly Average Concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.

Monthly Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar month divided by the number of days during which sewage was flowing to the sewage works that month.



Monthly Average Loading

Calculated by multiplying the monthly average concentration of a contaminant in the effluent sampled or measured, or both, during a calendar month by the monthly average daily flow.

N/A - Not Applicable

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.

Rated Capacity

The Average Daily Flow for which the works are approved to handle.

Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Septage

Partially treated sludge from a septic tank.

Sludge

The settleable solids separated from liquids during processing.

TAN -Total Ammonia Nitrogen

Ammonia exists in two forms in the water: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

TCR -Total Chlorine Residual

The total amount of chlorine in water, including the combined chlorine and the free available chlorine.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.

TP -Total Phosphorus

A laboratory analyses to determine the total amount of particulate and soluble phosphorus present in the wastewater.

TSS -Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.



TS -Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Unionized Ammonia Nitrogen

Un-ionized ammonia refers to all forms of ammonia in water with the exception of the ammonium ion (NH_4^+). Calculated using the methodology specified in the MOECC's Guideline and Policies document titled "Provincial Water Quality Objectives" (July 1994).

WPCP - Water Pollution Control Plant

Is typically a facility composed of a variety of treatment processes that collectively treat the wastewater.

If this information is required in an accessible format, please contact 1-800-372-1102 extension 3488



Lake Simcoe Water Pollution Control Plant Annual Performance Report 2016





The Regional Municipality of Durham

Lake Simcoe Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 5292-8CYHTQ Dated June 28, 2012

Environmental Compliance Approval (Air): 8-3041-95-006 Dated February 5, 1996

The Lake Simcoe Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers an overview of the performance of the Lake Simcoe WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

Water Pollution Control Plant Process Description

General

The Lake Simcoe WPCP located in the Community of Beaverton in the Township of Brock is owned and operated by the Regional Municipality of Durham. The plant is operated according to the terms and conditions of the ECA. This MOECC Class Three wastewater treatment plant utilizes an extended aeration process with tertiary treatment and is designed to treat wastewater at a rated capacity of 4,550 cubic metres per day (m³/d) The Lake Simcoe WPCP has a service population of 3,809 residents.

Lake Simcoe WPCP treats wastewater from the Community of Beaverton service area utilizing the following processes:

- raw influent pumping,
- preliminary treatment,
- phosphorus removal,
- secondary treatment,
- tertiary treatment,
- disinfection,
- solids treatment.

Raw Influent Pumping

Wastewater is collected through approximately 23.9 km of sanitary sewers in Beaverton and is conveyed to the WPCP by gravity or by two sanitary sewage pumping stations Harbour Street and Cedar Beach located in the collection system. The two flows are combined in the raw sewage inlet channel.

Preliminary Treatment

Screening: There are two screen channels in the screen room for the removal of paper products and large material that could harm pumps and process equipment. One channel contains an automatic, mechanically cleaned bar screen and the other is equipped with a bar rack to provide screening on an emergency basis. Screenings are removed in this process and transported to landfill for disposal.



Grit Removal: Vortex grit removal is provided to remove sand, gravel, etc. for protection of mechanical equipment from unnecessary wear and reduce formation of heavy deposits in pipelines, channels and process tanks. The vortex grit tank uses centrifugal force to separate the grit from the wastewater. Grit is collected in the lower portion of the grit tank and is pumped to a grit classifier for dewatering. The dewatered grit is conveyed to the grit/screenings bin for landfill disposal.

Phosphorus Removal

The phosphorous removal system is intended to lower the total phosphorous level in the final effluent by adding a chemical coagulant (aluminum sulphate) as part of the treatment process. Aluminum sulphate can be added at multiple locations within the plant.

Secondary Treatment

Aerated Bioreactors: Preliminary effluent flow is directed to two aerated bioreactors. Surface mechanical aerators mix air into the sewage to assist bacteria in removing dissolved and suspended organics and nutrients from the wastewater. Biological activity is controlled to assimilate the organic material.

Secondary Clarifier: The effluent from the aerated bioreactors is directed to its associated secondary clarifier where solids settle quickly as activated sludge leaving a clear effluent. A portion of the activated sludge collected on the bottom of the clarifier is pumped back to the head of the bioreactors and the excess activated sludge is wasted to the aerobic digester.

Tertiary Treatment

Tertiary Clarifier: The secondary effluent is directed to the tertiary clarifier. The helical flow pattern in the clarifier separates the solids from the liquid, the effluent flows over to the next process and the thickened sludge is pumped to the aerobic digester.

Tertiary Sand Filter: Effluent flow from the tertiary clarifier flows into an automatic self-cleaning sand filter. The automatic backwash is initiated by an increase in head pressure or a programmed timer. The backwash water is returned to the beginning of the plant for further treatment.

Disinfection

Ultra Violet (UV) Irradiation: The effluent flow from the sand filter is then directed to the UV channel for disinfection. The flow passes two banks of UV lamps connected in series before being discharged to Lake Simcoe through the 400mm diameter outfall extending 314 metres into Lake Simcoe.

Solids Treatment

Aerobic Digester: Activated sludge from the secondary clarifiers is pumped to an aerobic digester for stabilization. A mechanical mixer and a fixed header diffused aeration system provide oxygen for the microorganisms. The mixer and diffusers are turned off to allow solids to settle for removal and the supernatant to be decanted and flow by gravity to the raw equalization lagoon for further treatment.

Biosolids Management: Stabilized biosolids from the digester are transported to Duffin Creek Water Pollution Control Plant within the Region of Durham for incineration in accordance with ECA #A820250.

Environmental Compliance Approval

Under Condition 9 (5) of ECA # 5292-8CYHTQ the Region of Durham must produce an annual performance report that must contain the following information:



a) Summary and interpretation of all monitoring data and a comparison to the effluent limits outlined in Condition 5, including an overview of the success and adequacy of the works

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA. Table 2 summarizes the raw wastewater characteristics during the reporting period.

The Lake Simcoe WPCP effluent was compliant with the approval limits during the reporting period. The plant operated at 38.3% of its rated capacity and received a maximum daily flow of 5,891m³/d on April 2nd, 2016. Tables 3-5 provide a tabulation of effluent results.

b) Description of any operating problems encountered and corrective actions taken

No operating problems were encountered in 2016.

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the works

Major maintenance items in 2016 included:

- A new pump was installed to replace duty pump #2 at Cedar Beach Pumping Station
- Three new Variable Frequency Drives were installed at Cedar Beach Pumping Station
- A new radio alarm unit was installed at Cedar Beach Pumping station

d) Summary of any effluent quality assurance or control measures undertaken in the reporting period

- In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. Results were found to be in a comparable range. On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment

- Calibration of the effluent flow meter occurred in May and November 2016.
- Calibration of the in-house laboratory equipment was conducted in July 2016.
- Calibration of the pH meter is conducted weekly.

f) Efforts made and results achieved in meeting the effluent objectives of Condition 4

- The Regional Municipality of Durham strives to achieve the best effluent quality at all times, remaining below the ECA compliance limits.



- The Lake Simcoe WPCP effluent met all ECA objectives except for:
The effluent objective for total suspended solids was exceeded in eight of 309 samples (2.6%).
The effluent objective for total phosphorus was exceeded in five of 312 samples (1.6%).
Results were monitored and adjustments were made to the treatment process when required.
On March 28th we experienced heavier than usual flows due to wet weather conditions resulting in higher total suspended solids and total phosphorus levels. Adjustments were made to the plant processes to accommodate these conditions.
- Best efforts and process adjustments will continue to be applied to maintain results below objectives.

g) Tabulation of Volume of Sludge Generated

The volume of sludge removed from Lake Simcoe WPCP in 2016 was 1,840m³.

Outline of Anticipated Volumes to be Generated in the Next Reporting Period

There is no increase of sludge volume expected in the next reporting period.

Summary of Locations to Where Sludge was Disposed

Duffin Creek WPCP- 1,840m³.

h) Summary of any complaints received during the reporting period and any steps taken to address the complaint

A summary of complaints received from the public is administered through a central database. There were no complaints received during the reporting period.

i) Summary of all By-pass, Spill or Abnormal Discharge Events

On March 28th secondary effluent overflowed to the environment due to wet weather conditions. This event was reported to the MOECC as a bypass.

j) Status Update of Initial Effluent Characterization

The effluent characterization report was submitted in 2015.

k) Information required by MOECC District Manager

No additional information was requested.

MOECC Inspection

This plant was not inspected by the MOECC in 2016.



Summary of Tables

Table 1 Flows

Month	Total Plant Flow m ³	Average Day Flow m ³ /d	Maximum Day Flow m ³ /d
January	48,750	1,573	2,495
February	58,470	2,016	2,795
March	89,338	2,882	5,837
April	94,140	3,138	5,891
May	56,299	1,816	3,038
June	35,173	1,172	1,495
July	42,973	1,386	2,736
August	58,796	1,897	3,609
September	55,141	1,838	2,674
October	37,846	1,221	2,511
November	27,068	902	1,155
December	34,280	1,106	1,923
Total	638,273		
Average	53,189	1,744*	
Minimum	27,068		
Maximum	94,140		5,891
ECA Requirement		4,550	15,110
Met Compliance		Yes	Yes

*Annual Average



Table 2 Raw Influent Analyses

Month	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d	DP avg. conc. mg/L	Alkalinity CaCO ₃ mg/L
January	59	93	78	122	1.9	3.1	1.2	288
February	57	115	65	131	1.3	2.7	0.9	287
March	31	89	48	138	0.9	2.5	0.5	275
April	64	201	96	301	1.5	4.6	0.6	276
May	77	140	76	138	2.1	3.8	1.0	304
June	82	97	80	94	2.7	3.1	1.7	277
July	94	130	102	142	2.6	3.6	1.4	242
August	79	150	98	186	2.0	3.8	1.1	213
September	92	169	115	211	2.4	4.5	1.4	207
October	112	137	117	143	2.9	3.5	1.7	246
November	112	101	91	82	3.3	3.0	2.2	289
December	78	86	75	83	2.6	2.8	1.7	263
Average	78	136	87	151	2.2	3.8	1.3	264
Minimum	31	86	48	82	0.9	2.5	0.5	207
Maximum	112	201	117	301	3.3	4.6	2.2	304
Sampling Frequency Requirement Met	Yes		Yes		Yes			Yes



Lake Simcoe Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses continued

Month	TKN avg. conc. mg/L	TKN loading kg/d	TAN avg. conc. mg/L	TAN loading kg/d	pH min.	pH max.	Temp. Degrees Celsius min.	Temp. Degrees Celsius max.
January	16.13	25	13.08	20.6	7.50	7.98	4.5	11.5
February	14.10	28	8.09	16.3	7.54	8.05	4.9	10.3
March	7.74	22	5.09	14.7	7.66	7.93	5.3	11.8
April	12.90	40	6.02	18.9	7.66	8.19	3.3	11.0
May	18.90	34	11.50	20.9	7.37	7.84	8.9	16.0
June	24.64	29	7.18	8.4	7.15	7.60	13.1	17.4
July	24.68	34	17.83	24.7	7.07	7.30	15.8	19.2
August	18.88	36	13.83	26.2	6.46	7.53	17.4	22.0
September	23.08	42	16.58	30.5	6.90	7.35	16.5	20.6
October	27.30	33	22.44	27.4	6.67	7.46	12.9	18.1
November	31.16	28	25.35	22.9	7.03	7.50	10.6	15.7
December	25.08	28	18.49	20.4	7.26	7.86	7.8	13.5
Average	20.38	36	13.79	24.1				
Minimum	7.74	22	5.09	8.4	6.46		3.3	
Maximum	31.16	42	25.35	30.5		8.19		22.0
Sampling Frequency Requirement Met	Yes				Yes	Yes		



Table 3 Final Effluent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d	TP loading kg/month
January	0.5	0.8	0.7	1	0.03	0.0	1.2
February	0.6	1.3	0.8	2	0.03	0.1	1.6
March	1.4	4.1	4.1	12	0.05	0.1	4.3
April	0.9	2.7	4.8	15	0.04	0.1	3.8
May	1.1	2.0	1.0	2	0.07	0.1	4.1
June	0.6	0.7	0.8	1	0.08	0.1	2.8
July	0.5	0.7	0.9	1	0.04	0.1	1.8
August	0.4	0.8	0.9	2	0.03	0.1	1.6
September	0.5	0.9	1.1	2	0.03	0.0	1.4
October	0.8	1.0	0.9	1	0.03	0.0	1.0
November	0.5	0.5	0.7	1	0.05	0.0	1.3
December	0.5	0.6	0.7	1	0.03	0.0	0.9
Total							26*
Average	0.7	1.2	1.5	3	0.04	0.1	2.2
Minimum	0.4	0.5	0.7	1	0.03	0.0	0.9
Maximum	1.4	4.1	4.8	15	0.08	0.1	4.3
ECA Limit	10**		10**		0.3**		190*
ECA Objective	5		5		0.12		190
LSPRS					0.15***		190*
Within Compliance	Yes		Yes		Yes		Yes
Sampling Frequency Requirement Met	Yes		Yes		Yes		

*Total Annual Loading, kg/year

**Monthly Average Concentration

***Annual Average Concentration



Table 3 Final Effluent Analyses continued

Month	DP avg. conc. mg/L	TAN Summer avg. conc. mg/L	TAN Winter avg. conc. mg/L	TAN loading kg/d	TKN avg. conc. mg/L	Un-ionized ammonia avg. conc. mg/L
January	0.02		0.02	0.0	0.50	0.0
February	0.02		0.03	0.1	0.50	0.0
March	0.02		0.10	0.3	0.75	0.0
April	0.02		0.08	0.2	0.66	0.0
May	0.04		0.04	0.1	0.64	0.0
June	0.05	0.04		0.1	0.73	0.0
July	0.03	0.03		0.0	0.65	0.0
August	0.02	0.02		0.0	0.66	0.0
September	0.01		0.03	0.1	0.78	0.0
October	0.01		0.03	0.0	0.72	0.0
November	0.03		0.03	0.0	0.72	0.0
December	0.02		0.03	0.0	0.62	0.0
Average	0.02	0.03	0.04	0.1	0.66	0.0
Minimum	0.01	0.02	0.02	0.0	0.50	0.0
Maximum	0.05	0.04	0.10	0.3	0.78	0.0
ECA Limit		5**	15**			
ECA Objective		3	10			
Within Compliance		Yes	Yes			
Sampling Frequency Requirement Met		Yes	Yes			

**Monthly Average Concentration



Table 3 Final Effluent Analyses continued

Month	pH min.	pH max.	Temp. Degrees Celsius min.	Temp. Degrees Celsius max.
January	7.23	7.47	6.8	9.8
February	7.29	7.67	5.2	12.4
March	7.18	7.51	5.3	10.8
April	7.24	7.58	7.3	12.3
May	7.23	7.74	10.2	17.2
June	6.90	7.49	14.0	18.9
July	6.56	7.17	18.2	23.1
August	6.75	7.49	19.5	22.7
September	6.71	7.43	16.3	23.2
October	6.67	7.13	11.8	18.3
November	6.91	7.19	8.4	14.7
December	7.04	7.39	5.2	13.0
Minimum	6.56		5.2	
Maximum		7.74		23.2
ECA Objective	6.5	9.0		
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes



Table 4 Escherichia Coliform Sampling

Month	Number of Samples	Monthly Geometric Mean Density
January	4	0
February	4	0
March	5	0
April	4	0
May	4	0
June	5	1
July	4	0
August	5	0
September	4	0
October	4	0
November	5	1
December	4	0
ECA Objective		40 organisms/100ml
Sampling Frequency Requirement Met	Yes	



Table 5 Total Coliform Sampling

Month	Number of Samples	Geometric Mean Density
January	4	1
February	4	0
March	5	5
April	4	1
May	4	0
June	5	10
July	4	2
August	5	0
September	4	1
October	4	2
November	5	2
December	4	1
Sampling Frequency Requirement Met	Yes	



Table 6 Energy and Chemical Usage

Month	Alum (litres)	Hydro (kWh)	Natural Gas (cubic metres)
January	4,882	87,851	17,387
February	4,869	72,954	17,472
March	9,971	78,302	16,146
April	7,447	71,427	13,348
May	1,954	76,010	7,455
June	2,416	68,371	0
July	3,450	70,281	0
August	7,066	71,808	0
September	5,881	67,989	0
October	3,369	72,572	2,432
November	3,045	74,482	10,158
December	4,188	90,906	15,605
Total	58,538	902,953	100,003



Glossary of Terms

Annual Average Concentration

An arithmetic mean of the monthly average concentrations of a contaminant in the effluent calculated for any particular year.

Annual Average Loading

The value obtained by multiplying the annual average concentration of a contaminant by the average daily flow over the same calendar year.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

Avg – Average

An arithmetic mean of the average concentrations and loadings.

Biosolids

Organic material recovered from wastewater sludge.

Bioreactor

A bioreactor is a vessel in which a biological process is carried out which involves bacterial organisms or biochemically active substances derived from such organisms.

BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

Any discharge from the works that does not undergo any treatment or only receives partial treatment before it is discharged to the environment.

cBOD₅ -Five Day Carbonaceous Biochemical Oxygen Demand

Means a five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample..

Conc. - Concentration

The abundance of a constituent divided by the total volume of a mixture.

Daily Concentration

The concentration of a contaminant in the effluent discharged over any single day, as measured by a composite or grab sample, whichever is required.

DP - Dissolved Reactive Phosphorus

This is the soluble form of phosphorus present in the wastewater.

ECA - Environmental Compliance Approval

The primary regulatory instrument for each water pollution control plant.

E. - coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius.



Final Effluent

Sewage discharge through the water pollution control plant outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.

Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, when tested provides a snapshot of the conditions at the time the sample was retrieved.

kg - kilogram

Basic unit of mass in the metric system

kg/d – kilogram per day

LSPRS - Lake Simcoe Phosphorus Reduction Strategy

The ECA issued on June 28, 2012 introduced additional phosphorus objectives to comply with the requirements of the Lake Simcoe Phosphorus Reduction Strategy (2010) prepared under the Lake Simcoe Protection Plan (2009).

m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metre Per Day)

Flow measurement, 1m³ = 1000litres or 220 imperial gallons. Volume of liquid treated in a day.

Max-Maximum

The peak or highest value recorded during a specific time period usually a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.

mg/L - (Milligram Per Litre)

This is a measure of the concentration of a parameter in water, sometimes referred to as parts per million (ppm).

Min-Minimum

The lowest value recorded during a specific time period usually in a day.

mm.-(millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.

MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly Average Concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.



Monthly Average Loading

Is calculated by multiplying the monthly average concentration of a contaminant by the monthly average daily flow over the same calendar month.

N/A - Not Applicable

Peak Flow Rate

The maximum rate of sewage flow for which the plant or process unit was designed.

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.

Rated Capacity

The average daily flow for which the works are approved to handle.

Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Septage

Partially treated sludge from a septic tank.

Sludge

The settleable solids separated from liquids during processing.

TAN - Total Ammonia Nitrogen

Ammonia exists in two forms in the wastewater: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.

Total Annual Loading

Is calculated by adding the calculated total monthly load discharged for each calendar year.

Total Monthly Loading

Is calculated by multiplying the total monthly flow by the monthly average concentration.

TP - Total Phosphorus

A laboratory analyses to determine the total amount of non-soluble and soluble phosphorus present in the wastewater.

TSS - Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS - Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Unionized Ammonia Nitrogen

Un-ionized ammonia refers to all forms of ammonia in water with the exception of the ammonium ion (NH_4^+).



WPCP - Water Pollution Control Plant

A facility composed of a variety of treatment processes that collectively treat wastewater.

If this information is required in an accessible format, please contact 1-800-372-1102 extension 3488



Lake Simcoe Water Pollution Control Plant Annual Performance Report 2016





The Regional Municipality of Durham

Lake Simcoe Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 5292-8CYHTQ Dated June 28, 2012

Environmental Compliance Approval (Air): 8-3041-95-006 Dated February 5, 1996

The Lake Simcoe Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers an overview of the performance of the Lake Simcoe WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

Water Pollution Control Plant Process Description

General

The Lake Simcoe WPCP located in the Community of Beaverton in the Township of Brock is owned and operated by the Regional Municipality of Durham. The plant is operated according to the terms and conditions of the ECA. This MOECC Class Three wastewater treatment plant utilizes an extended aeration process with tertiary treatment and is designed to treat wastewater at a rated capacity of 4,550 cubic metres per day (m³/d) The Lake Simcoe WPCP has a service population of 3,809 residents.

Lake Simcoe WPCP treats wastewater from the Community of Beaverton service area utilizing the following processes:

- raw influent pumping,
- preliminary treatment,
- phosphorus removal,
- secondary treatment,
- tertiary treatment,
- disinfection,
- solids treatment.

Raw Influent Pumping

Wastewater is collected through approximately 23.9 km of sanitary sewers in Beaverton and is conveyed to the WPCP by gravity or by two sanitary sewage pumping stations Harbour Street and Cedar Beach located in the collection system. The two flows are combined in the raw sewage inlet channel.

Preliminary Treatment

Screening: There are two screen channels in the screen room for the removal of paper products and large material that could harm pumps and process equipment. One channel contains an automatic, mechanically cleaned bar screen and the other is equipped with a bar rack to provide screening on an emergency basis. Screenings are removed in this process and transported to landfill for disposal.



Grit Removal: Vortex grit removal is provided to remove sand, gravel, etc. for protection of mechanical equipment from unnecessary wear and reduce formation of heavy deposits in pipelines, channels and process tanks. The vortex grit tank uses centrifugal force to separate the grit from the wastewater. Grit is collected in the lower portion of the grit tank and is pumped to a grit classifier for dewatering. The dewatered grit is conveyed to the grit/screenings bin for landfill disposal.

Phosphorus Removal

The phosphorous removal system is intended to lower the total phosphorous level in the final effluent by adding a chemical coagulant (aluminum sulphate) as part of the treatment process. Aluminum sulphate can be added at multiple locations within the plant.

Secondary Treatment

Aerated Bioreactors: Preliminary effluent flow is directed to two aerated bioreactors. Surface mechanical aerators mix air into the sewage to assist bacteria in removing dissolved and suspended organics and nutrients from the wastewater. Biological activity is controlled to assimilate the organic material.

Secondary Clarifier: The effluent from the aerated bioreactors is directed to its associated secondary clarifier where solids settle quickly as activated sludge leaving a clear effluent. A portion of the activated sludge collected on the bottom of the clarifier is pumped back to the head of the bioreactors and the excess activated sludge is wasted to the aerobic digester.

Tertiary Treatment

Tertiary Clarifier: The secondary effluent is directed to the tertiary clarifier. The helical flow pattern in the clarifier separates the solids from the liquid, the effluent flows over to the next process and the thickened sludge is pumped to the aerobic digester.

Tertiary Sand Filter: Effluent flow from the tertiary clarifier flows into an automatic self-cleaning sand filter. The automatic backwash is initiated by an increase in head pressure or a programmed timer. The backwash water is returned to the beginning of the plant for further treatment.

Disinfection

Ultra Violet (UV) Irradiation: The effluent flow from the sand filter is then directed to the UV channel for disinfection. The flow passes two banks of UV lamps connected in series before being discharged to Lake Simcoe through the 400mm diameter outfall extending 314 metres into Lake Simcoe.

Solids Treatment

Aerobic Digester: Activated sludge from the secondary clarifiers is pumped to an aerobic digester for stabilization. A mechanical mixer and a fixed header diffused aeration system provide oxygen for the microorganisms. The mixer and diffusers are turned off to allow solids to settle for removal and the supernatant to be decanted and flow by gravity to the raw equalization lagoon for further treatment.

Biosolids Management: Stabilized biosolids from the digester are transported to Duffin Creek Water Pollution Control Plant within the Region of Durham for incineration in accordance with ECA #A820250.

Environmental Compliance Approval

Under Condition 9 (5) of ECA # 5292-8CYHTQ the Region of Durham must produce an annual performance report that must contain the following information:



a) Summary and interpretation of all monitoring data and a comparison to the effluent limits outlined in Condition 5, including an overview of the success and adequacy of the works

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA. Table 2 summarizes the raw wastewater characteristics during the reporting period.

The Lake Simcoe WPCP effluent was compliant with the approval limits during the reporting period. The plant operated at 38.3% of its rated capacity and received a maximum daily flow of 5,891m³/d on April 2nd, 2016. Tables 3-5 provide a tabulation of effluent results.

b) Description of any operating problems encountered and corrective actions taken

No operating problems were encountered in 2016.

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the works

Major maintenance items in 2016 included:

- A new pump was installed to replace duty pump #2 at Cedar Beach Pumping Station
- Three new Variable Frequency Drives were installed at Cedar Beach Pumping Station
- A new radio alarm unit was installed at Cedar Beach Pumping station

d) Summary of any effluent quality assurance or control measures undertaken in the reporting period

- In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. Results were found to be in a comparable range. On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment

- Calibration of the effluent flow meter occurred in May and November 2016.
- Calibration of the in-house laboratory equipment was conducted in July 2016.
- Calibration of the pH meter is conducted weekly.

f) Efforts made and results achieved in meeting the effluent objectives of Condition 4

- The Regional Municipality of Durham strives to achieve the best effluent quality at all times, remaining below the ECA compliance limits.



- The Lake Simcoe WPCP effluent met all ECA objectives except for:
The effluent objective for total suspended solids was exceeded in eight of 309 samples (2.6%).
The effluent objective for total phosphorus was exceeded in five of 312 samples (1.6%).
Results were monitored and adjustments were made to the treatment process when required.
On March 28th we experienced heavier than usual flows due to wet weather conditions resulting in higher total suspended solids and total phosphorus levels. Adjustments were made to the plant processes to accommodate these conditions.
- Best efforts and process adjustments will continue to be applied to maintain results below objectives.

g) Tabulation of Volume of Sludge Generated

The volume of sludge removed from Lake Simcoe WPCP in 2016 was 1,840m³.

Outline of Anticipated Volumes to be Generated in the Next Reporting Period

There is no increase of sludge volume expected in the next reporting period.

Summary of Locations to Where Sludge was Disposed

Duffin Creek WPCP- 1,840m³.

h) Summary of any complaints received during the reporting period and any steps taken to address the complaint

A summary of complaints received from the public is administered through a central database. There were no complaints received during the reporting period.

i) Summary of all By-pass, Spill or Abnormal Discharge Events

On March 28th secondary effluent overflowed to the environment due to wet weather conditions. This event was reported to the MOECC as a bypass.

j) Status Update of Initial Effluent Characterization

The effluent characterization report was submitted in 2015.

k) Information required by MOECC District Manager

No additional information was requested.

MOECC Inspection

This plant was not inspected by the MOECC in 2016.



Summary of Tables

Table 1 Flows

Month	Total Plant Flow m ³	Average Day Flow m ³ /d	Maximum Day Flow m ³ /d
January	48,750	1,573	2,495
February	58,470	2,016	2,795
March	89,338	2,882	5,837
April	94,140	3,138	5,891
May	56,299	1,816	3,038
June	35,173	1,172	1,495
July	42,973	1,386	2,736
August	58,796	1,897	3,609
September	55,141	1,838	2,674
October	37,846	1,221	2,511
November	27,068	902	1,155
December	34,280	1,106	1,923
Total	638,273		
Average	53,189	1,744*	
Minimum	27,068		
Maximum	94,140		5,891
ECA Requirement		4,550	15,110
Met Compliance		Yes	Yes

*Annual Average



Table 2 Raw Influent Analyses

Month	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d	DP avg. conc. mg/L	Alkalinity CaCO ₃ mg/L
January	59	93	78	122	1.9	3.1	1.2	288
February	57	115	65	131	1.3	2.7	0.9	287
March	31	89	48	138	0.9	2.5	0.5	275
April	64	201	96	301	1.5	4.6	0.6	276
May	77	140	76	138	2.1	3.8	1.0	304
June	82	97	80	94	2.7	3.1	1.7	277
July	94	130	102	142	2.6	3.6	1.4	242
August	79	150	98	186	2.0	3.8	1.1	213
September	92	169	115	211	2.4	4.5	1.4	207
October	112	137	117	143	2.9	3.5	1.7	246
November	112	101	91	82	3.3	3.0	2.2	289
December	78	86	75	83	2.6	2.8	1.7	263
Average	78	136	87	151	2.2	3.8	1.3	264
Minimum	31	86	48	82	0.9	2.5	0.5	207
Maximum	112	201	117	301	3.3	4.6	2.2	304
Sampling Frequency Requirement Met	Yes		Yes		Yes			Yes



**Lake Simcoe Water Pollution Control Plant
Annual Performance Report 2016**

Table 2 Raw Influent Analyses continued

Month	TKN avg. conc. mg/L	TKN loading kg/d	TAN avg. conc. mg/L	TAN loading kg/d	pH min.	pH max.	Temp. Degrees Celsius min.	Temp. Degrees Celsius max.
January	16.13	25	13.08	20.6	7.50	7.98	4.5	11.5
February	14.10	28	8.09	16.3	7.54	8.05	4.9	10.3
March	7.74	22	5.09	14.7	7.66	7.93	5.3	11.8
April	12.90	40	6.02	18.9	7.66	8.19	3.3	11.0
May	18.90	34	11.50	20.9	7.37	7.84	8.9	16.0
June	24.64	29	7.18	8.4	7.15	7.60	13.1	17.4
July	24.68	34	17.83	24.7	7.07	7.30	15.8	19.2
August	18.88	36	13.83	26.2	6.46	7.53	17.4	22.0
September	23.08	42	16.58	30.5	6.90	7.35	16.5	20.6
October	27.30	33	22.44	27.4	6.67	7.46	12.9	18.1
November	31.16	28	25.35	22.9	7.03	7.50	10.6	15.7
December	25.08	28	18.49	20.4	7.26	7.86	7.8	13.5
Average	20.38	36	13.79	24.1				
Minimum	7.74	22	5.09	8.4	6.46		3.3	
Maximum	31.16	42	25.35	30.5		8.19		22.0
Sampling Frequency Requirement Met	Yes				Yes	Yes		



Table 3 Final Effluent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d	TP loading kg/month
January	0.5	0.8	0.7	1	0.03	0.0	1.2
February	0.6	1.3	0.8	2	0.03	0.1	1.6
March	1.4	4.1	4.1	12	0.05	0.1	4.3
April	0.9	2.7	4.8	15	0.04	0.1	3.8
May	1.1	2.0	1.0	2	0.07	0.1	4.1
June	0.6	0.7	0.8	1	0.08	0.1	2.8
July	0.5	0.7	0.9	1	0.04	0.1	1.8
August	0.4	0.8	0.9	2	0.03	0.1	1.6
September	0.5	0.9	1.1	2	0.03	0.0	1.4
October	0.8	1.0	0.9	1	0.03	0.0	1.0
November	0.5	0.5	0.7	1	0.05	0.0	1.3
December	0.5	0.6	0.7	1	0.03	0.0	0.9
Total							26*
Average	0.7	1.2	1.5	3	0.04	0.1	2.2
Minimum	0.4	0.5	0.7	1	0.03	0.0	0.9
Maximum	1.4	4.1	4.8	15	0.08	0.1	4.3
ECA Limit	10**		10**		0.3**		190*
ECA Objective	5		5		0.12		190
LSPRS					0.15***		190*
Within Compliance	Yes		Yes		Yes		Yes
Sampling Frequency Requirement Met	Yes		Yes		Yes		

*Total Annual Loading, kg/year

**Monthly Average Concentration

***Annual Average Concentration



Table 3 Final Effluent Analyses continued

Month	DP avg. conc. mg/L	TAN Summer avg. conc. mg/L	TAN Winter avg. conc. mg/L	TAN loading kg/d	TKN avg. conc. mg/L	Un-ionized ammonia avg. conc. mg/L
January	0.02		0.02	0.0	0.50	0.0
February	0.02		0.03	0.1	0.50	0.0
March	0.02		0.10	0.3	0.75	0.0
April	0.02		0.08	0.2	0.66	0.0
May	0.04		0.04	0.1	0.64	0.0
June	0.05	0.04		0.1	0.73	0.0
July	0.03	0.03		0.0	0.65	0.0
August	0.02	0.02		0.0	0.66	0.0
September	0.01		0.03	0.1	0.78	0.0
October	0.01		0.03	0.0	0.72	0.0
November	0.03		0.03	0.0	0.72	0.0
December	0.02		0.03	0.0	0.62	0.0
Average	0.02	0.03	0.04	0.1	0.66	0.0
Minimum	0.01	0.02	0.02	0.0	0.50	0.0
Maximum	0.05	0.04	0.10	0.3	0.78	0.0
ECA Limit		5**	15**			
ECA Objective		3	10			
Within Compliance		Yes	Yes			
Sampling Frequency Requirement Met		Yes	Yes			

**Monthly Average Concentration



Table 3 Final Effluent Analyses continued

Month	pH min.	pH max.	Temp. Degrees Celsius min.	Temp. Degrees Celsius max.
January	7.23	7.47	6.8	9.8
February	7.29	7.67	5.2	12.4
March	7.18	7.51	5.3	10.8
April	7.24	7.58	7.3	12.3
May	7.23	7.74	10.2	17.2
June	6.90	7.49	14.0	18.9
July	6.56	7.17	18.2	23.1
August	6.75	7.49	19.5	22.7
September	6.71	7.43	16.3	23.2
October	6.67	7.13	11.8	18.3
November	6.91	7.19	8.4	14.7
December	7.04	7.39	5.2	13.0
Minimum	6.56		5.2	
Maximum		7.74		23.2
ECA Objective	6.5	9.0		
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes



Table 4 Escherichia Coliform Sampling

Month	Number of Samples	Monthly Geometric Mean Density
January	4	0
February	4	0
March	5	0
April	4	0
May	4	0
June	5	1
July	4	0
August	5	0
September	4	0
October	4	0
November	5	1
December	4	0
ECA Objective		40 organisms/100ml
Sampling Frequency Requirement Met	Yes	



Table 5 Total Coliform Sampling

Month	Number of Samples	Geometric Mean Density
January	4	1
February	4	0
March	5	5
April	4	1
May	4	0
June	5	10
July	4	2
August	5	0
September	4	1
October	4	2
November	5	2
December	4	1
Sampling Frequency Requirement Met	Yes	



Table 6 Energy and Chemical Usage

Month	Alum (litres)	Hydro (kWh)	Natural Gas (cubic metres)
January	4,882	87,851	17,387
February	4,869	72,954	17,472
March	9,971	78,302	16,146
April	7,447	71,427	13,348
May	1,954	76,010	7,455
June	2,416	68,371	0
July	3,450	70,281	0
August	7,066	71,808	0
September	5,881	67,989	0
October	3,369	72,572	2,432
November	3,045	74,482	10,158
December	4,188	90,906	15,605
Total	58,538	902,953	100,003



Glossary of Terms

Annual Average Concentration

An arithmetic mean of the monthly average concentrations of a contaminant in the effluent calculated for any particular year.

Annual Average Loading

The value obtained by multiplying the annual average concentration of a contaminant by the average daily flow over the same calendar year.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

Avg – Average

An arithmetic mean of the average concentrations and loadings.

Biosolids

Organic material recovered from wastewater sludge.

Bioreactor

A bioreactor is a vessel in which a biological process is carried out which involves bacterial organisms or biochemically active substances derived from such organisms.

BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

Any discharge from the works that does not undergo any treatment or only receives partial treatment before it is discharged to the environment.

cBOD₅ -Five Day Carbonaceous Biochemical Oxygen Demand

Means a five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample..

Conc. - Concentration

The abundance of a constituent divided by the total volume of a mixture.

Daily Concentration

The concentration of a contaminant in the effluent discharged over any single day, as measured by a composite or grab sample, whichever is required.

DP - Dissolved Reactive Phosphorus

This is the soluble form of phosphorus present in the wastewater.

ECA - Environmental Compliance Approval

The primary regulatory instrument for each water pollution control plant.

E. - coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius.



Final Effluent

Sewage discharge through the water pollution control plant outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.

Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, when tested provides a snapshot of the conditions at the time the sample was retrieved.

kg - kilogram

Basic unit of mass in the metric system

kg/d – kilogram per day

LSPRS - Lake Simcoe Phosphorus Reduction Strategy

The ECA issued on June 28, 2012 introduced additional phosphorus objectives to comply with the requirements of the Lake Simcoe Phosphorus Reduction Strategy (2010) prepared under the Lake Simcoe Protection Plan (2009).

m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metre Per Day)

Flow measurement, 1m³ = 1000litres or 220 imperial gallons. Volume of liquid treated in a day.

Max-Maximum

The peak or highest value recorded during a specific time period usually a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.

mg/L - (Milligram Per Litre)

This is a measure of the concentration of a parameter in water, sometimes referred to as parts per million (ppm).

Min-Minimum

The lowest value recorded during a specific time period usually in a day.

mm.-(millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.

MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly Average Concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.



Monthly Average Loading

Is calculated by multiplying the monthly average concentration of a contaminant by the monthly average daily flow over the same calendar month.

N/A - Not Applicable

Peak Flow Rate

The maximum rate of sewage flow for which the plant or process unit was designed.

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.

Rated Capacity

The average daily flow for which the works are approved to handle.

Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Septage

Partially treated sludge from a septic tank.

Sludge

The settleable solids separated from liquids during processing.

TAN - Total Ammonia Nitrogen

Ammonia exists in two forms in the wastewater: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.

Total Annual Loading

Is calculated by adding the calculated total monthly load discharged for each calendar year.

Total Monthly Loading

Is calculated by multiplying the total monthly flow by the monthly average concentration.

TP - Total Phosphorus

A laboratory analyses to determine the total amount of non-soluble and soluble phosphorus present in the wastewater.

TSS - Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS - Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Unionized Ammonia Nitrogen

Un-ionized ammonia refers to all forms of ammonia in water with the exception of the ammonium ion (NH_4^+).



WPCP - Water Pollution Control Plant

A facility composed of a variety of treatment processes that collectively treat wastewater.

If this information is required in an accessible format, please contact 1-800-372-1102 extension 3488



Newcastle Water Pollution Control Plant Annual Performance Report 2016





The Regional Municipality of Durham

Newcastle Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 3-2189-87-946 Dated July 26, 1994

Amendments: Dated June 21, 2006

May 10, 1998

June 11, 1996

Environmental Compliance Approval (Air): 8-3083-93-006 Dated March 22, 1993

The Newcastle Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers a performance overview of the Newcastle WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

Water Pollution Control Plant Process Description

General

The Newcastle WPCP is located in the Municipality of Clarington (Newcastle) and is owned and operated by the Regional Municipality of Durham. The plant is operated according to the terms and conditions of the ECA.

The plant treats wastewater from the Newcastle service area in the Regional Municipality of Durham, servicing approximately 10,477 residents.

The Newcastle WPCP is designed to treat wastewater at an average flow rate of 4,086 cubic metres per day (m^3/d) with a peak flow rate of 12,300 m^3/d . The plant is an MOECC Class Three conventional activated sludge treatment plant that utilizes the following processes to treat wastewater:

- raw influent pumping,
- preliminary treatment,
- primary treatment,
- secondary treatment,
- phosphorus removal,
- disinfection (chlorination/dechlorination),
- solids treatment.

Raw Influent Pumping

Wastewater collected through approximately 38 km of sanitary sewers in Newcastle is conveyed to the Newcastle WPCP by gravity and by two sanitary sewage pumping stations located in the collection system.



Preliminary Treatment

Screening: One automatic, mechanically cleaned screen removes paper products and large material that could harm pumps and process equipment. Screenings removed in this process are transported to landfill.

Grit Removal: Heavy suspended material such as sand and small stones (grit) is removed in the aerated grit tank. The velocity of the wastewater rolling in the tanks is controlled by the quantity of air added to produce conditions that allow heavy grit material to settle, while keeping the lighter organic material in suspension to proceed to the next process tank. The grit removed in this process is dewatered and transported to landfill.

Primary Treatment

The primary clarifier utilizes the physical process of sedimentation which allows suspended material to settle to the bottom of the tank as sludge. This raw sludge, along with excess activated sludge from the secondary treatment process is collected by a sweep arm mechanism which pushes the sludge into a hopper. The sludge is then pumped to the sludge holding tank for transportation to Courtice WPCP. Any material floating on the surface of the clarifier (scum) is also removed to the holding tank.

Secondary Treatment

Aerated Bioreactor: The bioreactors are comprised of two distinct sections. The first section is an anoxic zone, where no oxygen is introduced and allows for potential denitrification. Subsequently, the flow leaves the anoxic zone and enters the aerated zone where fine bubbled air is diffused into the sewage to assist bacteria in removing dissolved and suspended organics, and nutrients from the wastewater. Biological activity is controlled to assimilate the organic material.

Secondary Clarifier: The effluent from the bioreactor is directed to the secondary clarifier where the solids settle quickly to the bottom as activated sludge leaving clear supernatant. A portion of the activated sludge collected on the bottom of the clarifier is pumped back to the head of the bioreactor and the excess activated sludge is wasted to the primary clarifier.

Phosphorus Removal

The phosphorous removal system is intended to lower the total phosphorous level in the final effluent by adding a chemical coagulant (aluminum chloride). Aluminum chloride can be added at multiple locations within the plant

Disinfection (chlorination/dechlorination)

Chlorine in the form of liquid sodium hypochlorite is metered into the secondary effluent stream for pathogen control. Adequate contact time is provided by the single chlorine contact chamber. Disinfected effluent is dechlorinated with a sodium bisulphite solution before being discharged through a 900 mm diameter outfall extending 130 m to a 600 mm pipe extending 800 m into Lake Ontario.

Solids Treatment

All sludge produced at the Newcastle WPCP is stored in a sludge holding tank. The sludge is shipped to the Courtice WPCP for anaerobic digestion. Sludge is transported plant to plant in accordance with ECA #A820250.



Environmental Compliance Approval

Under Condition 17 (1) of ECA #3-2189-87-946 the Region of Durham must produce an annual report that contains the following information:

a) Summary and interpretation of all monitoring data and a comparison to the effluent limits

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA. Table 2 summarizes the raw wastewater characteristics during the reporting period.

The Newcastle WPCP effluent was determined to be compliant with the ECA approval limits during the reporting period. The plant operated at an average of 63% of its annual average rated flow capacity and received a maximum daily flow of 6,417 m³/d on January 11th, 2016. See tables for effluent results.

b) Description of any operating problems encountered and corrective actions taken:

No operating problems were encountered at the Newcastle WPCP in 2016.

c) Maintenance of major equipment

Major maintenance items in 2016 included:

- Rebuilt raw sewage pump #2.
- Installed upgraded plant-wide SCADA system.

d) Summary of any effluent quality assurance or control measures

- In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. All results were found to be within a comparable range.
- Online instrumentation is verified by WPCP operators using field or laboratory test equipment.

e) Summary of the calibration and maintenance carried out

- Calibration of the raw influent flow meter was conducted in May and September 2016.
- Calibration of the AutoCat 9000 chlorine analyzer was conducted on July 29, 2016.
- Calibration of the in-house lab pH meter was conducted monthly.

f) Effluent Objectives

The Regional Municipality of Durham continually strives to achieve the best effluent quality at all times, remaining below the ECA compliance limits.

The average daily rated flow capacity of 4,086m³/d was not exceeded. The maximum rated flow rate of 12,300 m³/d was not exceeded.

The total chlorine residual monthly average objective was exceeded on five of 12 occasions (42%). The ECA requests an objective concentration of 0 mg/L, however the instrumentation used has a detection limit of 0.0012 mg/L so it is typical to have results above 0 mg/L. Sodium bisulphite dosing is monitored to ensure low total chlorine residuals.



Best efforts and process adjustments will continue to be applied to maintain results below objectives.

g) Sludge Production:

Tabulation of Volume of Sludge Generated:

The volume of sludge removed from Newcastle WPCP in 2016 was 6,956 m³ at an average concentration of 2.5% total solids. See table 5 Sludge Quality and Disposal.

Outline of Anticipated Volumes to be Generated in the Next Reporting Period:

There is no increase of sludge volume expected in the next reporting period.

Summary of Locations to Where Sludge is Disposed:

Courtice WPCP -100%

h) Summary of Complaints and Steps Taken to Address the Complaints:

There were two odour complaints received from the same homeowner in 2016. Once on August 20 and another on December 2. The MOECC was notified regarding the August 20 complaint for informative purposes only and the homeowner could not identify a specific period regarding the second complaint. Additional steps to reduce odourous air from leaving the headworks building were put in place and staff continue to monitor for odours from this facility. No further complaints have been received.

i) By-passes and Spills

An MOECC approved by-pass of the chlorine contact chamber was conducted on October 19, 2016 for annual cleaning. The MOECC supervisor was notified once the bypass was complete.

There were no spills during the reporting period.

j) Proposed Alterations, Extensions or Replacements

A plant-wide SCADA system upgrade was completed in 2016.

k) Information Required by MOECC Water Supervisor

Table 7 provides a Bacterial analysis of the Newcastle Water Supply Plant raw water for 2016.

MOECC Inspection

No MOECC inspection occurred in 2016.



Newcastle Water Pollution Control Plant
Annual Performance Report 2016

Table 1 Raw Influent Flows

Month	Total Flow to Plant -metered at the raw influent m ³	Average Day Flow m ³ /d	Maximum Day Flow m ³ /d
January	116,673	3,764	7,007
February	97,148	3,350	4,332
March	118,647	3,827	5,544
April	103,436	3,448	5,900
May	79,882	2,577	3,130
June	71,506	2,384	3,217
July	67,451	2,176	2,741
August	68,376	2,206	2,714
September	64,939	2,165	2,731
October	64,224	2,072	2,440
November	61,953	2,065	2,439
December	74,033	2,388	3,162
Total	988,268		
Average	82,356	2,700*	
Minimum	61,953		
Maximum	118,647		7,007
ECA Requirement		4,086	
Met Compliance		Yes	

*Annual Average Daily Flow



Newcastle Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d
January	76	287	180	677	188	706	3.4	13
February	76	255	170	569	204	684	3.8	13
March	81	309	133	508	187	716	3.5	14
April	80	275	140	481	186	641	3.3	11
May	114	294	176	454	235	607	5.1	13
June	108	257	162	386	217	518	5.1	12
July	149	323	172	374	221	481	5.0	11
August	118	261	183	403	235	518	5.3	12
September	133	288	178	386	215	465	5.6	12
October	162	335	244	506	274	568	6.7	14
November	149	307	190	393	237	489	5.9	12
December	106	252	141	336	252	601	5.2	13
Average	113	304	172	465	221	596	4.8	13
Minimum	76	252	133	336	186	465	3.3	11
Maximum	162	335	244	677	274	716	6.7	14
Sampling Frequency Requirement Met								



**Newcastle Water Pollution Control Plant
Annual Performance Report 2016**

Table 2 Raw Influent Analyses continued

Month	DP avg. conc. mg/L	TKN avg. conc. mg/L	TKN loading kg/d	TAN avg. conc. mg/L	TAN loading kg/d	pH min.	pH max.
January	1.38	27.95	105	18.75	71	7.10	7.55
February	1.72	32.38	108	20.88	70	5.30	7.50
March	1.42	29.62	113	19.38	74	7.10	7.98
April	1.44	28.83	99	17.83	61	6.70	7.80
May	2.29	37.28	96	23.62	61	6.86	7.72
June	2.05	41.60	99	26.02	62	6.92	7.90
July	2.21	41.73	91	26.85	58	6.42	7.23
August	2.26	39.96	88	25.21	56	6.60	7.23
September	2.31	40.08	87	26.33	57	6.86	7.60
October	2.76	47.38	98	29.73	62	6.89	7.90
November	2.79	44.70	92	30.94	64	7.01	7.80
December	2.42	38.65	92	28.61	68	6.20	7.49
Average	2.09	37.51	101	24.51	66		
Minimum	1.38	27.95	87	17.83	56	5.30	
Maximum	2.79	47.38	113	30.94	74		7.98
Sampling Frequency Requirement Met							



Table 3 Final Effluent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d	TAN avg. conc. mg/L summer	TAN avg. conc. mg/L winter	TAN loading kg/d
January	1.5	6	4.9	18	0.32	1.2		0.20	0.8
February	1.7	6	5.9	20	0.28	0.9		0.47	1.6
March	2.0	8	5.5	21	0.25	1.0		0.32	1.2
April	1.6	6	6.6	23	0.42	1.5	0.23		0.8
May	2.1	5	6.3	16	0.38	1.0	0.53		1.4
June	2.5	6	5.7	14	0.30	0.7	0.67		1.6
July	1.9	4	4.8	10	0.23	0.5	0.07		0.2
August	1.9	4	5.3	12	0.22	0.5	0.18		0.4
September	1.6	3	4.9	11	0.20	0.4	0.59		1.3
October	2.3	5	6.4	13	0.30	0.6	0.99		2.1
November	2.0	4	7.2	15	0.26	0.5	3.93		8.1
December	1.8	4	6.1	15	0.17	0.4		4.76	11.4
Average	1.9	5	5.8	16	0.28	0.8	0.90	1.44	2.6
Minimum	1.5	3	4.8	10	0.17	0.4	0.07	0.20	0.2
Maximum	2.5	8	7.2	23	0.42	1.5	3.93	4.76	11.4
ECA Requirement	25.0	102	25.0	102			15	20	
ECA Objective	15.0	61.29	15.0	61.29	1.0	4.1	10	15	
Within Compliance	Yes	Yes	Yes	Yes	Yes		Yes	Yes	
Sampling Frequency Requirement Met	Yes		Yes		Yes		Yes	Yes	



Table 3 Final Effluent Analyses continued

Month	Unionized NH3 avg. conc. mg/L	TKN avg. conc. mg/L	DP avg. conc. mg/L	TCR avg. conc. mg/L	Nitrate plus Nitrite mg/L	pH min.	pH max.	Temp. °C min.	Temp. °C max.
January	0.00	1.02	0.06	0.00	12.11	6.40	7.18	11.4	15.3
February	0.00	1.72	0.09	0.00	12.90	6.20	7.12	10.2	13.1
March	0.00	1.14	0.09	0.00	12.24	6.40	7.52	10.2	12.8
April	0.00	1.18	0.19	0.00	12.20	6.20	7.11	10.8	13.5
May	0.00	1.70	0.13	0.01	14.18	6.00	7.09	12.3	17.2
June	0.00	1.90	0.10	0.01	14.00	5.90	6.94	15.5	21.3
July	0.00	1.18	0.05	0.00	14.23	6.30	6.77	18.0	20.2
August	0.00	1.35	0.05	0.00	14.66	5.71	6.90	20.3	22.0
September	0.00	1.56	0.04	0.01	14.48	6.00	6.51	19.8	22.4
October	0.00	2.66	0.05	0.01	16.70	5.50	6.80	17.1	21.7
November	0.01	4.53	0.02	0.01	15.96	6.20	6.98	15.1	18.6
December	0.01	6.36	0.02	0.00	13.75	6.20	6.99	12.8	16.7
Average	0.00	2.19	0.07	0.00	13.95				
Minimum	0.00	1.02	0.02	0.00	12.11	5.50		10.2	
Maximum	0.01	6.36	0.19	0.01	16.70		7.52		22.4
ECA Requirement				0.04					
ECA Objective				0					
Within Compliance				Yes					
Sampling Frequency Requirement Met		Yes		Yes	Yes	Yes	Yes	Yes	Yes



Table 4 Escherichia Coliform Sampling

Month	Number of Samples	Geometric Mean Density
January	4	50
February	4	103
March	5	8
April	4	6
May	5	0
June	4	48
July	4	17
August	5	13
September	4	0
October	4	0
November	5	0
December	4	0
ECA Requirement		N/A
ECA Objective		200
Within Compliance		N/A
Sampling Frequency Requirement Met	Yes	



Table 4(a) Summary of the Faecal Streptococcus sampling

Month	Number of Samples	Geometric Mean Density
January	2	155
February	2	90
March	2	10
April	2	25
May	2	9
June	2	80
July	2	26
August	2	187
September	2	259
October	2	152
November	2	17
December	2	11
ECA Requirement		N/A
ECA Objective		N/A
Within Compliance		N/A
Sampling Frequency Requirement Met	Yes	



Table 4(b) Summary of the Total Coliform sampling

Month	Number of Samples	Geometric Mean Density
January	2	1,296
February	2	620
March	2	99
April	2	962
May	2	62
June	2	1,022
July	2	794
August	2	1,032
September	2	4
October	2	83
November	2	95
December	2	26
ECA Requirement		N/A
ECA Objective		N/A
Within Compliance		N/A
Sampling Frequency Requirement Met	Yes	



Table 5 Sludge Quality and Disposal

Month	Avg. Sludge TS (%)	Total Volume Removed (m ³)	Total Volume Hauled to Courtice WPCP (m ³)	Total Volume Hauled to Duffin Creek WPCP (m ³)
January	2.99	532	532	0
February	3.05	570	570	0
March	3.30	564	564	0
April	2.76	572	572	0
May	1.83	572	572	0
June	3.82	648	648	0
July	1.99	568	568	0
August	1.73	612	612	0
September	1.42	610	610	0
October	1.87	528	528	0
November	2.62	572	572	0
December	2.37	608	608	0
Total		6,956	6,956	0
Average	2.48	580	580	0



Table 6 Energy and Chemical Usage

Month	Total Plant Flow (cubic metres)	Alum (litres)	Sodium Hypochlorite (kilograms as chlorine)	Sodium Bisulphite (Litres)	Hydro (kWh)	Natural Gas (cubic metres)
January	116,673	6,556	513	4,984	74,864	16,616
February	97,148	6,135	444	3,027	103,893	16,732
March	118,647	6,410	463	3,330	98,291	18,512
April	103,436	6,223	402	3,801	96,254	8,738
May	79,882	6,356	454	2,855	88,105	4,069
June	71,506	6,134	373	2,474	84,540	262
July	67,451	6,494	272	2,247	90,143	236
August	68,376	7,117	810	2,280	97,782	256
September	64,939	8,397	942	2,653	93,708	239
October	64,224	7,324	428	2,606	98,291	7,226
November	61,953	7,749	266	2,612	89,124	10,375
December	74,033	7,725	288	2,647	112,042	19,235
Total	988,268	41,822	3,278	15,115	1,127,037	102,496



Table 7 Summary of the raw Water Bacteriological analyses at the Newcastle Water Supply Plant

Month	E.coli cfu/100ml (min-max result)	E.coli (number of samples)	Total Coliform cfu/100ml (min-max result)	Total Coliform (number of samples)
January	<1-4	16	<1-480	16
February	<1	16	<1-68	16
March	<1-1	18	<1- 48	18
April	<1	16	<1-1	16
May	<1	17	<1-25	17
June	<1	18	<1-10	18
July	<1-1	16	<1-24	16
August	<1-3	18	<1-37	18
September	<1-1	16	1-1400	16
October	<1-1	16	<1-8	16
November	<1-1	18	<1-2	18
December	<1-1	15	<1-11	15



Glossary of Terms

Aeration tank

An aeration tank is a vessel in which a biological process is carried out which involves bacterial organisms or biochemically active substances derived from such organisms. This encompasses a combination of aerobic and anoxic processes.

Anaerobic digestion

Is a series of biological processes in which microorganisms break down biodegradable material in the absence of oxygen.

Average Concentration

The arithmetic mean concentration of a parameter within a specified period of operation.

Average Daily Flow

The total volume of sewage flow to the plant over twelve consecutive calendar months divided by the number of days over the same period of time.

BOD₅ - Five day Biochemical Oxygen Demand

(also known as total BOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

A diversion of sewage around one or more unit processes within the Sewage Treatment Plant with the diverted sewage flows being returned to the Sewage Treatment Plant treatment train upstream of the Final effluent sampling location, and discharging to the environment through the Sewage Treatment Plant outfall.

CBOD₅ -Five day Carbonaceous Biochemical Oxygen Demand

A five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample.

conc. – Concentration

A measure of the amount of dissolved substance contained per unit of volume.

DP – Dissolved Phosphorus

This is the soluble form of phosphorus present in the wastewater.

Denitrification -

The biological process of nitrate reduction to nitrogen gases occurring in low dissolved oxygen environments.

ECA

Environmental Compliance Approval. The primary governing document for each WPCP.

E. coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius. Calculated using a monthly geometric mean density.

Final Effluent

sewage discharge via the Sewage Treatment Plant outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.



Geometric mean density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, a snapshot of the conditions at the time the sample was retrieved.

Loading

Volume of a parameter that is present in a given volume of wastewater, is calculated by multiplying the annual average concentration by the average daily flow as kg/day.

m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metre Per Day)

Flow measurement, 1m³ = 1000 litres or 220 imperial gallons. Volume of liquid treated in a day.

Max. – Maximum

The peak or highest value recorded during a specific time period usually in a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.

Mg/L - (Milligram Per Litre)

This is a measure of the concentration of a parameter in water, sometimes referred to as parts per million (ppm).

Min. – Minimum

The lowest value recorded during a specific time period usually in a day.

mm.- (millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.

MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly average concentration

Calculated as an arithmetic mean of all daily concentrations analyzed for the month.

Monthly average loading

Calculated by multiplying the monthly average concentration by the monthly average daily flow.

N/A - Not applicable

NH₃ – Unionized Ammonia

Is a compound of nitrogen and hydrogen with the formula NH₃. It is a colourless gas with a characteristic pungent smell

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. A solution of pH from 0-7 is acidic, 7 is neutral, and 7-14 is alkaline.



Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Rated Capacity

The average daily flow for which the works is approved to handle.

Septage

Partially treated sludge from a septic tank.

Sludge

A Semi-solid material that is produced as a by-product during sewage treatment. Similar to biosolids.

TAN -Total Ammonia Nitrogen

Ammonia exists in two forms in the water: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

TCR -Total Chlorine Residual

The sum of the free and combined chlorine residual

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.

Total loading

Calculated by multiplying the average concentration by the average flow.

TP -Total Phosphorus

A laboratory analyses to determine the total amount of particulate and soluble phosphorus present in the wastewater.

TSS -Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS -Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Un-ionized Ammonia nitrogen

Calculated using the methodology specified in the MOECC's Guideline and Policies document titled "Provincial Water Quality Objectives" (July 1994).

WPCP - Water Pollution Control Plant

Is typically a facility composed of a variety of treatment processes that collectively treat the wastewater.

If this information is required in an accessible format, please contact 1-800-372-1102 extension 3488



**Nonquon Water Pollution Control Plant
Annual Performance Report 2016**





The Regional Municipality of Durham

Nonquon Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 2207-9LKHLM Dated July 17, 2014
4143-7NCKSG Dated June 18, 2009

The Nonquon Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers an overview of the performance of the Nonquon WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

Water Pollution Control Plant Process Description

General

The Nonquon WPCP located in the Community of Port Perry in the Township of Scugog is owned and operated by the Regional Municipality of Durham. The plant is operated according to the terms and conditions of the ECA. This MOECC Class Two wastewater treatment plant is designed to treat wastewater at an average flow rate of 3,870 cubic metres per day (m³/d) utilizing two aerated lagoon cells and six seasonal facultative retention ponds. The Nonquon WPCP has a service population of 8,157 residents. The treated effluent is discharged to the Nonquon River in accordance with the conditions listed in the ECA.

Raw Influent

Wastewater is collected through approximately 48.7 km of sanitary sewers in the Port Perry service area and is conveyed to the Nonquon WPCP by three sanitary sewage pumping stations: Water Street Pumping Station, Reach Street Pumping Station and Canterbury Common Pumping Station. Additional flow is added to the forcemain by two private pumping systems: a recreational complex and a small lakefront community of 16 individual homes. Aluminum sulphate is added at the Water Street Pumping Station to enhance the settling of solids and phosphorus removal.

Lagoon Treatment

Aerated Cells

Influent wastewater enters the Nonquon WPCP through the aerated cell inlet chamber where the flow is split and directed into two aerated cells. These cells are aerated by mechanical surface aerators to mix the contents and provide oxygen to maintain biological activity.

Seasonal Retention Ponds

Partially treated wastewater from the aerated cells flows by gravity to cell number six for solids settling. The flow from cell number six is transferred through a distribution chamber to one of the five retention stabilization lagoons. The ECA permits discharge ten months of the year excluding July and



August. Prior to and during discharging to the Nonquon River samples are collected to verify the effluent meets the limits established in the ECA.

Environmental Compliance Approval

Under Condition 10 (6) of ECA #2207-9LKHLM the Region of Durham must produce an annual performance report that must contain the following information:

a) Summary and interpretation of all monitoring data and a comparison to the effluent limits

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the plant's ECA.

The Nonquon WPCP effluent was determined to be compliant with the approval limits during the reporting period. The plant operated at 63.9% of its rated capacity and received a maximum daily flow of 6,927 m³/d on April 1, 2016. The total treated effluent discharged to the Nonquon River in 2016 was 846,328 m³.

b) Description of any operating problems encountered and corrective actions taken

No operating problems were encountered in 2016.

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the works

No maintenance was performed on major equipment during the reporting period.

d) Summary of any effluent quality assurance or control measures undertaken in the reporting period

In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. Results were found to be in a comparable range.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment

- Calibration of the influent flow meter was conducted in June and November, 2016.
- Temperature and pH are monitored in the field, all other routine process control tests are performed at the Uxbridge Brook WPCP laboratory in Uxbridge. All monitoring and laboratory equipment is calibrated and maintained according to manufacturer's specifications.

f) Description of efforts made and results achieved in meeting the effluent objectives of Condition 6

- The Regional Municipality of Durham strives to achieve the best effluent quality at all times, remaining below the ECA compliance limits.
- All effluent objectives were met in 2016 except for:
The effluent objective for total phosphorus was exceeded in two of 150 samples (1.3%).
The effluent objective for total suspended solids was exceeded in nine of 152 samples (5.9%). To assist in total suspended solids and total phosphorus removal, the aluminum



sulphate dosage at the Water Street sanitary sewage pumping station was increased and additional aluminum sulphate was added to the lagoons.

The effluent objective for total ammonia nitrogen was exceeded in 78 of 152 samples (51.3%). The removal of total ammonia nitrogen is difficult to achieve in a lagoon treatment system. The new Nonquon WPCP activated sludge and tertiary treatment plant is expected to be commissioned in the winter of 2017

- All effluent flows met the flow objectives with the exception of June where an emergency discharge request to increase effluent flows was approved by the MOECC.
- Best efforts will continue to be applied to maintain results below objectives.

g) Tabulation of the volume of sludge generated

The annual depletion of the sludge settling capacity is negligible. There was no removal of biosolids during the reporting period.

h) Summary of any complaints received during the reporting period and any steps taken to address the complaint

A summary of complaints received from the public is administered through a central database. There were no complaints received in 2016.

i) Summary of all By-pass, Spill or Abnormal Discharge Events

No by-passes or spills occurred during the reporting period.

Additional Discharge

The Region of Durham requested an emergency discharge to increase the treated effluent discharge rate to 8,200m³/day during the month of June. The MOECC approved an increased discharge rate in a letter dated May 19, 2016.

j) Copy of all Notice of Modifications and any implementation of Limited Operational Flexibility(Schedule B)

No notice of modifications were submitted in 2016.

k) Report summarizing modifications(Schedule B)

There were no modifications to the plant during the reporting period..

l) Information required by MOECC Water Supervisor

No additional information was requested.

MOECC Inspection

This plant was not inspected by the MOECC in 2016.



**Nonquon Water Pollution Control Plant
Annual Performance Report 2016**

Table 1 Raw Influent Flows

Month	Total Flow to Plant -metered at lagoon inlet m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d
January	88,125	2,843	4,949
February	82,184	2,834	3,498
March	108,129	3,488	6,017
April	109,321	3,644	6,927
May	76,392	2,464	2,820
June	65,054	2,168	2,473
July	61,249	1,976	2,228
August	60,386	1,948	2,314
September	60,122	2,004	2,230
October	61,701	1,990	2,122
November	61,296	2,043	2,240
December	71,125	2,294	3,085
Total	905,086		
Annual Average	75,424	2,473*	
Minimum	60,122		
Maximum	109,321		6,927
ECA Requirement		3870*	
Met Compliance		Yes	

*Annual Average



Nonquon Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses

Month	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg conc. mg/L	TSS loading kg/d	TP avg conc. mg/L	TP loading kg/d
January	161	456	206	586	3.3	9
February	141	400	198	561	2.7	8
March	150	522	161	560	2.4	8
April	113	413	179	651	3.1	11
May	159	392	165	407	3.4	8
June	240	521	265	576	4.4	10
July	223	441	180	355	3.5	7
August	225	438	189	369	4.5	9
September	228	457	240	482	4.7	9
October	279	555	251	499	4.6	9
November	242	494	241	493	5.3	11
December	154	354	222	509	4.5	10
Average	193	477	208	515	3.9	10
Minimum	113	354	161	355	2.4	7
Maximum	279	555	265	651	5.3	11
Sampling Frequency Requirement Met	Yes		Yes		Yes	



**Nonquon Water Pollution Control Plant
Annual Performance Report 2016**

Table 2 Raw Influent Analyses continued

Month	DP avg. conc. mg/L	TKN avg. conc. mg/L	TKN loading kg/d
January	0.7	36.60	104
February	0.3	35.65	101
March	0.3	28.72	100
April	0.2	30.85	112
May	0.9	38.48	95
June	1.3	48.24	105
July	0.7	44.48	88
August	1.0	46.28	90
September	1.0	48.43	97
October	1.2	46.20	92
November	1.6	51.34	105
December	1.6	46.20	106
Average	0.9	41.79	103
Minimum	0.2	28.72	88
Maximum	1.6	51.34	112
Sampling Frequency Requirement Met		Yes	



**Nonquon Water Pollution Control Plant
Annual Performance Report 2016**

Table 3 Final Effluent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading avg. kg/d	TSS avg. conc. mg/L	TSS loading avg. kg/d	TP avg. conc. mg/L	TP loading avg. kg/d	DP avg. conc. mg/L
January	4.0	14.4	5.8	20.8	0.07	0.266	0.01
February	5.5	16.7	9.7	29.4	0.13	0.408	0.01
March	6.5	17.2	7.9	21.0	0.17	0.452	0.33
April	3.1	13.3	6.2	26.5	0.07	0.304	0.01
May	1.8	2.0	2.3	2.6	0.05	0.055	0.01
June	3.4	23.5	3.0	21.2	0.09	0.647	0.02
July							
August							
September	1.3	3.0	3.2	7.2	0.05	0.106	0.01
October	2.7	8.8	6.3	20.9	0.13	0.422	0.03
November	3.9	15.5	4.5	17.6	0.06	0.244	0.01
December	2.0	2.8	3.5	5.0	0.03	0.043	0.03
Average	3.4	11.6	5.2	17.7	0.09	0.290	0.05
Minimum	1.3	2.0	2.3	2.6	0.03	0.043	0.01
Maximum	6.5	23.5	9.7	29.4	0.17	0.647	0.33
ECA Limit	10*	37.1**	12.0*	44.5**	0.3***	1.1**	
ECA Objective	8.0		11.0		0.21		
Within Compliance	Yes	Yes	Yes		Yes	Yes	
Sampling Frequency Requirement Met	Yes		Yes		Yes	Yes	

*Annual Average Concentration

**Annual Average Loading, kg/day

***Monthly Average Concentration



**Nonquon Water Pollution Control Plant
Annual Performance Report 2016**

Table 3 Final Effluent Analyses continued

Month	TAN avg. conc. mg/L	TAN loading ave kg/d	TKN avg. conc. mg/L	Un-ionized ammonia avg. conc. mg/L	pH min.	pH max.	Temp. °C min.	Temp. °C max.
January	5.40	19.4	7.75	0.0	6.12	8.39	1.4	3.9
February	17.54	53.1	24.60	0.2	6.40	8.49	3.4	6.1
March	16.72	44.3	19.30	0.0	6.28	7.37	4.8	6.9
April	10.11	43.0	9.64	0.1	6.98	8.50	3.8	14.6
May	4.31	4.8	5.10	0.0	6.54	8.00	10.4	21.7
June	1.84	12.8	3.38	0.0	7.16	8.87	16.4	23.1
July								
August								
September	0.51	1.1	1.76	0.0	6.50	8.60	14.8	24.6
October	5.56	18.6	6.79	0.1	7.00	7.78	6.8	18.5
November	3.28	12.9	4.74	0.0	6.91	8.03	7.1	15.6
December	4.20	5.9	5.12	0.0	7.54	8.13	1.5	6.8
Average	6.95	23.4	8.82	0.1				
Minimum	0.51	1.1	1.76	0.0	6.12		1.4	
Maximum	17.54	53.1	24.60	0.2		8.87		24.6
ECA Limit					6.0	9.5		
ECA Objective	Refer to Table 4	Refer to Table 4			6.0	9.5		
Within Compliance					Yes	Yes		
Sampling Frequency Requirement Met	Yes				Yes	Yes	Yes	Yes



Table 4 Effluent Objectives for Total Ammonia Nitrogen

Month	TAN Effluent Objective conc. mg/L
January	8.4
February	8.6
March	8.6
April	7.8
May	2.4
June	2.1
July	
August	
September	2.3
October	3.4
November	5.7
December	7.9



Table 5 Effluent Discharge Flows

Month	Total Flow Discharged metered at outlet m ³	Monthly Max Objective m ³	Daily Average Discharge m ³	Daily Maximum Discharge m ³	Maximum Daily Flow Objective m ³ /d
January	100,387	130,000	3,585	4,085	4,600
February	72,675	100,000	3,028	3,618	3,900
March	50,330	130,000	2,649	4,221	4,600
April	127,690	150,000	4,256	5,412	5,500
May	34,710	40,000	1,120	1,235	1,400
June	209,058	70,000	6,969*	7,472*	2,600
July					
August					
September	68,029	70,000	2,268	2,411	2,600
October	103,514	145,000	3,339	4,579	5,100
November	63,127	290,000	3,945	8,944	10,700
December	16,808	230,000	1,401	4,356	8,200
Total	846,328	1,355,000			

*Additional Discharge Approved



Table 6 Energy and Chemical Usage

Month	Aluminum Sulphate (m³)	Hydro kWh
January	18.8	36,032
February	18.4	55,130
March	26.5	51,055
April	25.1	42,270
May	17.5	51,310
June	14.8	42,143
July	12.8	40,870
August	12.9	32,085
September	11.4	32,084
October	11.0	27,119
November	11.6	27,119
December	12.7	31,703
Total	193.5	468,920



Glossary of Terms

Annual Average Concentration

An arithmetic mean of the monthly average concentrations of a contaminant in the effluent calculated for any particular year.

Annual Average Loading

The value obtained by multiplying the annual average concentration of a contaminant by the Average Daily Flow over the same calendar year.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

Biosolids

Organic material recovered from wastewater sludge.

BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

A diversion of sewage around one or more unit processes within the water pollution control plant with the diverted sewage flows being returned to the water pollution control plant treatment train upstream of the final effluent sampling location, and discharging to the environment through the water pollution control plant outfall.

CBOD₅ -Five Day Carbonaceous Biochemical Oxygen Demand

Means a five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample.

Conc. Concentration

The abundance of a constituent divided by the total volume of a mixture.

Daily Concentration

The concentration of a contaminant in the effluent discharged over any single day, as measured by a composite or grab sample, whichever is required.

DP – Dissolved Reactive Phosphorus

This is the soluble form of phosphorus present in the wastewater.

ECA Environmental Compliance Approval

The primary regulatory instrument for each water pollution control plant.



Final Effluent

Sewage discharge via the water pollution control plant outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.

Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, when tested provides a snapshot of the conditions at the time the sample was retrieved.

kg - kilogram

Basic unit of mass in the metric system.

kg/d – kilogram per day

m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metre Per Day)

Flow measurement, 1m³ = 1000litres or 220 imperial gallons. Volume of liquid treated in a day.

Max. – Maximum

The peak or highest value recorded during a specific time period usually a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.

mg/L. - (Milligram Per Litre)

This is a measure of the concentration of a parameter in water, sometimes referred to as parts per million (ppm).

Min. – Minimum

The lowest value recorded during a specific time period usually in a day.

mm.-(millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.

MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.



Monthly Average Concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.

Monthly Average Loading

Is calculated by multiplying the monthly average concentration of a contaminant in the effluent sampled or measured, or both, during a calendar month.

N/A - Not Applicable

N/D - No Discharge

Peak Flow Rate

The maximum rate of sewage flow for which the plant or process unit was designed.

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.

Rated Capacity

The average daily flow for which the works are approved to handle.

Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Seasonal Average Concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured or both during the seasonal discharge period.

Sludge

The settleable solids separated from liquids during processing.

TAN - Total Ammonia Nitrogen

Ammonia exists in two forms in the water: NH₃ (this is called unionized ammonia) NH₄⁺ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.

Total Annual Loading

Is calculated by summarizing the total monthly loadings within a calendar year.



Total Monthly Loading

Is calculated by multiplying the total monthly flow by the monthly average concentration.

TP - Total Phosphorus

A laboratory analyses to determine the total amount of non-soluble and soluble phosphorus present in the wastewater.

TSS - Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS - Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Unionized Ammonia Nitrogen

Un-ionized ammonia refers to all forms of ammonia in water with the exception of the ammonium ion (NH_4^+).

WPCP - Water Pollution Control Plant

A facility composed of a variety of treatment processes that collectively treat wastewater.

If this information is required in an accessible format, please contact 1-800-372-1102 extension 3488



Port Darlington Water Pollution Control Plant Annual Performance Report 2016





The Regional Municipality of Durham

Port Darlington Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 0114-8S8RTA Dated April 24, 2012

Environmental Compliance Approval (Air): 2242-8TFNN3 Dated June 19, 2012

The Port Darlington Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers a performance overview of the Port Darlington WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

Water Pollution Control Plant Process Description

General

The Port Darlington WPCP is located in the Municipality of Clarington (Bowmanville) and is owned and operated by the Regional Municipality of Durham. The plant is operating according to the terms and conditions of the ECA.

Port Darlington WPCP treats wastewater from the Bowmanville service area in the Regional Municipality of Durham. The Port Darlington WPCP has been undergoing construction in order to provide additional capacity. Two new process trains have been added as of November 2015 and are treating all incoming wastewater. The four existing trains were removed from service for refurbishment before substantial completion can be granted. The Port Darlington WPCP services 40,115 residents.

The Port Darlington WPCP is designed to treat wastewater at an average daily flow rate of 13,638 cubic metres per day (m^3/d) with an increased rating of 27,276 m^3/d once the plant expansion is completed and substantial completion is recognized. The plant is an MOECC Class Three conventional activated sludge treatment plant that utilizes the following processes to treat wastewater:

- raw influent pumping,
- preliminary treatment,
- primary treatment,
- secondary treatment,
- phosphorus removal,
- disinfection (chlorination/dechlorination),
- solids treatment.



Raw Influent Pumping

Wastewater is collected through approximately 140 km of sanitary sewers in Bowmanville and is conveyed to the Port Darlington WPCP by gravity to a sanitary sewage pumping station located at the WPCP.

Preliminary Treatment

Screening: Two automatic, mechanically cleaned screens remove paper products and large material that could harm pumps and process equipment. Screenings removed in this process are compacted for landfill disposal.

Grit Removal: Heavy suspended material such as sand and small stones (grit) is removed in the two vortex grit tanks. The velocity of the wastewater swirling in the tanks is controlled by the velocity of influent flow to allow heavy grit material to settle, while keeping the lighter organic material in suspension to proceed to the next process tank. The grit removed in this process is dewatered and transported to landfill.

Primary Treatment

The two primary clarifiers utilize the physical process of sedimentation which allows suspended material to settle to the bottom of the tank as sludge. This raw sludge, along with excess activated sludge from the secondary treatment process is collected by a flight and chain mechanism which pushes the sludge into hoppers. The sludge is then pumped to the anaerobic digesters for further treatment. Any material floating on the surface of the clarifier (scum) is also removed to the digester.

Secondary Treatment

Aerated Bioreactor: The bioreactors are comprised of two distinct sections. The first section is an anoxic zone, where no oxygen is introduced and allows for potential denitrification. Subsequently, the flow leaves the anoxic zone and enters the aerated zone where fine bubbled air is diffused into the sewage to assist bacteria in removing dissolved and suspended organics, and nutrients from the wastewater. Biological activity is controlled to assimilate the organic material.

Secondary Clarifier: The effluent from the bioreactors is directed to the two secondary clarifiers where the solids settle quickly to the bottom as activated sludge leaving clear supernatant. A portion of the activated sludge collected on the bottom of the clarifier is pumped back to the head of the bioreactors and the excess activated sludge is wasted to the primary clarifiers.

Phosphorus Removal

The phosphorous removal system is intended to lower the total phosphorous level in the final effluent by adding a chemical coagulant (ferrous chloride). Ferrous chloride can be added at multiple locations throughout the WPCP.

Disinfection (chlorination/dechlorination)

Chlorine in the form of liquid sodium hypochlorite is metered into the secondary effluent stream for pathogen control. Adequate contact time is provided by the single chlorine contact chamber. Disinfected effluent is dechlorinated with a sodium bisulphite solution before being discharged through the 1,350 mm diameter outfall extending 1,100 meters into Lake Ontario.



Solids Treatment

Anaerobic Digestion: The raw sludge that is collected from the primary clarifiers is pumped into the anaerobic digesters where anaerobic bacteria reduce the volume of sludge. The primary digester is currently being used as a sludge holding tank until the plant upgrades are completed.

Biosolids management: All sludge produced at the Port Darlington WPCP is hauled to either the Harmony Creek WPCP, the Courtice WPCP or the Duffin Creek WPCP for further processing. Sludges are transported plant to plant in accordance with ECA #A820250.

Environmental Compliance Approval

Under Condition 10 (6) of ECA #0114-8S8RTA the Region of Durham must produce an annual report that contains the following information:

a) Summary and interpretation of all monitoring data and a comparison to the effluent limits, including an overview of the success and adequacy of the Works;

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA. Table 2 summarizes the raw wastewater characteristics during the reporting period.

The Port Darlington WPCP effluent was determined to be compliant with the ECA approval limits during the reporting period. The plant operated at an average of 81% of its annual average rated flow capacity based on the existing pre-construction plant capacity and received a maximum daily flow of 29,294 m³/d on January 11, 2016. See tables 3 and 4 for effluent results.

b) Description of any operating problems encountered and corrective actions taken:

There were no operating problems encountered in 2016.

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the Works;

- Due to the construction, no major maintenance was completed outside of the expansion and refurbishment scope of work.

d) Summary of any effluent quality assurance or control measures undertaken in the reporting period;

- In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. All results were found to be within a comparable range.
- On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment;

- The new raw influent flow meter was not calibrated in 2016 due to the ongoing construction during the plant expansion project.
- Calibration of the AutoCat 9000 chlorine analyzer was conducted July 28th 2016.



- Calibration of the in-house lab pH meter is conducted regularly.

f) A description of efforts made and results achieved in meeting the Effluent Objectives;

The Regional Municipality of Durham continually strives to achieve the best effluent quality at all times, remaining below the ECA compliance limits.

The annual average daily flow did not exceed the rated capacity of 13,638 m³/d during the reporting period.

The pH objective of not less than 6.5 was exceeded 17 of 311 samples (5.5%). The pH meter was calibrated regularly.

The total suspended solids objective of 15 mg/L was exceeded on one of 12 monthly results (8%) with a monthly average result of 15.9 mg/L.

Best efforts and process adjustments will continue to be applied to maintain results below objectives.

g) A tabulation of the volume of sludge generated in the reporting period, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed:

The volume of sludge removed from Port Darlington WPCP in 2016 was 31,344 m³.

Outline of anticipated volumes to be generated in the next reporting period:

There is a 30% reduction of sludge volume expected in the next reporting period due to new digesters being on-line.

Summary of locations to where sludge was disposed:

Duffin Creek WPCP – 2,032 m³ or 6.5%

Harmony Creek WPCP – 16,164 m³ or 51.6%

Courtice WPCP – 13,148 m³ or 41.9%

h) Summary of any complaints received during the reporting period and any steps taken to address the complaints:

There were no documented complaints received about the Port Darlington WPCP in 2016.

i) A summary of all By-pass, Spills or abnormal discharge events;

There were no by-passes during the reporting period. There are no anticipated by-passes planned during the next reporting period.

There were no spills during the reporting period.

MOECC Inspection

No MOECC inspection occurred in 2016.



Port Darlington Water Pollution Control Plant
Annual Performance Report 2016

Table 1 Influent Flows

Month	Total Flow to Plant -metered at the final effluent m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d
January	402,805	12,994	29,294
February	339,098	11,693	16,682
March	408,629	13,182	17,038
April	444,970	14,832	25,476
May	358,434	11,562	13,751
June	308,732	10,291	12,503
July	300,629	9,698	11,109
August	306,499	9,887	11,330
September	286,002	9,533	11,329
October	273,108	8,810	10,326
November	296,462	9,882	11,144
December	308,149	9,940	14,561
Total	4,033,516		
Average	336,126	11,051*	
Minimum	273,108		
Maximum	444,970		29,294
ECA Requirement		13,638	
Met Compliance		Yes	

*Annual Average Daily Flow



**Port Darlington Water Pollution Control Plant
Annual Performance Report 2016**

Table 2 Raw Influent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ avg. loading kg/d	BOD ₅ avg. conc. mg/L	BOD ₅ avg. loading kg/d	TSS avg. conc. mg/L	TSS avg. loading kg/d	TP avg. conc. mg/L	TP avg. loading kg/d
January	111	1,436	143	1,857	261	3,395	3.8	50
February	138	1,611	188	2,201	248	2,896	4.7	55
March	103	1,352	149	1,967	219	2,887	3.7	49
April	107	1,590	149	2,214	249	3,693	4.1	60
May	133	1,538	187	2,160	297	3,430	4.9	56
June	288	2,964	396	4,075	840	8,641	5.3	55
July	262	2,541	334	3,237	853	8,276	5.5	53
August	151	1,495	195	1,923	328	3,247	7.2	71
September	171	1,628	252	2,400	487	4,645	8.6	82
October	329	2,896	448	3,942	939	8,277	5.9	52
November	402	3,975	476	4,706	857	8,465	5.8	58
December	198	1,972	239	2,378	497	4,941	5.4	53
Average	199	2,203	263	2,906	506	5,595	5.4	60
Minimum	103	1,352	143	1,857	219	2,887	3.7	49
Maximum	402	3,975	476	4,706	939	8,641	8.6	82
Sampling Frequency Requirement Met			Yes		Yes		Yes	



**Port Darlington Water Pollution Control Plant
Annual Performance Report 2016**

Table 2 Raw Influent Analyses continued

Month	DP avg. conc. mg/L	TKN avg. conc. mg/L	TAN avg. conc. mg/L	TAN avg. loading kg/d	pH min.	pH max.
January	1.61	34.70	22.5	292	7.10	8.00
February	1.82	41.35	26.0	304	7.10	8.09
March	1.47	35.68	23.3	307	6.80	8.00
April	1.93	37.88	22.5	334	7.02	8.07
May	1.73	44.64	28.9	334	7.18	7.97
June	1.99	51.53	32.7	337	7.00	7.89
July	2.49	48.55	35.1	341	7.10	8.10
August	2.68	51.14	36.8	364	7.08	7.99
September	4.35	70.98	50.9	486	7.10	8.20
October	3.20	63.15	26.4	232	7.31	8.50
November	2.10	51.88	36.2	358	7.00	8.60
December	2.14	46.73	36.1	359	7.28	8.50
Average	2.29	48.18	31.4	348		
Minimum	1.47	34.70	22.5	232	6.80	
Maximum	4.35	70.98	50.9	486		8.60
Sampling Frequency Requirement Met		Yes	Yes		Yes	Yes



Table 3 Final Effluent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ avg. loading kg/d	TSS avg. conc. mg/L	TSS avg. loading kg/d	TP avg. conc. mg/L	TP avg. loading kg/d	TAN avg. conc. mg/L	TAN avg. loading kg/d
January	4.8	62.7	11.3	146.9	0.55	7.09	0.34	4.44
February	5.7	66.9	10.6	124.5	0.66	7.68	0.58	6.77
March	5.3	69.3	9.3	122.0	0.51	6.75	0.45	5.92
April	3.7	54.5	6.9	102.7	0.60	8.83	0.53	7.92
May	3.9	45.6	6.4	73.8	0.83	9.60	0.52	5.99
June	4.6	47.1	8.3	85.2	0.74	7.60	0.19	1.98
July	4.5	43.9	8.7	84.4	0.49	4.77	0.27	2.64
August	3.8	37.8	10.0	99.1	0.36	3.60	0.20	1.93
September	4.3	40.8	15.9	151.4	0.81	7.72	0.83	7.95
October	4.9	42.9	11.6	102.3	0.83	7.29	0.30	2.61
November	4.1	40.1	9.0	88.6	0.43	4.20	0.28	2.80
December	4.7	47.0	7.7	76.4	0.46	4.58	1.30	12.94
Average	4.5	49.9	9.6	106.5	0.60	6.68	0.48	5.34
Minimum	3.7	37.8	6.4	73.8	0.36	3.60	0.19	1.93
Maximum	5.7	69.3	15.9	151.4	0.83	9.60	1.30	12.94
ECA Requirement	25.0		25.0		1			
ECA Objective	15.0		15.0		1		14	
Within Compliance	Yes		Yes		Yes			
Sampling Frequency Requirement Met	Yes		Yes		Yes		Yes	



**Port Darlington Water Pollution Control Plant
Annual Performance Report 2016**

Table 3 Final Effluent Analyses continued

Month	Unionized NH ₃ avg. conc. mg/L	TKN avg. conc. mg/L	DP avg. conc. mg/L	TCR avg. conc. mg/L	TCR avg. loading kg/d	pH min.	pH max.	Temp. °C min.	Temp. °C max.
January	0.00	2.43	0.26	0.01	0.18	6.40	7.60	10.3	12.6
February	0.00	3.25	0.34	0.01	0.07	6.50	7.77	6.6	13.9
March	0.00	2.94	0.27	0.00	0.00	6.50	7.41	4.3	20.2
April	0.00	2.09	0.38	0.00	0.04	6.70	7.98	9.5	13.4
May	0.00	2.20	0.61	0.00	0.01	6.80	7.69	8.7	16.3
June	0.00	2.20	0.43	0.03	0.32	6.70	7.06	10.1	18.9
July	0.00	1.87	0.23	0.00	0.05	6.70	7.40	11.0	20.5
August	0.00	1.89	0.13	0.00	0.05	6.70	7.28	11.7	28.0
September	0.00	3.68	0.49	0.01	0.06	5.96	7.40	10.8	21.9
October	0.00	2.31	0.54	0.02	0.16	6.30	7.20	13.6	21.9
November	0.00	1.71	0.21	0.00	0.03	6.20	7.50	11.3	20.9
December	0.00	3.21	0.29	0.00	0.05	6.36	7.60	7.3	18.0
Average	0.00	2.48	0.35	0.01	0.09				
Minimum	0.00	1.71	0.13	0.00	0.00	5.96		4.3	
Maximum	0.00	3.68	0.61	0.03	0.32		7.98		28.0
ECA Requirement						5.5	9.5		
ECA Objective				0.5		6.5	9.0		
Within Compliance						Yes	Yes		
Sampling Frequency Requirement Met	Yes			Yes		Yes	Yes	Yes	



Table 4 Escherichia Coliform Sampling

Month	Number of Samples	Geometric Mean Density
January	4	184*
February	4	444*
March	5	3,208*
April	4	160
May	5	4
June	4	2
July	4	0
August	5	4
September	4	3
October	4	3
November	5	12
December	4	8
ECA Requirement		200*
ECA Objective		N/A
Within Compliance		N/A
Sampling Frequency Requirement Met	Yes	

NOTE: *ECA limit of 200 organisms per 100 ml is not required until the disinfection system upgrade is completed.



Table 5 Energy and Chemical Usage

Month	Total Plant Flow (cubic metres)	Ferrous Chloride (litres)	Sodium Hypochlorite (kilograms as chlorine)	Sodium Bisulphite (Litres)	Hydro (kWh)	Natural Gas (cubic metres)
January	402,805	26,258	753	978	296,524	35,444
February	339,098	26,378	258	451	272,686	40,520
March	408,629	26,378	-	-	279,732	25,787
April	444,970	21,222	1,032	1,842	269,925	22,419
May	358,434	20,623	1,699	1,316	269,740	10,056
June	308,732	28,177	1,161	1,354	239,494	1,500
July	300,629	29,735	1,026	1,579	221,399	671
August	306,499	33,572	1,011	1,824	215,616	932
September	286,002	24,340	1,054	1,842	208,539	1,728
October	273,108	30,934	933	1,466	220,922	3,569
November	296,462	50,598	796	1,354	233,900	22,252
December	308,149	32,013	946	1,278	270,236	33,523
Total	4,033,516	350,228	10,669	15,284	2,998,713	198,401



Table 6 Summary of Raw Water Bacteriological Analyses at the Bowmanville Water Supply Plant

Month	E.coli cfu/100ml (min-max result)	E.coli (number of samples)	Total Coliform cfu/100ml (min-max result)	Total Coliform (number of samples)
January	<1	16	<1-12	16
February	<1	16	<1-5	16
March	<1	18	<1-16	18
April	<1-2	16	<1-18	16
May	<1-1	17	<1-16	17
June	<1-1	18	<1-19	18
July	<1-1	16	<1-67	16
August	<1-1	18	<1-35	18
September	<1-2	16	1-93	16
October	<1-2	16	<1-14	16
November	<1	18	<1-3	18
December	<1-1	15	<1-30	15



Glossary of Terms

Aeration Tank

A vessel in which a biological process is carried out which involves bacterial organisms or biochemically active substances derived from such organisms. This encompasses a combination of aerobic, anoxic, and anaerobic processes.

Anaerobic Digestion

Is a series of biological processes in which microorganisms break down biodegradable material in the absence of oxygen.

Annual Average Concentration

An arithmetic mean of the monthly average concentrations of a contaminant in the effluent calculated for any particular year.

Annual Average Loading

The value obtained by multiplying the Annual Average Concentration of a contaminant by the Average Daily Flow over the same calendar year.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

Biosolids

Organic material recovered from wastewater sludge.

BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

A diversion of sewage around one or more unit processes within the Sewage Treatment Plant with the diverted sewage flows being returned to the Sewage Treatment Plant treatment train upstream of the Final effluent sampling location, and discharging to the environment through the Sewage Treatment Plant outfall.

CBOD₅ -Five day Carbonaceous Biochemical Oxygen Demand

A five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample.

conc. – Concentration

A measure of the amount of dissolved substance contained per unit of volume.

DP – Dissolved Phosphorus

The soluble form of phosphorus present in the wastewater.

ECA - Environmental Compliance Approval

The primary regulatory instrument for each WPCP.

E. coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius.



Final Effluent

Sewage discharge via the Sewage Treatment Plant outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.

Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, a snapshot of the conditions at the time the sample was retrieved.

m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metres Per Day)

Flow measurement, 1m³ = 1000 litres or 220 imperial gallons. Volume of liquid treated in a day.

Max. – Maximum

The peak or highest value recorded during a specific time period usually in a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.

mg/L - (Milligram Per Litre)

A measure of the concentration of a parameter in water or wastewater, sometimes referred to as parts per million (ppm).

Min. – Minimum

The lowest value recorded during a specific time period usually in a day.

mm - (millimetre)

A unit of length in the metric system, equal to one thousandth of a metre.

MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly average concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.

Monthly average loading

Is calculated by multiplying the monthly average concentration of a contaminant in the effluent sampled or measured, or both, during a calendar month.

N/A - Not Applicable

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.



Rated Capacity

The average daily flow for which the works are approved to handle.

Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Septage

Partially treated sludge from a septic tank.

Sludge

The settleable solids separated from liquids during processing.

Substantial completion

Has the same meaning as “substantial performance” in the Construction Lien Act.

TAN -Total Ammonia Nitrogen

Ammonia exists in two forms in the water: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

TCR -Total Chlorine Residual

The total amount of chlorine in water, including the combined chlorine and the free available chlorine.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.

TP -Total Phosphorus

A laboratory analyses to determine the total amount of particulate and soluble phosphorus present in the wastewater.

TSS -Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS -Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Unionized Ammonia Nitrogen

Un-ionized ammonia refers to all forms of ammonia in water with the exception of the ammonium ion (NH_4^+).

Works

The sewage works described in the owner’s application, and the ECA, and includes both proposed works and previous works.

WPCP - Water Pollution Control Plant

Is typically a facility composed of a variety of treatment processes that collectively treat the wastewater.



Sunderland Water Pollution Control Plant Annual Performance Report 2016





The Regional Municipality of Durham

Sunderland Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 9252-8CUNBZ Dated June 28, 2012

The Sunderland Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers an overview of the performance of the Sunderland WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

General

The Sunderland WPCP located in the Community of Sunderland in the Township of Brock is owned and operated by the Regional Municipality of Durham. The plant is operated according to the terms and conditions of the ECA. This MOECC Class One wastewater treatment plant is designed to treat wastewater at a rated capacity of 632 cubic metres per day (m³/d) and utilizes a seasonal wastewater stabilization lagoon system. The Sunderland WPCP has a service population of 1,217 residents.

Raw Influent

Wastewater is collected through 7.7 km of sanitary sewers in the Sunderland service area and is conveyed to the treatment facility by a single sanitary sewage pumping station located on River Street.

Lagoon Treatment

The Sunderland WPCP is a two cell lagoon system where the influent raw sewage enters a retention stabilization lagoon and overflows into an exfiltration cell giving a combined retention time of approximately 182.5 days. The ECA permits two seasonal discharges per year. Spring discharge is for 20 days in May and fall discharge is for 20 days in November. Prior to and during discharge to the Beaver River, samples are collected to verify the effluent meets the limits established in the ECA.

Environmental Compliance Approval

Under Condition 9 (4) of ECA #9252-8CUNBZ the Region of Durham must produce an annual performance report that must contain the following information:

- a) **Summary and interpretation of all monitoring data and a comparison to the effluent limits outlined in Condition 5, including an overview of the success and adequacy of the works**

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA.

The Sunderland WPCP effluent was determined to be compliant with the approval limits during the reporting period. The plant operated at 63.1% of its rated capacity and received a



maximum daily flow of 921 m³/d on March 31, 2016. The total treated effluent discharged to the Beaver River in 2016 was calculated to be 82,142 m³.

b) Description of any operating problems encountered and corrective actions taken

The River Street Sanitary Sewage Pumping Station flow meter was found to be inaccurate in the fall of 2015. Replacement of the flow meter was completed in February 2016.

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the works

- A new Variable Frequency Drive was installed at River Street Pumping Station.
- A new radio alarm unit was installed at River Street Pumping Station.

d) Summary of any effluent quality assurance or control measures undertaken in the reporting period

In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. Results were found to be within a comparable range.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment

- Calibration of the influent flow meter located at River Street Pumping Station was conducted in May and November, 2016.
- Temperature and pH are monitored in the field, all other routine process control tests are performed at the Lake Simcoe WPCP laboratory in Beaverton. All monitoring and laboratory equipment is calibrated and maintained according to manufacturer's specifications.

f) Estimate of sludge settling capacity of the lagoons and its annual depletion

The annual depletion of the sludge settling capacity is negligible. There was no removal of solids from the lagoons in 2016. The construction of a maintenance lagoon is expected to begin in 2017.

g) Efforts made and results achieved in meeting the effluent objectives of Condition 4

- The Regional Municipality of Durham strives to achieve the best effluent quality at all times consistently remaining well below ECA limits.
- All effluent objectives were met in 2016 except for the maximum objective for pH of 8.0 was exceeded 12 times during the spring discharge. The pH results ranged between 8.0 and 8.6. Due to the nature of wastewater treatment in a lagoon system pH is a difficult parameter to control.
- Best efforts will continue to be applied to maintain results below objectives.

h) Summary of any complaints received during the reporting period and any steps taken to address the complaint

A summary of complaints received from the public is administered through a central database. No complaints were received during the reporting period regarding this plant.

i) Summary of all By-pass, Spill or Abnormal Discharge Events

No by-passes, spills or abnormal discharges occurred during the reporting period.



j) Status Update of the Initial Effluent Characterization

The initial effluent characterization report was submitted in April of 2016.

k) Information Required by MOECC District Manager

No additional information was requested.

MOECC Inspection

This plant was not inspected by the MOECC in 2016.



Summary of Tables

Table 1 Raw Influent Flows

Month	Total Flow to Plant - metered at the River Street Pumping Station m ³	Average Daily Flow m ³ /d	Maximum Daily Flow m ³ /d	Minimum Daily Flow m ³ /d
January	6,721	217	247	176
February	11,066	382	512	210
March	18,232	588	921	450
April	20,069	669	896	508
May	15,053	486	571	413
June	11,749	392	437	325
July	10,622	343	401	296
August	10,355	334	405	272
September	9,892	330	385	283
October	10,211	329	379	235
November	10,132	338	384	285
December	11,468	370	548	296
Total	145,570			
Annual Average	12,131	399*		
Minimum	6,721			176
Maximum	20,069		921	
ECA Requirement		632*		
Met Compliance		Yes		

*Annual average daily flow



Sunderland Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg conc. mg/L	TSS loading kg/d	TP avg conc. mg/L	TP loading kg/d
January	97	21	138	30	154	33	3.9	0.8
February	89	34	131	50	143	55	4.1	1.6
March	92	54	129	76	160	94	3.5	2.1
April	52	35	71	48	101	68	2.4	1.6
May	103	50	117	57	151	73	3.5	1.7
June	147	58	157	61	172	67	5.5	2.2
July	154	53	193	66	215	74	5.2	1.8
August	147	49	205	68	207	69	6.2	2.1
September	156	51	194	64	251	83	5.8	1.9
October	132	44	181	60	211	70	5.9	1.9
November	153	52	193	65	196	66	5.2	1.7
December	115	43	129	48	385	142	4.8	1.8
Average	120	48	153	61	196	78	4.7	1.9
Minimum	52	21	71	30	101	33	2.4	0.8
Maximum	156	58	205	76	385	142	6.2	2.2
Sampling Frequency Requirement Met	Yes		Yes		Yes		Yes	



Sunderland Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses continued

Month	DP avg. conc. mg/L	TKN avg. conc. mg/L	TKN loading kg/d	TAN avg. conc. mg/L	TAN loading kg/d	pH min.	pH max.	Temp. Degrees Celsius min.	Temp. Degrees Celsius max.
January	1.7	32.83	7	20.4	4.4	7.4	8.0	10.8	11.6
February	2.1	36.58	14	21.9	8.4	7.6	8.4	9.9	11.3
March	1.5	32.75	19	18.7	11.0	7.4	8.0	8.9	10.5
April	1.0	21.03	14	12.0	8.0	7.4	7.9	8.7	10.6
May	1.4	32.04	16	20.1	9.7	7.1	8.0	10.1	13.4
June	2.3	42.45	17	26.6	10.4	7.6	8.0	13.0	15.2
July	2.5	42.18	14	29.3	10.0	7.8	8.0	15.4	19.2
August	1.4	49.70	17	32.0	10.7	8.2	8.3	17.2	18.4
September	2.7	48.55	16	32.2	10.6	8.1	8.2	17.3	18.5
October	3.1	53.32	18	38.0	12.5	8.2	8.2	14.1	18.0
November	2.3	43.38	15	26.4	8.9	7.7	8.1	13.5	16.4
December	2.5	45.58	17	31.7	11.7	7.8	7.9	10.4	13.4
Average	2.0	40.03	16	25.8	10.3				
Minimum	1.0	21.03	7	12.0	4.4	7.1		8.7	
Maximum	3.1	53.32	19	38.0	12.5		8.4		19.2
Sampling Frequency Requirement Met				Yes		Yes	Yes	Yes	Yes



Table 3 Calculated Effluent Flows

Month	Effluent Flow m ³
January	
February	
March	
April	
May	50,701
June	
July	
August	
September	
October	
November	31,441
December	
Total	82,142
Annual Average	41,071
Minimum	31,441
Maximum	50,701



Table 4 Final Effluent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading kg/d	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d	TP loading kg/month
January									
February									
March									
April									
May	4.5	12	5.9	16	8.6	23	0.07	0.2	3.4
June									
July									
August									
September									
October									
November	2.6	13	4.1	21	5.2	27	0.11	0.6	3.4
December									
Total									6.8
Average	3.6	12	5.0	16	6.9	23	0.09	0.3	0.9
Minimum	2.6	12	4.1	16	5.2	23	0.07	0.2	3.4
Maximum	4.5	13	5.9	21	8.6	27	0.11	0.6	3.4
ECA Limit	10**				15**		0.3**		69*
ECA Objective	10				15		0.5		
LSPRS							0.25*		58*
Within Compliance	Yes				Yes		Yes		Yes
Sampling Frequency Requirement Met	Yes				Yes		Yes		Yes

*Total Annual Loading, kg/year

**Annual Average Concentration



Sunderland Water Pollution Control Plant
Annual Performance Report 2016

Table 4 Final Effluent Analyses continued

Month	DP avg. conc. mg/L	TAN avg. conc. mg/L	TAN loading kg/d	TKN avg. conc. mg/L	Un-ionized ammonia avg. conc. mg/L	pH min.	pH max.	Temp. °C min.	Temp. °C max.
January									
February									
March									
April									
May	0.01	6.47	4.81	12.9	0.26	8.0	8.6	12.2	18.4
June									
July									
August									
September									
October									
November	0.02	3.70	1.56	8.0	0.00	6.9	7.4	6.3	8.5
December									
Average	0.01	5.08	3.18	10.5	0.13				
Minimum	0.01	3.70	1.56	8.0	0.00	6.9		6.3	
Maximum	0.02	6.47	4.81	12.9	0.26		8.6		18.4
ECA Limit						6.0	9.5		
ECA Objective						6.5	8.0		
Within Compliance									
Sampling Frequency Requirement Met		Yes				Yes	Yes	Yes	Yes



Glossary of Terms

Annual Average Concentration

An arithmetic mean of the seasonal average concentrations of a contaminant in the effluent calculated for any particular year.

Annual Average Loading

The value obtained by multiplying the seasonal average concentration of a contaminant by the Average Daily Flow over the same calendar year.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

Avg – Average

An arithmetic mean of the average concentrations and loadings.

BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

Any discharge from any portion of the works other than in accordance with the conditions of the ECA.

CBOD₅ -Five Day Carbonaceous Biochemical Oxygen Demand

A five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample.

Conc. Concentration

The abundance of a constituent divided by the total volume of a mixture.

Daily Concentration

Means the concentration of a contaminant in the effluent discharged over any single day, as measured by a composite or grab sample, whichever is required.

DP – Dissolved Reactive Phosphorus

This is the soluble form of phosphorus present in the wastewater.

ECA Environmental Compliance Approval

The primary regulatory instrument for each water pollution control plant.

E. coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius.



Final Effluent

Sewage discharge through the water pollution control plant outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.

Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, when tested provides a snapshot of the conditions at the time the sample was retrieved.

kg - kilogram

Basic unit of mass in the metric system

kg/d – kilogram per day

LSPRS - Lake Simcoe Phosphorus Reduction Strategy

The ECA issued on June 28, 2012 introduced additional phosphorus objectives to comply with the requirements of the Lake Simcoe Phosphorus Reduction Strategy (2010) prepared under the Lake Simcoe Protection Plan (2009).

m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metre Per Day)

Flow measurement, 1m³ = 1000 litres or 220 imperial gallons. Volume of liquid treated in a day.

Max. – Maximum

The peak or highest value recorded during a specific time period usually a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.

mg/L. - (Milligram Per Litre)

This is a measure of the concentration of a parameter in water, sometimes referred to as parts per million (ppm).

Min. – Minimum

The lowest value recorded during a specific time period usually in a day.

mm.-(millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.



MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly Average Concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.

Monthly Average Loading

Is calculated by multiplying the monthly average concentration of a contaminant in the effluent by the monthly average daily flow during a calendar month.

N/A - Not Applicable

N/D - No Discharge

Peak Flow Rate

The maximum rate of sewage flow for which the plant or process unit was designed.

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.

Rated Capacity

The average daily flow for which the works are approved to handle.

Raw Influent

Raw wastewater entering the water pollution control plant before treatment.

Seasonal Average Concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured or both during the seasonal discharge period.

Sludge

The settleable solids separated from liquids during processing.

TAN - Total Ammonia Nitrogen

Ammonia exists in two forms in the wastewater: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.



Total Annual Loading

Is calculated by adding the calculated total monthly load discharged each month during each seasonal discharge period for each calendar year.

Total Monthly Loading

Is calculated by multiplying the total monthly flow by the monthly average concentration.

TP - Total Phosphorus

A laboratory analyses to determine the total amount of non-soluble and soluble phosphorus present in the wastewater.

TSS - Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS - Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

WPCP - Water Pollution Control Plant

A facility composed of a variety of treatment processes that collectively treat wastewater.



Uxbridge Brook Water Pollution Control Plant

Annual Performance Report 2016





The Regional Municipality of Durham

Uxbridge Brook Water Pollution Control Plant 2016 Annual Performance Report

Environmental Compliance Approval (ECA): 8357-8CTQ5V Dated June 28, 2012

Environmental Compliance Approval (Air): 6581-67GRPR Dated December 10, 2004

The Uxbridge Brook Water Pollution Control Plant (WPCP) Performance Report provides staff, stakeholders and customers an overview of the performance of the Uxbridge Brook WPCP in 2016. Further, this report fulfills the annual reporting requirements of the Ontario Ministry of the Environment and Climate Change (MOECC). The performance report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

For a description of terms and abbreviations used in this report, refer to the glossary at the end of the report.

Water Pollution Control Plant Process Description

General

The Uxbridge Brook WPCP located in the Township of Uxbridge is owned and operated by the Regional Municipality of Durham. The plant is operated according to the terms and conditions of the ECA. This MOECC Class Three wastewater treatment plant utilizes an extended aeration process with tertiary treatment and is designed to treat wastewater at a rated capacity of 5,221 cubic metres per day (m³/d). The Uxbridge Brook WPCP has a service population of 11,467 residents.

Uxbridge Brook WPCP treats wastewater from the Uxbridge service area utilizing the following processes:

- raw influent pumping,
- preliminary treatment,
- phosphorus removal,
- secondary treatment,
- tertiary filtration,
- disinfection,
- solids treatment.

Raw Influent Pumping

Wastewater is collected through approximately 50.2 km of sanitary sewers in Uxbridge and is conveyed to the WPCP by gravity and one sanitary sewage pumping station (Sandy Hook).

Preliminary Treatment

Screening: There are two screens in the screening room for the removal of paper products and large material that could harm pumps and process equipment. One channel contains an automatic, mechanically cleaned bar screen and the other is equipped with a manually raked bar screen to provide screening on an emergency basis. Screenings are removed in this process and transported to landfill for disposal.



Grit Removal: Vortex grit removal is provided to remove sand, gravel, etc. for protection of mechanical equipment from unnecessary wear and reduce formation of heavy deposits in pipelines, channels and process tanks. The vortex grit removal chamber uses centrifugal force to separate the grit from the wastewater. Grit is collected in the lower portion of the grit tank and is pumped to a grit classifier for dewatering. The dewatered grit is conveyed to the grit/screenings bin for landfill disposal.

Phosphorus Removal

The phosphorous removal system is intended to lower the total phosphorous level in the final effluent by adding a chemical coagulant (aluminum sulphate) as part of the treatment process. Aluminum sulphate can be added at multiple locations within the plant.

Secondary Treatment

Aerated Bioreactors: Preliminary effluent flow is directed to two aerated bioreactors. Fine bubbled air is diffused into the sewage to assist bacteria in removing dissolved and suspended organics and nutrients from the wastewater. Biological activity is controlled to assimilate the organic material.

Secondary Clarifiers: The effluent from the aerated bioreactor is directed to three secondary clarifiers where solids settle quickly as activated sludge leaving a clear effluent. A portion of the activated sludge collected on the bottom of the clarifiers is pumped back to the front of the bioreactors and any excess activated sludge is wasted to the aerobic digester.

Tertiary Treatment

Tertiary Sand Filter: Effluent from the secondary clarifiers is filtered through two automatic self cleaning sand filters. The automatic backwash is initiated by an increase in head pressure or on a programmed timer. The backwash water is returned to the front of the plant for further treatment.

Disinfection

Ultra Violet (UV) Irradiation: The effluent flow from the sand filter is then directed to the UV channel for disinfection. The effluent passes two banks of UV lamps connected in series. The treated final effluent is discharged to the Uxbridge Brook.

Solids Treatment

Aerobic Digester: Waste activated sludge from the secondary clarifiers is pumped to a two stage aerobic digester for stabilization. A coarse bubble diffuser provides oxygen for the microorganisms. The diffusers are turned off to allow solids to settle for removal and the supernatant is returned to the front of the plant for further treatment.

Biosolids Management: Stabilized biosolids from the digester is transported to Duffin Creek Water Pollution Control Plant in the Region of Durham for incineration in accordance with ECA #A820250.

Environmental Compliance Approval

Under Condition 9 (5) of ECA #8357-8CTQ5V the Region of Durham must produce an annual performance report that must contain the following information:



a) Summary and interpretation of all monitoring data and a comparison to the effluent limits outlined in Condition 5, including an overview of the success and adequacy of the works

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the conditions in the ECA.

The Uxbridge Brook WPCP effluent was compliant with the approval limits during the reporting period. The plant operated at 62.1% of its rated capacity and received a maximum daily flow of 5,393 m³/d on April 1st, 2016.

b) Description of any operating problems encountered and corrective actions taken

No operating problems were encountered in 2016

c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the works

Major maintenance items in 2016 included:

- A new blower unit was installed for aerated bioreactor number one.
- Adjustments were made to the effluent flume to improve flow monitoring.
- Secondary clarifiers one, two and three were taken out of service for inspection and minor repairs.

d) Summary of any effluent quality assurance or control measures

In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. Results were found to be in a comparable range. On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.

e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment

- Calibration of the plant flow meters was conducted in July and November 2016.
- Calibration of the in-house laboratory equipment was conducted in July 2016.
- Calibration of the pH meter is conducted daily.

f) Description of efforts made and results achieved in meeting the effluent objectives

- The Regional Municipality of Durham strives to achieve the best effluent quality at all times, remaining below the ECA compliance limits.
- The Uxbridge Brook WPCP effluent met all ECA objectives except for:
The effluent objective for total suspended solids was exceeded in six of 306 samples (1.9%).
The effluent objective for total phosphorus was exceeded in six of 309 samples (1.9%).
Results were monitored and adjustments were made to the treatment process when required.
The minimum effluent objective for pH was exceeded in three of 260 samples (1.2%).
Calibration, maintenance and cleaning of the pH electrode probe is performed regularly.
- Best efforts and process adjustments will continue to be applied to maintain results below objectives.



g) Tabulation of Volume of Sludge Generated

The volume of sludge removed from Uxbridge Brook WPCP in 2016 was 12,120m³.

Outline of Anticipated Volumes to be Generated in the Next Reporting Period

There is no increase of sludge volume expected in the next reporting period.

Summary of Locations to Where Sludge was Disposed

Duffin Creek WPCP- 12,120m³.

h) Summary of any complaints received during the reporting period and any steps taken to address the complaint

A summary of complaints received from the public is administered through a central database. One odour complaint was received on March 24th, 2016. The odour control unit for the aerobic digester was temporarily out of service due to freezing rain. Upon restoration the odour was resolved.

i) Summary of all By-pass, Spill or Abnormal Discharge Events

No by-passes, spills or abnormal discharges occurred during the reporting period.

j) Status Update of the Initial Effluent Characterization

The initial effluent characterization report was submitted in 2016.

k) Information Required by MOECC District Manager

No additional information was requested.

MOECC Inspection

This plant was not inspected by the MOECC in 2016.



Summary of Tables

Table 1 Flows

Month	Plant Flow - metered at the final effluent m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d
January	117,990	3,806	4,704
February	98,686	3,403	4,726
March	117,438	3,788	5,336
April	129,337	4,311	5,393
May	109,683	3,538	3,968
June	97,030	3,234	3,687
July	87,952	2,837	3,451
August	89,353	2,882	3,667
September	83,248	2,775	3,011
October	89,387	2,883	4,077
November	79,841	2,661	3,844
December	86,078	2,777	3,433
Total	1,186,024		
Average	98,835	3,241*	
Minimum	79,841		
Maximum	129,337		5,393
ECA Requirement		5,221	15,110
Met Compliance		Yes	Yes

*Annual average



Uxbridge Brook Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses

Month	BOD ₅ avg. conc. mg/L	BOD ₅ loading kg/d	TSS avg. conc. mg/L	TSS loading kg/d	TP avg. conc. mg/L	TP loading kg/d	DP avg. conc. mg/L
January	139	529	111	424	3.4	13	2.0
February	102	346	91	309	3.1	11	2.1
March	96	365	116	441	2.8	11	1.6
April	76	327	93	399	2.6	11	1.7
May	238	843	365	1292	3.6	13	1.9
June	191	619	281	908	3.7	12	2.3
July	258	732	269	762	4.0	11	2.5
August	267	770	269	776	4.2	12	2.5
September	244	677	279	776	4.3	12	2.6
October	278	800	552	1592	4.4	13	2.6
November	222	591	333	885	4.5	12	2.5
December	310	859	616	1710	4.4	12	2.7
Average	202	654	281	911	3.8	12	2.3
Minimum	76	327	91	309	2.6	11	1.6
Maximum	310	859	616	1710	4.5	13	2.7
Sampling Frequency Requirement Met	Yes		Yes		Yes		Yes



Uxbridge Brook Water Pollution Control Plant
Annual Performance Report 2016

Table 2 Raw Influent Analyses continued

Month	TKN avg. conc. mg/L	TKN loading kg/d	TAN avg. conc. mg/L	TAN loading kg/d	Alkalinity CaCO ₃ mg/L	pH min.	pH max.	Temp. Degrees Celsius min.	Temp. Degrees Celsius max.
January	32.23	123	22.0	83.8	293	7.1	8.5	10.9	16.2
February	30.13	103	24.4	83.1	340	7.7	8.6	6.3	14.6
March	27.40	104	18.7	70.9	341	7.7	8.4	10.6	16.0
April	24.10	104	19.6	84.5	322	7.0	8.4	10.7	14.1
May	31.25	111	22.4	79.3	345	7.6	8.4	13.2	18.3
June	33.94	110	25.6	82.9	326	7.6	8.8	16.1	20.7
July	36.43	103	24.0	68.0	312	7.4	8.3	13.1	20.3
August	39.94	115	26.4	76.0	320	7.8	8.4	18.1	21.3
September	40.03	111	27.5	76.4	354	7.1	8.4	18.4	22.0
October	37.08	107	26.0	74.9	326	7.0	8.4	12.0	20.0
November	39.50	105	27.5	73.1	339	7.8	8.7	15.5	18.3
December	41.83	116	27.3	75.9	327	7.5	8.6	10.0	17.4
Average	34.49	112	24.3	78.7	329				
Minimum	24.10	103	18.7	68.0	293	7.0		6.3	
Maximum	41.83	123	27.5	84.5	354		8.8		22.0
Sampling Frequency Requirement Met	Yes		Yes		Yes	Yes	Yes	Yes	Yes



Table 3 Final Effluent Analyses

Month	CBOD ₅ avg. conc. mg/L	CBOD ₅ loading monthly avg kg/d	TSS avg. conc. mg/L	TSS loading monthly avg. kg/d	TP avg. conc. mg/L	TP loading avg. kg/d	TP loading kg/month
January	0.5	1.9	1.1	4.0	0.03	0.12	4
February	0.7	2.5	1.6	5.5	0.04	0.13	4
March	1.1	4.1	1.4	5.4	0.04	0.14	4
April	0.4	1.7	0.9	3.7	0.02	0.11	3
May	0.7	2.3	0.7	2.5	0.03	0.09	3
June	0.7	2.3	1.3	4.1	0.03	0.09	3
July	0.5	1.4	0.9	2.6	0.03	0.07	2
August	0.7	2.1	0.9	2.5	0.03	0.09	3
September	0.5	1.4	1.1	3.2	0.05	0.14	4
October	1.1	3.2	2.2	6.3	0.07	0.20	6
November	0.5	1.3	0.9	2.5	0.03	0.08	2
December	1.1	3.1	2.4	6.7	0.05	0.13	4
Total							42
Average	0.7	2.3	1.3	4.2	0.04	0.12	4
Minimum	0.4	1.3	0.7	2.5	0.02	0.07	2
Maximum	1.1	4.1	2.4	6.7	0.07	0.20	6
ECA Limit	8.5**	30.9****	10**	36.3****	0.15**	0.78****	286*
ECA Objective	5		5		0.1		
LSPRS					0.15***		286*
Within Compliance	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Sampling Frequency Requirement Met	Yes		Yes		Yes	Yes	

*Total Annual Loading, kg/year
 **Monthly Average Concentration
 *** Annual Average Concentration
 **** Annual Average Loading,kg/day
 *****Monthly Average Loading,kg/day



Uxbridge Brook Water Pollution Control Plant
Annual Performance Report 2016

Table 3 Final Effluent Analyses continued

Month	DP avg. conc. mg/L	TAN Winter avg. conc. mg/L	TAN Winter loading monthly avg. kg/d	TAN Summer avg. conc. mg/L	TAN Summer loading monthly avg. kg/d	TKN avg. conc. mg/L	Un-ionized Ammonia Nitrogen avg. conc. mg/L
January	0.03	0.02	0.09			0.61	0.0
February	0.02	0.03	0.11			0.72	0.0
March	0.02	0.05	0.18			0.65	0.0
April	0.02	0.03	0.13			0.53	0.0
May	0.02			0.03	0.10	0.58	0.0
June	0.02			0.04	0.13	0.64	0.0
July	0.01			0.04	0.11	0.61	0.0
August	0.01			0.04	0.11	0.60	0.0
September	0.02			0.08	0.22	0.75	0.0
October	0.03			0.14	0.41	1.07	0.0
November	0.01			0.03	0.08	0.66	0.0
December	0.03	0.08	0.22	--	--	0.90	0.0
Average	0.02	0.04	0.14	0.06	0.17	0.69	0.0
Minimum	0.01	0.02	0.09	0.03	0.08	0.53	0.0
Maximum	0.03	0.08	0.22	0.14	0.41	1.07	0.0
ECA Limit		6**	21.8*****	3**	10.9*****		0.1**
ECA Objective		5		2			
Within Compliance		Yes	Yes	Yes	Yes		Yes
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes	Yes		Yes



Uxbridge Brook Water Pollution Control Plant
Annual Performance Report 2016

Table 3 Final Effluent Analyses continued

Month	Nitrate Nitrogen avg. conc. mg/L	Alkalinity CaCO ³ . mg/L	pH min.	pH max.	Temp. Degrees Celsius min.	Temp. Degrees Celsius max.
January	25.8	119	6.89	7.30	10.2	15.0
February	25.8	114	6.66	7.28	7.1	12.9
March	21.4	136	6.57	7.29	8.9	13.3
April	20.2	135	6.79	7.13	9.6	13.7
May	23.0	117	6.79	7.28	10.8	17.8
June	26.9	82	6.61	7.21	15.5	20.1
July	28.9	61	6.67	6.96	18.6	20.6
August	29.8	60	6.64	7.18	19.7	21.6
September	31.3	64	6.48	7.70	18.0	21.6
October	30.8	57	6.36	7.31	15.1	19.5
November	30.7	70	6.59	7.04	13.6	17.5
December	30.1	70	6.54	7.18	11.4	15.3
Average	27.0	90				
Minimum	20.2	57	6.36		7.1	
Maximum	31.3	136		7.70		21.6
ECA Limit			6.0	9.5		
ECA Objective			6.5	9.0		
Within Compliance						
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes	Yes	Yes



Table 4 Escherichia Coliform Sampling

Month	Number of Samples	Monthly Geometric Mean Density
January	4	0
February	4	0
March	5	0
April	4	0
May	4	0
June	5	1
July	4	0
August	5	0
September	4	1
October	4	0
November	5	0
December	4	0
ECA Objective		200 organisms/100ml
Sampling Frequency Requirement Met	Yes	



Table 5 Energy and Chemical Usage

Month	Aluminum Sulphate (litres)	Hydro (kWh)	Natural Gas (cubic metres)
January	20,031	123,776	2,154
February	20,243	114,418	1,165
March	28,261	112,950	1,384
April	29,618	100,757	2,169
May	24,382	91,160	748
June	22,420	86,086	181
July	21,181	94,308	120
August	21,449	96,312	110
September	20,031	95,069	134
October	20,296	101,569	202
November	19,541	100,639	727
December	22,072	113,324	1,204
Total	269,525	1,230,368	10298



Glossary of Terms

Annual Average Concentration

An arithmetic mean of the monthly average concentrations of a contaminant in the effluent calculated for any particular calendar year.

Annual Average Loading

The value obtained by multiplying the annual average concentration of a contaminant by the average daily flow over the same calendar year.

Average Daily Flow

The cumulative total sewage flow to the sewage works during a calendar year divided by the number of days during which sewage was flowing to the sewage works that year.

Avg – Average

An arithmetic mean of the average concentrations and loadings.

Biosolids

Organic material recovered from wastewater sludge.

Bioreactor

A bioreactor is a vessel in which a biological process is carried out which involves bacterial organisms or biochemically active substances derived from such organisms.

BOD₅ Five Day Biochemical Oxygen Demand

(also known as total BOD₅) a five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand.

By-pass

Any discharge from the works that does not undergo any treatment or only undergoes partial treatment before it is discharged to the environment.

CBOD₅ -Five Day Carbonaceous Biochemical Oxygen Demand

A five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample.

Conc. - Concentration

The abundance of a constituent divided by the total volume of a mixture.

Daily Concentration

The concentration of a contaminant in the effluent discharged over any single day, as measured by a composite or grab sample, whichever is required.



DP - Dissolved Reactive Phosphorus

This is the soluble form of phosphorus present in the wastewater.

ECA - Environmental Compliance Approval

The primary regulatory instrument for each water pollution control plant.

E. - coli - (Escherichia coli)

Refers to the thermally tolerant forms of Escherichia that can survive at 44.5 degrees Celsius.

Final Effluent

Sewage discharge through the water pollution control plant outfall after undergoing the full train of unit processes as listed in the Environmental Compliance Approval.

Geometric Mean Density

Is the nth root of the product of multiplication of the results of n number of samples over the period specified.

Grab Sample

A single sample taken at a specific moment in time, when tested provides a snapshot of the conditions at the time the sample was retrieved.

kg - kilogram

Basic unit of mass in the metric system

kg/d – kilogram per day

LSPRS - Lake Simcoe Phosphorus Reduction Strategy

The ECA issued on June 28, 2012 introduced additional phosphorus objectives to comply with the requirements of the Lake Simcoe Phosphorus Reduction Strategy (2010) prepared under the Lake Simcoe Protection Plan (2009).

m³ - (Cubic Metre)

Volume measurement, 1m³ = 1000 litres or 220 imperial gallons.

m³/d - (Cubic Metre Per Day)

Flow measurement, 1m³ = 1000litres or 220 imperial gallons. Volume of liquid treated in a day.

Max-Maximum

The peak or highest value recorded during a specific time period usually a day.

Maximum Flow Rate

The peak or highest flow recorded during a specific time period usually in a day.



mg/L - (Milligram Per Litre)

This is a measure of the concentration of a parameter in water, sometimes referred to as parts per million (ppm).

Min- Minimum

The lowest value recorded during a specific time period usually in a day.

mm.-(millimetre)

Is a unit of length in the metric system, equal to one thousandth of a metre.

MOECC - (Ministry of the Environment and Climate Change)

The Provincial regulatory agency responsible for overseeing the water and wastewater industries in Ontario. Their primary functions include approval for new or expanding facilities, inspections and investigations.

Monthly average concentration

The arithmetic mean of all daily concentrations of a contaminant in the effluent sampled or measured, or both, during a calendar month.

Monthly average loading

Is calculated by multiplying the monthly average concentration of a contaminant by the monthly average daily flow over the same calendar month.

Nitrate Nitrogen

Is a salt or ester of nitric acid, containing the NO_3 ion. Nitrates are the most water soluble of salts, and play a major part in the nitrogen cycle and nitrate pollution.

N/A - Not Applicable

Peak Flow Rate

The maximum rate of sewage flow for which the plant or process unit was designed.

pH

Index of hydrogen ion activity, pH is defined as the negative logarithm of hydrogen ion concentration in moles per litre. The pH may range from 0 – 14, where 0 is most acidic, 14 most basic and 7 neutral.

Rated Capacity

The average daily flow for which the works are approved to handle.

Raw Influent

Raw wastewater entering the water pollution control plant before treatment.



Septage

Partially treated sludge from a septic tank.

Sludge

The settleable solids separated from liquids during processing.

TAN - Total Ammonia Nitrogen

Ammonia exists in two forms in the wastewater: NH_3 (this is called unionized ammonia) NH_4^+ (this is called ionized ammonia) Together, these two forms of ammonia are called TAN which means total ammonia nitrogen.

Temp. – Temperature

A measure of the warmth or coldness of an object or substance identified as degrees Celsius.

Total Annual Loading

Is calculated by adding the calculated total monthly load discharged for each calendar year.

Total Monthly Loading

Is calculated by multiplying the total monthly flow by the monthly average concentration.

TP - Total Phosphorus

A laboratory analyses to determine the total amount of non-soluble and soluble phosphorus present in the wastewater.

TSS - Total Suspended Solids

A laboratory analyses to measure particles that are larger than 2 microns found in the wastewater.

TS - Total Solids

Is a measure of the suspended and dissolved solids in the wastewater and in biosolids.

Unionized Ammonia Nitrogen

Un-ionized ammonia refers to all forms of ammonia in water with the exception of the ammonium ion (NH_4^+).

WPCP - Water Pollution Control Plant

A facility composed of a variety of treatment processes that collectively treat wastewater.

If this information is required in an accessible format, please contact 1-800-372-1102 extension 3488