

- BEDDING AS PER S-200.010.

- HYDRANT EXTENSIONS SHALL BE INSTALLED AT BOTTOM OF BARREL. ANCHOR TEE, VALVE & HYDRANT SHALL BE COMPLETELY BACKFILLED WITH 19 mm CRUSHER RUN LIMESTONE. IF HYDRANT REQUIRES ACCESS ACROSS DITCH, INSTALLATION SHALL BE AS PER S-210.030.
- 6. 12 GAUGE COPPER CORE SOLID STRAND TRACER WIRE COATED, AS PER AMPL.
- 7. TRACER WIRE SHALL BE INSTALLED AT ALL HYDRANT LOCATIONS.
- 8. CATHODIC PROTECTION, BONDING CABLE AND TRACER WIRE SHALL BE AS PER S-201.030, S-201.031.

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED

HYDRANT SET WITH MECHANICALLY RESTRAINED JOINTS

DWG. DATE: 1978 03 REVISION NO.: REV. DATE: 2025 02 SCALE: N.T.S.

S-210.010

