



**NOTES**

1. SEE DETAILS S-200.050 AND S-200.060 FOR METHOD OF RESTRAINING JOINTS ON P.V.C. WM.
2. COMPACTED GRANULAR SHALL BE PLACED BETWEEN SEWER & WATERMAIN AS PER S-200.030.
3. PROVIDE CATHODIC PROTECTION FOR FITTINGS AS PER S-201.030 AND S-201.031.
4. MINIMUM VERTICAL SEPARATION TO BE 250mm FOR WATERMAIN TO CROSS ABOVE SEWER.

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED.



**DEFLECTION OF WATERMAIN  
OVER AND UNDER SEWER**

DWG. DATE: 2004 07
REVISION NO.: 4
REV. DATE: 2017 04
SCALE: N.T.S.
<b>S-200.070</b>