



**ELEVATION**

**NOTES**

1. ALL SHORING SHALL BE CUT OFF AT CREEK BED WHEN CONSTRUCTION IS COMPLETED.
2. VALVES SHALL BE PROVIDED AT BOTH ENDS OF WATER CROSSING ABOVE THE HIGH WATER LINE.
3. THE PIPE SHALL BE OF SPECIAL CONSTRUCTION, HAVING FLEXIBLE, WATERTIGHT JOINTS.

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED.



WORKS DEPARTMENT

**WATERMAIN TRENCH DETAIL  
UNDER WATER COURSE**

DWG. DATE: 1978 03
REVISION NO.: 5
REV. DATE: 2013 04
SCALE: N.T.S.

**S-200.090**