



NOTES

1. ALL DUCTS SHALL BE CSA C22.2 #211-2 APPROVED OR SUBSEQUENT REVISION THEREOF.
2. ALL FITTINGS SHALL BE MOULDED OR FABRICATED FROM MATERIAL COMPATIBLE WITH THE DUCT MATERIAL. ALL JOINTS MUST CONFORM TO MANUFACTURERS RECOMMENDED PRACTICE AND BE CONNECTED BY AN APPROVED SOLVENT CEMENT.
3. HOLES EXCAVATED BY AUGERING, 1.0m DEPTH OF TUBING MAY BE USED. HOLES EXCAVATED BY JET/VACUUM, HAND DIG OR OTHER SUITABLE MEANS, TUBING MUST EXTEND THE FULL DEPTH.
4. FOUNDATIONS INSTALLED ON SLOPED GRADES SHALL USE LOCAL GRADING AS PER OPSD-2210.01.
5. CONCRETE SHALL BE CSA SPECIFICATION C-1 35 MPa CLASS OF EXPOSURE IN ACCORDANCE WITH CSA A23. 1-09 TABLE 1 & 2.

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED.

BASE TYPE	STUD DIST B	BOLT CIRCLE C	ANCHOR DEPTH	ANCHOR TYPE
I	287	406	457	PRE-SET ANCHOR ASSEMBLY 32mm TYPE DGR-2B-406
II	380	539	457	PRE-SET ANCHOR ASSEMBLY 32mm TYPE DGR-2B-539



WORKS DEPARTMENT

CONCRETE FOOTING FOR PEDESTAL SUPPLY CONTROL CABINET

DWG. DATE: 1985 02

REVISION NO.: 13

REV. DATE: 2017 04

SCALE: N.T.S.

S-400.011