



**NOTES**

1. ALL DUCTS SHALL BE CSA C22.2 #211-2 APPROVED OR SUBSEQUENT REVISION THEREOF.
2. ALL FITTINGS SHALL BE MOULDED OR FABRICATED FROM MATERIAL COMPATIBLE WITH THE DUCT MATERIAL. ALL JOINTS MUST CONFORM TO MANUFACTURERS RECOMMENDED PRACTICE.
3. FORM WITH 20mm PLYWOOD BRACED AROUND ENTIRE PERIMETER TO PREVENT WARPING.
4. CONCRETE SHALL BE CSA SPECIFICATION C-1 35 MPa CLASS OF EXPOSURE IN ACCORDANCE WITH CSA A23.1-09. TABLE 1 & 2.

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED.



**CONCRETE FOOTING FOR TRAFFIC CONTROLLER/UPS CABINET**

|                    |
|--------------------|
| DWG. DATE: 2001 04 |
| REVISION NO.: 9    |
| REV. DATE: 2021 04 |
| SCALE: N.T.S.      |
| <b>S-400.020</b>   |