



NOTES:

1. THE METER BASE (IF REQUIRED) SHALL BE BONDED TO THE SUPPLY CONTROL CABINET WITH A GREEN #6 AWG INSULATED WIRE.
2. CONDUIT SHALL BE MOUNTED USING 16 mm STAINLESS STEEL STRAPPING AND BUCKLES ON CONCRETE POLES OR GALVANIZED PIPE STRAPS WITH 6 X 38 mm LAG SCREWS ON WOOD POLES AT MAXIMUM SPACINGS OF 1.2 m.
3. NUMBER OF GROUND RODS/PLATES AND SIZE OF GROUND WIRE SHALL BE AS INDICATED ELSEWHERE IN THE CONTRACT.
4. FOR ORIENTATION AND LOCATION OF POLES AND EQUIPMENT REFER TO CONTRACT DRAWINGS.
5. WHERE UNDERGROUND RACEWAYS OR CABLES ARE SUBJECT TO MOVEMENT BY SETTLEMENT OR FROST, PROVISION SHALL BE MADE SO AS TO PREVENT DAMAGE TO THE CONDUCTORS OR THE ELECTRICAL EQUIPMENT.

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED.



WORKS DEPARTMENT

SUPPLY CONTROL CABINET INSTALLATION ON WOODEN OR CONCRETE POLE – OVERHEAD SUPPLY (UNDERGROUND SIGNAL WIRING)

DWG. DATE:	2008 04
REVISION NO.:	5
REV. DATE:	2023 04
SCALE:	N.T.S.

S-410.091