



# **Nonquon Water Pollution Control Plant 2024 Annual Performance Report**





## **The Regional Municipality of Durham**

### **Nonquon Water Pollution Control Plant 2024 Annual Performance Report**

**Environmental Compliance Approval (ECA): 2207-9LKHLM**

Dated July 17, 2014

The Nonquon Water Pollution Control Plant (WPCP) 2024 Annual Performance Report provides staff, stakeholders, and customers an overview of the performance of the Nonquon WPCP in 2024.

Further, this report fulfills the annual reporting requirements of the Ontario Ministry of Environment, Conservation and Parks (MECP). This report demonstrates the commitment of ensuring that the WPCP continues to deliver wastewater services to our customers in an environmentally responsible manner.

#### **Water Pollution Control Plant Process Description**

##### **General**

The Nonquon WPCP located in the Community of Port Perry in the Township of Scugog is owned and operated by the Regional Municipality of Durham (Region). The plant is operated according to the terms and conditions of the ECA. This MECP Class 3 wastewater treatment plant utilizes an extended aeration process with tertiary treatment and is designed to treat wastewater at a rated capacity of 5,900 cubic metres per day (m<sup>3</sup>/d). The Nonquon WPCP has a service population of 9,632 residents.

Nonquon WPCP treats wastewater from the Port Perry service area utilizing the following processes:

- Raw influent pumping
- Preliminary treatment
- Phosphorus removal
- Secondary treatment
- Tertiary treatment
- Disinfection
- Solids management

##### **Raw Influent Pumping**

Wastewater is collected through approximately 53.4 kilometres of sanitary sewers in the Port Perry service area and is conveyed to the Nonquon WPCP by three sanitary sewage pumping stations (SSPS): Water Street, Reach Street and Canterbury Common SSPS.

The influent pumping station at the Nonquon WPCP allows raw wastewater flow more than the design flow of 5,900 m<sup>3</sup>/d to passively overflow to the inlet chamber and be directed to one of the five equalization lagoons for storage. A gravity sanitary sewer pipe allows for lagoon effluent to be returned to the influent pumping station during periods of low flows, for full treatment.



## **Preliminary Treatment**

**Screening:** There are two bar screens in the screening room for the removal of paper products and large material that could harm pumps and process equipment. One channel contains an automatic, mechanically cleaned bar screen and the other is equipped with a manually raked bar screen to provide screening on an emergency basis. A screenings washer/compacter utilizes plant effluent water to wash and compact the screenings. Screenings are removed in this process and transported to landfill for disposal.

**Grit Removal:** The vortex grit removal removes sand and small stones (grit) for the protection of mechanical equipment from unnecessary wear and reduce formation of heavy deposits in pipelines, channels, and process tanks. The vortex grit removal chamber uses centrifugal force to separate the grit from the wastewater. Grit is collected in the lower portion of the grit tank and is pumped to a grit classifier for dewatering. The dewatered grit is conveyed to the grit/screenings bin for landfill disposal.

## **Phosphorus Removal**

The phosphorus removal system lowers the total phosphorus level in the final effluent by adding a chemical coagulant, aluminum sulphate, as part of the treatment process. Aluminum sulphate can be added at multiple locations throughout the plant.

## **Secondary Treatment**

**Aeration Tanks:** Preliminary effluent flow is directed to two aeration tanks comprised of two distinct zones. The first is a swing zone equipped with fine bubble diffusers. This zone is capable of being operated as an anoxic zone where no oxygen is introduced and allows for potential denitrification or an aerated zone where fine bubbled air is diffused into the wastewater. It is typically operated as an anoxic zone. The flow leaves the swing zone and enters the aerated zone where fine bubbled air is diffused into the wastewater to assist bacteria in removing dissolved and suspended organics and nutrients. Prior to entering the secondary clarifiers, the two aeration tanks are equipped with a rotating slotted pipe for removal of any excess activated sludge, the waste activated sludge (WAS) is decanted manually to the WAS chamber and pumped to a storage lagoon.

**Secondary Clarifiers:** The effluent from the aeration tank is directed to the two secondary clarifiers where solids settle quickly as activated sludge leaving a clear effluent. The activated sludge collected on the bottom of the clarifiers is pumped back to the front of the aeration tanks. The clear effluent continues to tertiary treatment.



## **Tertiary Treatment**

**Tertiary Sand Filter:** Effluent from the secondary clarifiers is filtered through four upflow filter cells operated in parallel. The tertiary influent flow is directed to the bottom of the cells and upward through the sand media. The automatic backwash is initiated by an increase in head pressure or on a programmed timer. The backwash water is returned to the influent pumping station for further treatment.

## **Disinfection**

**Ultraviolet (UV) Irradiation:** The effluent flow from the sand filter is then directed to the UV channel for disinfection. The effluent passes through two banks of UV lamps connected in series. The treated final effluent is discharged to the Nonquon River.

## **Solids Management**

**Equalization Storage Lagoons:** During high flow conditions excess flow from the influent pumping station is diverted to the aerated cell inlet chamber, from here it is directed to one of the five storage lagoons. During low flow conditions the lagoon effluent can be returned to the influent pumping station for treatment.

**Solids Treatment:** Waste activated sludge (WAS) is pumped from the WAS chamber to lagoon number six for storage and settling, the solid levels are monitored and removed for disposal as needed.

## **Environmental Compliance Approval (ECA)**

Under Condition 10(6) of ECA #2207-9LKHLM the Region must produce an annual performance report that must contain the following information:

**a) Summary and interpretation of all monitoring data and a comparison to the effluent limits**

The raw wastewater flowing into the plant is analyzed for its chemical and physical composition. Monitoring of the raw wastewater is performed in accordance with the plant's ECA. Table 2 Raw Influent Analyses summarizes the raw wastewater characteristics during the reporting period.

The Nonquon WPCP effluent was determined to be compliant with the approval limits during the reporting period. The plant operated at 54.6% of its rated capacity and received a maximum daily flow of 6,381 cubic metres per day (m<sup>3</sup>/d) on April 13, 2024.



## Nonquon Water Pollution Control Plant 2024 Annual Performance Report

---

**b) Description of any operating problems encountered, and corrective actions taken.**

Higher than normal total phosphorous and total suspended solids were observed in early 2024. These results are due to the tertiary filters plugging frequently with algae, grease, and solids. All four filters were rotated out for service for cleaning and topping up the sand. Upgrades to aid removal of solids and grease are being planned. Routine maintenance of the filters is conducted to ensure filters remain operational,

**c) Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism, or thing forming part of the Works.**

Major maintenance items in 2024 included:

- Cleaned out and replaced broken diffusers for aeration 1 and 2.
- Performed substation maintenance.
- Cleaned and topped up sand for all tertiary filters.

**d) Summary of any effluent quality assurance or control measures undertaken in the reporting period**

In-house lab test results are compared to the results of the Regional Environmental Laboratory on comparable samples to determine the in-house accuracy. On-line instrumentation is verified by WPCP operators using various field or laboratory test equipment.

**e) Summary of the calibration and maintenance carried out on all effluent monitoring equipment.**

Calibration of the flow meter was conducted on June 11, 2024,

Calibration of the Hach equipment was conducted on November 24, 2024.

Calibration of the pH meter is conducted regularly.

**f) Description of efforts made, and results achieved in meeting the effluent objectives.**

The Region continually strives to achieve the best effluent quality at all times and remain below the objectives specified in the ECA.

The Nonquon WPCP effluent objectives were met in 2024 except for:

- The total phosphorus objective of 0.08 milligrams per litre (mg/L) was exceeded in 101 of 362 samples (27.9%).
- The total suspended solid's objective of 8.0 milligrams per litre (mg/L) was exceeded in 68 of 362 samples (18.8%).

Filter maintenance was conducted frequently to reduce total suspended solids and total phosphorous values to maintain results below objectives.



## Nonquon Water Pollution Control Plant 2024 Annual Performance Report

---

- g) A tabulation of the volume of sludge generated in the reporting period, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed.**

Waste Activated Sludge is discharged into the lagoons on-site. No sludge was removed during the reported period. The volume of biosolids will be calculated and reported in the year when sludge is removed from the site for final treatment or disposal.

Even with the increase in population on a year-to-year basis, no significant changes to flows or processing are anticipated. Therefore, no significant changes in sludge generation are expected for the next year.

- h) Summary of any complaints received during the reporting period and any steps taken to address the complaints.**

All complaints received from the public are administered and tracked through a central database. No complaints were received in 2024.

- i) Summary of all By-pass, spill, or abnormal discharge**

No by-passes or spills occurred during the reporting period.

- j) Copy of all Notice of Modifications and any implementation of Limited Operational Flexibility (Schedule B)**

No notices of modifications were submitted in 2024.

- k) Report summarizing modifications (Schedule B, Section 3)**

There were no modifications in 2024.

- l) Information required by Ministry of the Environment, Conservation and Parks Water Supervisor**

No additional information was requested.

### **Ministry of the Environment, Conservation and Parks (MECP) Inspection**

The plant was inspected by the MECP on March 5, 2019.



**Nonquon Water Pollution Control Plant  
2024 Annual Performance Report**

**Table 1 Final Effluent Flows**

Month	Total Plant Flow* cubic metre (m <sup>3</sup> )	Average Daily Flow cubic metre per day (m <sup>3</sup> /d)	Maximum Daily Flow m <sup>3</sup> /d
January	102,975	3,322	4,837
February	89,834	3,098	3,755
March	105,760	3,412	4,418
April	133,326	4,444	6,381
May	106,680	3,441	5,128
June	79,109	2,637	3,296
July	88,860	2,866	4,038
August	95,160	3,070	4,044
September	90,954	3,032	3,325
October	94,504	3,049	3,377
November	84,604	2,820	3,347
December	106,204	3,426	5,122
Total	1,177,970		
Annual Average	98,164	3,218	
Minimum	79,109		
Maximum	133,326		6,381
ECA Limit		5,900**	
Met Compliance		Yes	

\*Metered at the Final Effluent

\*\*Annual Average



**Nonquon Water Pollution Control Plant  
2024 Annual Performance Report**

**Table 2 Raw Influent Analyses**

Month	Biochemical Oxygen Demand (BOD <sub>5</sub> ) average (avg.) concentration (conc.) milligrams per litre (mg/L)	Total Suspended Solids (TSS) avg conc. mg/L	Total Phosphorus (TP) avg conc. mg/L	Total Kjeldahl Nitrogen avg. conc. mg/L
January	115	155	3.0	27.50
February	140	177	3.4	31.28
March	119	184	3.7	31.35
April	120	151	2.9	25.20
May	130	179	3.3	26.43
June	143	240	4.1	32.05
July	142	195	3.5	28.10
August	132	164	3.6	28.35
September	144	194	3.7	30.00
October	148	183	3.8	34.02
November	143	218	4.4	36.00
December	155	239	3.9	28.98
Average	136	190	3.6	29.94
Minimum	115	151	2.9	25.20
Maximum	155	240	4.4	36.00
Sampling Frequency Requirement Met	Yes	Yes	Yes	Yes



**Nonquon Water Pollution Control Plant  
2024 Annual Performance Report**

**Table 3 Final Effluent Analyses**

Month	Carbonaceous Biochemical Oxygen Demand (CBOD <sub>5</sub> ) average (avg.) concentration (conc.) milligrams per litre (mg/L)	CBOD <sub>5</sub> loading kilograms per day (kg/d) year to date avg.	Total Suspended Solids (TSS) avg. conc. mg/L	TSS kg/d year to date avg.
January	1.1	3.7	9.6	32.0
February	1.0	3.4	9.3	30.9
March	1.2	3.7	6.7	28.3
April	1.1	4.0	7.3	29.6
May	1.0	3.9	5.2	27.2
June	1.1	3.7	3.0	23.4
July	1.2	3.7	4.1	21.5
August	1.2	3.7	2.2	19.5
September	1.1	3.6	3.2	18.4
October	1.3	3.7	2.1	17.1
November	1.5	3.7	2.6	16.1
December	1.3	3.8	4.0	15.9
Annual Loading		3.8**		15.9**
Average	1.5*		4.8*	
Minimum	1.0	3.4	2.1	15.9
Maximum	1.5	4.0	9.6	32.0
ECA Limit	5.0*	29.5**	10.0*	59.0**
ECA Objective	4.0		8.0	
Within Compliance	Yes	Yes	Yes	Yes
Sampling Frequency Requirement Met	Yes		Yes	

\*Annual Average Concentration

\*\*Annual Average Loading



**Nonquon Water Pollution Control Plant  
2024 Annual Performance Report**

**Table 3 Final Effluent Analyses Continued**

Month	Total Phosphorus (TP) average (avg.) concentration (conc.) milligrams per litre (mg/L)	TP kilograms per month (kg/m) monthly avg.	TP kilograms per year (kg/year) to date avg.
January	0.11	11.3	11
February	0.11	9.9	21
March	0.09	9.5	31
April	0.10	13.3	44
May	0.07	7.5	52
June	0.03	2.4	53
July	0.05	4.4	57
August	0.03	2.9	59
September	0.04	3.6	62
October	0.04	3.8	66
November	0.04	3.4	69
December	0.06	6.4	76
Annual Loading			76**
Average	0.06	6.5	
Minimum	0.03	2.4	
Maximum	0.11	13.3	
ECA Limit		14.2* May to October	170**
ECA Objective	0.08		
Within Compliance		Yes	Yes
Sampling Frequency Requirement Met	Yes	Yes	Yes

\*Monthly Average Loading

\*\*Annual Average Loading



**Nonquon Water Pollution Control Plant  
2024 Annual Performance Report**

**Table 3 Final Effluent Analyses Continued**

Month	pH minimum	pH maximum	Temperature Degree Celsius average (avg.)
January	7.0	7.2	12.4
February	7.1	7.4	12.3
March	7.0	7.2	13.0
April	6.9	7.3	13.7
May	7.1	7.3	16.0
June	7.0	7.2	18.2
July	7.0	7.2	20.0
August	6.9	7.2	20.9
September	7.0	7.2	20.4
October	6.9	7.3	17.9
November	6.8	7.2	16.1
December	6.7	7.2	13.3
Average			16.2
Minimum	6.7		12.3
Maximum		7.4	20.9
ECA Limit	6.0	9.5	
Within Compliance	Yes	Yes	
Sampling Frequency Requirement Met	Yes	Yes	Yes



**Nonquon Water Pollution Control Plant  
2024 Annual Performance Report**

**Table 4 - Effluent Objectives for Total Ammonia Nitrogen**

Month	Total Ammonia Nitrogen (TAN) average (avg.) concentration (conc.) milligrams per litre (mg/L)	TAN Effluent Objective conc. mg/L	TAN Effluent Limit Monthly avg. conc. mg/L
January	0.8	4.0	5.0
February	0.0	4.0	5.0
March	0.0	4.0	5.0
April	0.1	4.0	5.0
May	0.0	2.4	3.0
June	0.0	1.2	1.5
July	0.0	1.2	1.5
August	0.0	1.2	1.5
September	0.0	1.2	1.5
October	0.0	2.4	3.0
November	0.0	4.0	5.0
December	0.1	4.0	5.0
Average	0.1		
Minimum	0.0		
Maximum	0.8		
Within Compliance	Yes		



**Table 5 *Escherichia coli* Sampling**

<b>Month</b>	<b>Number of Samples</b>	<b>Monthly Geometric Mean Density</b>
January	10	3
February	8	2
March	8	2
April	9	22
May	9	7
June	8	1
July	10	7
August	8	2
September	8	6
October	10	4
November	8	2
December	8	7
ECA Objective		100 organisms/100mL
ECA Limit		200 organisms/100mL
Within Compliance		Yes
Sampling Frequency Requirement Met	Yes	



**Nonquon Water Pollution Control Plant  
2024 Annual Performance Report**

---

**Table 6 Energy and Chemical Usage**

<b>Month</b>	<b>Aluminum Sulphate litres</b>	<b>Hydro kilowatt hours</b>
January	23,679	101,112
February	18,178	96,646
March	19,652	99,696
April	19,476	81,246
May	20,653	74,394
June	15,903	69,067
July	14,646	69,964
August	14,921	62,071
September	12,796	54,836
October	15,412	66,220
November	15,815	82,480
December	16,899	115,888
<b>Total</b>	<b>208,030</b>	<b>973,621</b>